

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 27-Oct-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity		Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW			
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1*260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1*210	180	0	0	Machine problem
3	Ghorasal 365 MW CAPP Unit-7	PDB	1*210+1*122	365	0	3906000	Under maint.
4	Ghorasal 78.5 MW PP(MAX)	ORPP	2*40	0	0	0	Under maint.
5	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	83	1539954	Engine problem
6	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
7	Haripur 412 MW CAPP	EGCB	1*273+1*139	412	402	9558020	Gas shortage
8	Haripur 380 MW CAPP(HPL)	IPP	1*230+1*155	385	262	6348000	Gas shortage
9	Meghnaghat 450 MW CAPP(MPL)	IPP	2*150+1*150	450	225	5124800	Gas shortage
10	Meghnaghat 100 MW(EL)	NENP	12*8.9	100	78	1423680	Engine problem
11	Meghnaghat CAPP(Summit)	IPP	2*110+1*110	335	140	3223011	Gas shortage
12	Madanganj 102 PP(Summit)	NENP	6*17	102	0	0	Under maint.
13	Madanganj-55 MW PP(Summit)	IPP	3*17.08+1*11.3	55	30	1023267	Engine problem
14	Keraniganj 100 MW PP (Powerpac)	ORPP	8*13.45	0	0	0	Contract Expired
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	358344	Engine problem
16	210 MW Siddhirgonj TPP	PDB	1*210	115	0	0	Under maint.
17	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	210	0	0	Gas shortage
18	Siddhirgonj 100 PP(Dutch Bangla)	NENP	12*8.9	100	88	1708800	Engine problem
19	Siddhirgonj 335 MW CAPP	EGCB	1*217+1*118	335	0	0	Under maint.
20	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	83	1346112	Engine problem
21	Katpali 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
22	Karnalghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	649800	Engine problem
23	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	110	1430400	Engine problem
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	897228	Engine problem
25	Manikganj 55 MW PP (Southern power)	IPP	3*19.3	55	17	410849	Engine problem
26	Bosila 108MW PP(CCLC)	IPP	12*8.75+1*3.5	0	0	0	Under maint.
27	Summit Power (Madhabdi-Ashulia)	SIPP, REB	33.67+4*8.73	80	49	1028380	Engine problem
28	Mazna 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	784400	Engine problem
29	Rugganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	30	761900	Engine problem
30	Gazipur 52 MW PP	RPCL	6*8.9	52	41	685440	Engine problem
31	Tongi 80 MW GTPP	PDB	1* 105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	275	4127455	Engine problem
33	Keraniganj 300 MW PP (ARR)	IPP	25*11.4	300	53	625394	Fuel conservation
34	Bramhataganj 100 MW PP (Aggreko)	IPP	114*0.959	100	50	350800	Fuel conservation
35	Aurahati 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	50	356133	Fuel conservation
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	117	2066980	Engine problem
37	Gazipur 100 MW PP	RPCL	6*17.5	105	88	1677600	Engine problem
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	92	1692480	Engine problem
39	Manikganj 162MW PP(MPL)	IPP	9*18	162	162	1679200	Engine problem
40	Spectra Solar Plant Ltd.	IPP	35	35	0	185315	Under maint.
40	Kanchan Purbachal Power Generation Ltd.	IPP	18.4*3	55	54	1218240	Under maint.
<b>Dhaka area Total</b>				<b>5847</b>	<b>2917</b>	<b>56388672</b>	
41	Chattogram TPP-1	PDB	1*210	180	0	0	Machine problem
42	Chattogram TPP-2	PDB	1*210	180	0	0	Gas shortage
43	Razzan 25 MW PP	RPCL	3*8.9	25	25	507821	Under maint.
44	Teknaf 200MW PP (Solartech)	IPP	20	20	20	146475	Under maint.
45	Kaptai 50MW PP (Baraka)	IPP	9*6.98	50	44	369720	Engine problem
46	Kaptai Hydro. Unit-1,2,3,4, 5	PDB	2*40+3*50	230	152	3678618	Low water level
47	Sikalbaha 225MW	PDB	1*150+1*175	225	151	3418807	ST Under maint
48	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	105	1779781	Under maint.
50	Hathazari 100 MW peaking PP	PDB	11*8.9	98	23	309504	Fuel shortage
51	Dohazari 100 MW Peaking	PDB	8*17	102	51	593010	Engine problem
52	Juidah 100 MW Unit-1 (Acorn)	NENP	8*13.45	100	55	707640	Fuel shortage
53	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8*13.5	100	50	745920	Engine problem
54	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	0	0	Engine problem
55	Malancha, Ctg. EPZ (Uniled)	IPP	5*8.73+3*9.34	0	9	407520	Under maint.
56	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	2	0	Fuel shortage
57	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	27359	Under maint.
58	Anwara 300 MW PP (Uniled)	IPP	17*17.24	300	283	3591200	Engine problem
59	Jodac Power	IPP	3*18.55+1*3.6	54	54	1268445	Under maint.
60	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	105	1809047	Under maint.
61	Juidah unit-2 (Acorn)	IPP	8*13.6	100	50	762240	Engine problem
62	Anlima Energy Ltd.	IPP	6*21.2	116	107	1894384	Engine problem
<b>Mirshara 150 MW</b>			<b>BPDB-RPCL</b>	<b>18.5*9</b>	<b>0</b>	<b>23418</b>	<b>On test.</b>
<b>Chattogram area Total</b>				<b>2382</b>	<b>1286</b>	<b>2153789</b>	
63	Ashuganj TPP Unit-3	APSCCL	1*150	0	0	0	Contract Expired
64	Ashuganj TPP Unit-4	APSCCL	1*150	0	0	0	Contract Expired
65	Ashuganj TPP Unit-5	APSCCL	1*150	134	0	0	Gas shortage
66	Ashuganj 225 MW CAPP	APSCCL	1*142+1*75	221	123	4100000	Gas shortage
67	Ashuganj 450 MW CAPP(North)	APSCCL	1*360	360	280	7058700	Gas shortage
68	Ashuganj 450 MW CAPP(South)	APSCCL	1*360	360	160	4951000	Gas shortage
69	Ashuganj 450 MW CAPP(East)	APSCCL	284*1+136*1	284	75	914200	On test
70	Ashuganj 50 MW PP	APSCCL	14*3.968	45	5	154152	Gas shortage
71	Ashuganj 55 MW PP (Precision)	ORPP	15*4	55	5	144960	Gas shortage
72	Ashuganj 195MW PP (APSCCL-Uniled)	IPP	20*9.73+1*16	195	8	200727	Gas shortage
73	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	0	Gas shortage
74	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	78	1388363	Fuel shortage
75	Titas 50 MW Peaking PP	PDB	6*8.92	52	37	439920	Engine problem
76	Chandpur 150 MW CAPP	PDB	1*106+1*57	163	0	0	Machine problem
77	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	167	1306560	High voltage
78	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	433584	Under maint.
79	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	239400	Under maint.
80	Imported (Tripura)	Imported power	0	160	124	2711040	Under maint.
81	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	13	534400	Engine problem
82	Jangalia 40 MW PP (Lakshmi)	IPP	6*8.92	52	43	240830	Engine problem
83	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	15	350150	Engine problem
84	Daudkandi 200 MW PP (B.Trac)	IPP	15*14.4	200	50	116160	Fuel conservation
85	Feni Lanka Power	IPP	7*18.415+1*9.78	114	114	837900	Under maint.
86	Chowmahani 113 MW	IPP	12*9.78+2*3.1	113	0	0	Fuel shortage
87	Bhairab 54.5 MW	IPP	3*18.2	54	35	856800	Engine problem
88	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	115	1779840	Under maint.
<b>Cumilla Area Total</b>				<b>3169</b>	<b>1477</b>	<b>2876788</b>	
89	RPCL 210MW CAPP	IPP	4*35+1*70	202	45	1643520	Gas shortage
90	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	18	425052	Engine problem
91	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
92	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12500	Under maint.
93	Mymensingh 200 MW PP (Uniled)	IPP	9*78*21	200	89	1413600	Fuel shortage
94	Jamalpur 115 MW PP (Uniled)	IPP	9*78*12	115	99	1489200	Engine problem
95	Sulakhali 50 MW Solar PP	IPP	50	50	0	314340	Under maint.
96	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	12	294960	Engine problem
<b>Mymensingh Area Total</b>				<b>614</b>	<b>263</b>	<b>5593172</b>	
97	Fenchugonj CAPP Phase-1	PDB	2*32+1*33	70	30	715000	Machine problem
98	Fenchugonj CAPP Phase-2	PDB	2*35+1*35	90	42	975760	Machine problem
99	Kushnara 163 MW CAPP (KP)	IPP	1*109+1*54	163	0	0	Gas shortage
100	Shajibazar 333 MW CAPP	PDB	3*330	330	0	0	Under maint.
101	Fenchugonj 51 MW PP (Barakatullah)	RPP	19*2.90	51	11	265200	Gas shortage
102	Fenchugonj 44MW (Energyprima)	NENP	12*3.3+5*2	50	10	293616	Gas shortage
103	Hobiganj 11MW PP Cofidence-E	SIPP, REB	4*2.90	11	5	120960	Gas shortage
104	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	32	754176	Gas shortage
105	Shahjibazar 90MW PP (Shahjibazar)	RPP	3*2.90	86	81	1361280	Under maint.
106	Shahjibazar 100 MW GTPP	PDB	1*100	100	0	0	Under maint.
107	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	185	4347030	Machine problem
108	Sylhet 20 MW GTPP	PDB	1*20	20	18	440000	Under maint.
109	Sylhet 50MW PP (EPL)	NENP	27*2	50	11	262200	Gas shortage
110	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	8	183024	Gas shortage
111	Bibiyan-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	270	7047500	FGMO
112	Bibiyan 225 MW CAPP	PDB	400 MW	400	400	9293000	Under maint.
113	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	235980	Under maint.
114	Bibiyan South 400 MW	PDB	400 MW	383	400	9061400	Under maint.
<b>Sylhet Area Total</b>				<b>2477</b>	<b>1513</b>	<b>3533126</b>	
115	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Fuel shortage
116	Bheramara (HVDC)	Imported power	2*500	1000	902	20365090	Under maint.
117	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	32	344640	Fuel shortage
118	Fardpur 22 MW Peaking PP	PDB	8*6.98	54	39	151200	Fuel shortage
119	Khulna 225 MW CAPP	NWPGCL	1*150+1*75	230	0	0	Fuel shortage
120	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	74	459776	Fuel shortage
121	Bheramara 410 MW CAPP	NWPGCL	1*278+1*132	410	175	4561056	Gas shortage
122	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	0	0	Fuel shortage
123	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	30	54720	Fuel conservation
124	Rupsha 118 MW PP (Orion rupsha)	IPP	6*18.445	105	56	1289120	Engine problem
125	Madhumati 100 MW PP	NWPGCL	0	105	0	0	Fuel shortage
126	Mongla Orion 100 MW Solar PP	IPP	100	100	0	543600	Under maint.
127	Khulna 330 MW CAPP (OIL)	BPDB	1*220+1*110	0	0	1584993	On test.
128	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	On test.
<b>Khulna Area Total</b>				<b>2384</b>	<b>1308</b>	<b>28324195</b>	
129	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Line O/L
130	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	22	382295	Engine problem
131	Bhola 225 MW CAPP	PDB					