

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1260	260	0	0	
2	Ghorasal Repowered CAPP Unit-4	PDB	1210	180	0	0	Machine problem
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4381650	
4	Ghorasal 365 MW CAPP Unit-7	PDB	1243+1122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
6	Ghorasal 108MW PP (Regent)	IPP	343.35	208	81	1913181	Engine problem
7	Haripur GTPP	SBU, PDB	232	0	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1273+1139	412	360	9381890	Gas shortage
9	Haripur 360MW CAPP(HPL)	IPP	1235+1125	360	305	7380000	Gas shortage
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2150+1150	450	225	5308800	Gas shortage
11	Meghnaghat 100 MW(IEI)	NENP	12.9	100	81	956160	Engine problem
12	Meghnaghat CAPP(Summit)	IPP	2110+1110	335	124	3249775	Gas shortage
13	Madaniganj 102 PP(Summit)	NENP	617	102	0	0	Under maint.
14	Madaniganj-55 MW PPS(Summit)	IPP	317.08+111.3	55	55	1276094	
15	Keraniganj 100 MW PP (Powerpac)	QRPP	813.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	82.90	22	16	313380	Engine problem
17	210 MW Siddhirganj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirganj 2120 MW GTTP	EGCB	2105	210	0	0	Gas shortage
19	Siddhirganj 100 PP(Dutch) Bangla	NENP	128.9	100	79	1189440	Engine problem
20	Siddhirganj 335 MW CAPP	EGCB	1217+118	335	0	0	
21	Gagnagar 102 MW PP (Digital Power)	IPP	128.924	102	92	876384	Engine problem
22	Kaipoti 52 MW PP (Sinha)	IPP	77.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	318	54	54	637920	
24	Kodda 150MW PP	BPDB-RPCL	917.06	149	82	636600	Engine problem
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	55	879634	
26	Nabaganj 55 MW PP (Southern power)	IPP	319.3	55	35	600384	Engine problem
27	Bosila 108MW PP(CLC)	IPP	128.775+113.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	33.67+48.73	80	52	1023140	Engine problem
29	Madhabdi 33 MW PP(Summit)	SIPP, REB	48.73	33	33	612880	
30	Ruaganj 30 MW PP(Summit)	SIPP, REB	48.73	33	32	780000	Engine problem
31	Gazipur 52 MW PP	RPCL	68.9	52	8	234240	Engine problem
32	Tongi 80 MW GTTP	PDB	1105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	248	2353527	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	2567.4	300	0	0	Fuel conservation
35	Bramhanaga 100 MW PP (Aggreko)	IPP	1149.959	100	0	0	Fuel conservation
36	Aurahi 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	0	0	Fuel conservation
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.45+8.97	149	93	1027870	Engine problem
38	Gazipur 100 MW PP	RPCL	617.5	105	88	1642800	Engine problem
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.56	104	93	1641600	Engine problem
40	Manikganj 162MW PP(MPGL)	IPP	918	162	162	1795680	
41	Spectro Solar Plant Ltd.	IPP	35	35	0	213064	
42	Kanchan Furbachal Power Generation Ltd.	IPP	18.43	55	54	1104120	
Dhaka area Total				5847	2687	51620213	
43	Chattoogram TPP-1	PDB	1210	180	0	0	Machine problem
44	Chattoogram TPP-2	PDB	1210	180	0	0	Gas shortage
45	Raozan 25 MW PP	RPCL	39.9	25	25	241135	
46	Tafal 20MW PP (Solaritech)	IPP	20	20	0	141480	
47	Palenga 50MW PP (Baraka)	IPP	86.98	50	21	190080	Engine problem
48	Kapali Hydro Unit-1,2,3,4, 5	IPP	240+350	230	153	3684422	Low water level
49	Sikalbaha 225MW	PDB	1150+1175	225	141	3657260	ST Under maint.
50	Sikalbaha Peaking GT	PDB	1150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	617.5	105	105	1755527	Gas shortage
52	Hathazari 100 MW Peaking PP	PDB	119.9	102	23	182692	Fuel shortage
53	Dohazari -Kalaish 100 MW Peaking	PDB	617	102	51	234999	Engine problem
54	Jullaha 100 MW Unit-1 (Accorn)	NENP	813.45	100	55	686280	Fuel shortage
55	Jullaha 100 MW PP Unit-3 (Accorn)	IPP	813.5	100	50	723840	Engine problem
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	82.90	22	0	0	Engine problem
57	Manarcho, Ch. EPZ Unit-3	IPP	58.73+9.34	0	32	807840	
58	Chattoogram 108 MW PP (ECPV)	IPP	167.9	108	0	0	Fuel shortage
59	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	25663	
60	Anwara 300 MW PP (United)	IPP	1717+24	300	282	3093709	Engine problem
61	Jodiach Power	IPP	318.55+113.6	54	54	794256	
62	Kanaphuli Power Ltd.	IPP	18.15+6+8.5	110	105	1755520	
63	Jullaha Unit-2 (Accorn)	IPP	813.5	100	43	651840	Engine problem
64	Anlima Energy Ltd.	IPP	621.2	116	53	895745	Engine problem
65	Minshahi 150 MW	BPDB-RPCL	18.59	0	0	0	On test.
Chattoogram area Total				2382	1193	19582088	
66	Ashuganj TPP Unit- 3	APSCL	1150	0	0	0	Contract Expired
67	Ashuganj TPP Unit- 4	APSCL	1150	0	0	0	Contract Expired
68	Ashuganj TPP Unit- 5	APSCL	1150	134	0	0	Gas shortage
69	Ashuganj 225 MW CAPP	APSCL	1142+1175	221	179	3822000	Gas shortage
70	Ashuganj 450 MW CAPP(North)	APSCL	1360	360	280	7079300	Gas shortage
71	Ashuganj 450 MW CAPP(South)	APSCL	1360	360	0	0	Gas shortage
72	Ashuganj 420 MW CAPP(East)	APSCL	2841+1361	284	0	4150900	On test.
73	Ashuganj 50 MW PP	APSCL	143.968	45	46	381816	Gas shortage
74	Ashuganj 100 MW PP (Precision)	QRPP	157.4	55	50	1198400	Gas shortage
75	Ashuganj 195MW PP (APSCL-United)	IPP	209.73+116	195	177	1321454	Gas shortage
76	Ashuganj 51 MW PP (Midland)	IPP	69.34	51	0	0	Gas shortage
77	Ashuganj 150MW PP (Midland)	IPP	237.015	150	63	812945	Fuel shortage
78	Titas 50 MW Peaking PP	PDB	68.92	52	47	217344	Engine problem
79	Chandpur 150 MW CAPP	PDB	12106+157	163	0	0	Machine problem
80	Chandpur 200MW (Desh energy)	IPP	1214.4	200	51	1374720	High voltage
81	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	19	438948	
82	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	11	238680	
83	Import (Tripura)	Imported power	0	160	116	2450880	
84	Jangalia 33MW PP (Summit)	SIPP, PDB	48.73	33	33	688600	Engine problem
85	Jangalia 52 MW PP (Lakshmi)	IPP	618.92	52	52	161611	Engine problem
86	Cumilla 25 MW PP (Summit)	SIPP, REB	33.67+26.97	25	18	333300	Engine problem
87	Daudkandi 200 MW PP (B. Trac)	IPP	1541.4	200	0	0	Fuel conservation
88	Feni Lanka Power	IPP	718.415+19.78	114	92	758100	Engine problem
89	Chowmuhani 113 MW	IPP	129.78+23.1	113	0	84000	Fuel shortage
90	Bharob 54.5 MW	IPP	318.2	54	35	886880	Engine problem
91	Chandpur 115 (Doreen)	IPP	418.5+222.5	115	110	1658840	
Cumilla Area Total				3169	1359	27280158	
92	RPCL 210MW CAPP	IPP	4156+170	202	67	1833600	Gas shortage
93	Tangal 22 MW PP (Doreen)	SIPP, PDB	82.90	22	18	421380	Engine problem
94	Jamalpur 95 MW PP(Powerpac)	IPP	128.924	0	0	0	Under maint.
95	Sarishabari 3 MW Solar Plant	IPP	13	3	0	14450	
96	Mymensingha 200 MW PP (United)	IPP	978921	87	200	1324800	Fuel shortage
97	Jamalpur 115 MW PP (United)	IPP	97812	115	98	1324800	Engine problem
98	Suliakhali 50 MW Solar PP	IPP	50	50	0	366270	
99	Tangal Pali Power Gen 22 MW	IPP	46.7	22	12	297840	Engine problem
Mymensingha Area Total				614	282	5583140	
100	Fenchuganj CAPP Phase-1	PDB	232+133	70	20	717000	Machine problem
101	Fenchuganj CAPP Phase-2	PDB	235+135	90	43	957240	Machine problem
102	Kushara 183 MW CAPP (KP)	IPP	1109+1154	163	0	0	Gas shortage
103	Shahjibazar 330 MW CAPP	PDB	3110	330	0	0	Under maint.
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	192.90	51	11	264600	Gas shortage
105	Fenchuganj 44MW (Energyprima)	NENP	123.3+52	50	10	299880	Gas shortage
106	Haldiganj 11MW PP Confidence-E	SIPP, REB	42.90	5	5	121100	Gas shortage
107	Shahjibazar GTTP Unit- 3 & 9	PDB	235	86	40	1068992	Gas shortage
108	Shahjibazar 86MW PP (Shahjibazar)	RPP	322.90	86	50	758400	
109	Shahjibazar 100 MW GTTP	PDB	1100	100	0	0	Under maint.
110	Sylhet 225 MW CAPP	PDB	1142+189	231	192	4568540	Machine problem
111	Sylhet 20 MW GTTP	PDB	120	20	18	441000	
112	Sylhet 50MW PP (EP)	NENP	272	50	11	261660	Gas shortage
113	Shahjahanulla 25 MW PP	SIPP, REB	39.34	25	8	192000	Gas shortage
114	Bitiana-II 341 MW CAPP (Summit)	IPP	1222+1119	341	255	7082000	FGMO
115	Bitiyana-III 400 MW CAPP	PDB	400 MW	400	329	9069000	
116	Sylhet 10MW PP (Desh)	RPP	61.95	10	10	237240	
117	Bitiyana South 400 MW	PDB	400 MW	383	313	8440000	
Sylhet Area Total				2477	1325	34506852	
118	Bheramara GTTP Unit- 3	PDB	120	16	0	0	Fuel shortage
119	Bheramara (HVDC)	Imported power	2500	1000	907	21924363	
120	Khulina 115 PP MW (KPCL-2)	NENP	717	115	32	294720	Fuel shortage
121	Fardpur 50 MW Peaking PP	PDB	68.89	54	39	70560	Fuel shortage
122	Khulina 225 MW CAPP	NWPGCL	1150+1175	230	0	0	Fuel shortage
123	Casapora 100 MW Peaking PP	IPP	1816.98	109	74	242944	Fuel shortage
124	Bheramara 410 MW CAPP	NWPGCL	1278+1132	410	175	4594464	Gas shortage
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	58.5	40	0	0	Fuel shortage
126	Noapara 100 MW PP (Bangla Trac)	IPP	701.4	100	0	0	Fuel conservation
127	Rupsha 105 MW PP (Orion rupsha)	IPP	618.445	105	56	875040	Engine problem
128	Madhumati 180 MW PP	NWPGCL	618	105	0	0	Fuel shortage
129	Mongia Orion 100 MW Solar PP	IPP	100	100	0	573120	Fuel shortage
130	Khulina 330 MW CAPP (DIL)	BPDB	1220+1110	0	0	0	On test.
131	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	On test.
Khulina Area Total				2384	1283	28575211	
132	Barisal 110 MW PP (Summit)	IPP	717.076	110	0	0	Line O/L
133	Bhola 33 MW PP (Venture)	NENP	134.50	40	17	327060	Engine problem
134	Bhola 225 MW CAPP	PDB	2630+188	194	74	1948936	Gas shortage
135	Bhola 95 MW PP (Aggreko)	QRPP	961.10	0	0	0	Contract Expired
136	Payra 1320 MW	BCPCL	2622	1244	770	17964600	Line O/L
137	Bhola Nutan Biddut BD LTD	IPP	220	220	180	4543336	
138	United Payra Power Ltd.	IPP	618.5+19.5	150	0	0	Line O/L
Barisal Area Total				1958	1041	2482378	
139	Baghabari 71 MW GTTP	PDB	1171	71	0	0	Gas shortage
140	Baghabari 100 MW GTTP	PDB	1100	100	0	0	Gas shortage
141	Baghabari 50 MW Peaking PP	PDB	68.9	52	24	31716	Engine problem
142	Bera 70 MW Peaking PP	PDB	98.29	71	4	10728	Engine problem
143	Ammura 50 MW PP(Sinha)	QRPP	77.79	0	0	0	Contract Expired
144	Katakhali 50 MW PP (Northern)	QRPP	68.9	50	16	307920	Engine problem
145	Kotakhali 50 MW Peaking PP	PDB	98.7	50	32	502940	Engine problem
146	Sirajgonj Unit-1 225MW	NWPGCL	1150+1175	210	0	0	Gas shortage
147	Sirajgonj Unit-2 225MW	NWPGCL	1150+1175	220	0	0	
148	Sirajgonj Unit-3 225MW	NWPGCL	1141	220	131	3473027	Gas shortage
149	Sirajgonj 400 MW CAPP Unit-4	SNWPGCL	1282+1132	414	233	5789309	Gas shortage
150	Santala 100 MW Peaking PP	PDB	618	35	35	59004	Engine problem
151	Bogra 22 MW PP (GEB)	RPP	64	22	0	0	Gas shortage
152	Bogra 20 MW PP (Energyprima)	NENP	513.3+52	0	0	0	
153	Ullapara 11 MW PP (Summit)	SIPP, REB	42.90	11	0	0	Gas shortage
154	Natore 52 MW PP (Rajlanka)	IPP	68.92	52	16	80640	Fuel shortage
155	Chapanawabaganj 10						