

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month October, 2022				Day: Monday				Date: 31.10.22			
Probable Maximum Demand : 11800 MW				Probable Maximum Generation : 11849 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 96.13 ft		Today = 95.90 ft		Rule Curve = 108.90 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.10.22 (Yesterday)		31.10.22 (Today)		30.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	0	0	0	0		Line Overload
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	76	79	80	80		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	273	258	260	275	102	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	205	225	225	245	Gas Shortage
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	407	397	400	400		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	135	138	135	135	197	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	92	60	92		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	16	16		
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	44	51	50	53		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	13	20	33	33		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	49	49	49		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	88	88	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	87	130	48	90		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	265	278	225	275		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	135	145	80	149		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	227	84	200	150		
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	25	100	50		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	90	25	100	50		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	71	71	74	92		
32	Manikganj 162MW PP(MPL)	HFO (IPP)	9x18	162	162	35	162	35	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	37	54	54	54		
35	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	71	89	70	90		
36	Meghnaghat 100 MW (EEL)	HFO (NENP)	12x8.9	100	100	68	85	70	80		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total				6004	5847	2943	2976	2837	3120	1194	740
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	153	151	152	152		Unit 1 under rehabilitation
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	0	5	0	180	Under maint.
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	11	25	17	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	44	44	44	44		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	105	70	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	150	150	150	75	STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	123	285	140	285		
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	25	50	25	50		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	16	51	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	23	24	24	24		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34	22	22	2	5	10	10		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108	Fuel oil shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	54	54	54	54		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	70	108	70	105		
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	50	25	50		
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	22	55	22	55		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
	Mirsharal 150 MW	HFO (BRPgen)	9x18.5			3	0	0	0		on test
Chattogram Zone Total				2442	2382	886	1261	947	1267	310	405
58	Ashuganj TPP Unit-5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	42	51	50	50		
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	197	191	180	200		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0	360	Under maint.
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	290	330	320	330		
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCl)	1x284	284	284	0	0	0	0	284	Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	50	50	50	50		
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*16	195	195	187	189	185	185		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51	Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	58	0	70	85		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	37	47	0	47		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	180	100	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	21	21		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	15	33	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	16	43	8	43		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	21	15	18		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.515+15x1.058	200	200	100	60	100	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	96	114	114		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	0	0	113	Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	17	35	35		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	63	115	53	115		
**	Import (Tripura)	India		160	160	130	146	143	166		
Cumilla Zone Total				3193	3169	1338	1600	1487	1811	582	523
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	57	60	90	145	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	100	90	100		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	87	45	88	113	Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	53	0	50	0		
87	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total				622	614	214	274	277	308	0	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.10.22 (Yesterday)		31.10.22 (Today)		30.10.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/Water Limitation		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	MW	MW		
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	G1-Under maint.
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	G1-Under maint.
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	0	0	0			
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	62	66	65			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	0	81			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	145	145	145			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	11	18	19	19			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	8	16	17		Gas Shortage
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	300	305	300			
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	404	409	400	400			
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	390	398	400	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	26	0	0	0	50		Gas Shortage
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.4'5'2	50	50	40	0	0	0	50		Gas Shortage
Sylhet Zone Total												
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	170	175	170	200	235		Gas Shortage
108	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	50	50	0	16	0	16			
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	68	0	70			
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	225	225	0	0	0	0			
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	10	0	50			
112	Rupsha 105 MW PP (Orion nupsha)	HFO (IPP)	6x18.445	105	105	76	95	75	55			
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0			
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	86	0	100	0			
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	29	32	0	32	83		Fuel oil shortage
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	8	32		Fuel oil shortage
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0			
	Khulna 330 MW CAPP	Gas/HSD (BFPCL)				0	0	0	0			
**	Bheramara (HVDC)	India		1000	1000	907	908	924	924			
Khulna Zone Total												
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	16		110	Line Overload
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	19	16	22			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	0	0	0	0	194		Gas Shortage
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	760	900	810	900			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload
122	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220			
Barishal Zone Total												
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32			
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	46	0	100			
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	26	0	22		45	Under maint.
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	87	0	86			
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	32	0	32			
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42			
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	30	0	35			
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	126	133	157	157	87		Gas Shortage
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	214	228	260	260	186		Gas Shortage
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	0	0	0	22		Gas Shortage
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0	11		Gas Shortage
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	96	113	113	113			
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	113	113	113	113			
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
Raishahi Zone Total												
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	80	80	82	907	45	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0		274	Under maint.
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	87	113	100	113			
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
146	Majpara, Tulsia 8 MW Solar PP (Simpa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	35	115	35	115			
148	Jamshaid 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	34	0	12	0			
Rangpur Zone Total												
Sub-total: Plants in operation												
22088 21710 9865.0 11230 10226 11849 4021 2903												
(B) Plants under long term maintenance/ contract expired												
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
153	Boqura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020
154	Aminura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 1/10/2022
Sub-Total: Plants under long term maintenance/ contract expired												
424 0 0 0 0 0 0 0												
Gross Total												
22512 21710 9865 11230 10226 11849 4021 2903												
(C) Actual data of 30.10.22 (Yesterday) Sunday :												
01.	Max. Demand at eve. peak (Generation end)	11300 MW, at = 19:30 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	10860 MW, at = 19:30 hrs										
03.	Highest Generation (Generation end)	11230 MW, at = 19:30 hrs										
04.	Minimum Generation (Generation end)	7713 MW, at = 6:00 hrs										
05.	Day-peak Generation (Generation end)	9865 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	11230 MW, at = 19:30 hrs										
07.	Evening Peak Load-shed (Sub-station end)	65 MW, at = 19:30 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	8172 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
a)	Gas/LF limitation	4021 MW										
d)	Coal supply Limitation	0 MW										
b)	Low water level in Kaptai lake	0 MW										
c)	Plants under shut down/ maintenance	2903 MW										
10.	Total Energy (Generation + India Import)	229.10 MKWh										
	By Gas = 112.482 MKWh	By Oil = 64.239 MKWh										
	By Coal = 23.364 MKWh	By Hydro = 3.696 MKWh										
	By Solar= 1.630 MKWh											
11.	Total Gas Supplied	841.87 MMCFD										
(D) Forecast of 31.10.22 (Today) Monday :												
01.	Maximum Demand	11800 MW (Generation end)										
02.	Maximum Generation	11849 MW (Generation end)										
03.	Reserve / Shortage	49 MW (Generation end)										
12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
	Dhaka	4103	4038	65	Mymensingh	875	875	0				
	Chattogram	1276	1276	0	Sylhet	501	501	0				
	Khulna	1145	1145	0	Barishal	263	263	0				
	Rajshahi	1039	1039	0	Rangpur	634	634	0				
	Cumilla	1024	1024	0								
					Total	10860	10795	65				
13.	Fuel cost :											
	(a) Gas = 124933851 Taka	(c) Coal = 204342229 Taka										
	(b) Oil = 873758616 Taka	Total = 1203034696 Taka										
14.	Maximum Temperature in Dhaka was :	32.5° C										
15.	Export through East-West interconnections :											
	At evening peak-hour	9865 MW, at 19:30 hrs										
	Maximum	180 MW, at 18:00 hrs										
	Energy	0 MKWh										
(E) Maximum Load-shed : 0 MW At evening peak (Sub-station end)												
05. Total Generation : 240.72 MKWh												
06. Probable Max. Temperature in Dhaka : 31.8° C												

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation