

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 4-Nov-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CAPP-Unit-3 (GT)	PDB	1'260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP-Unit-4	PDB	1'210	180	0	0	Machine problem
3	Ghorasal TPP Unit-5	PDB	1'210	190	180	4378500	
4	Ghorasal 365 MW CAPP Unit-7	PDB	1'243+1'122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0	
6	Ghorasal 108MW PP (Regent)	IPP	34'3.35	108	73	1711409	Engine problem
7	Haripur GTTP	SBU, PDB	2'32	20	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1'273+1'139	412	361	8903370	Gas shortage
9	Haripur 360MW CAPP(HPL)	IPP	1'235+1'125	360	227	5318000	Gas shortage
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2'150+1'150	450	175	4213600	Gas shortage
11	Meghnaghat 100 MW(IEI)	NENP	12'9	100	60	487680	Engine problem
12	Meghnaghat CAPP(Summit)	IPP	2'110+1'110	335	120	3209629	Gas shortage
13	Madanagar 102 PP(Summit)	NENP	6'17	0	102	0	Under maint.
14	Madanagar-55 MW PPS(Summit)	IPP	3'17.08+1'11.3	55	55	1207955	
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	410688	
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0	Under maint.
18	Siddhirgonj 2'120 MW GTTP	EGCB	2'105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch) Bangla	NENP	12'9.9	100	77	88920	Engine problem
20	Siddhirgonj 335 MW CAPP	EGCB	1'217+1'118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	92	1096848	Engine problem
22	Kaipoti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	659180	
24	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	64	780480	High voltage
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	654813	
26	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	0	881931	Tripped at 18:48
27	Bosila 108MW PP(CLC)	IPP	12'8.775+1'3.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	48	1141080	Engine problem
29	Madhabdi 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	630400	
30	Ruaganj 33 MW PP(Summit)	SIPP, REB	4'8.73	33	29	745100	Engine problem
31	Gazipur 52 MW PP	RPCL	6'8.9	52	24	465802	0.00
32	Tongi 80 MW GTTP	PDB	1' 105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	260	5512473	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	44080	Fuel conservation
35	Bramhanaga 100 MW PP (Aggreko)	IPP	11'49.959	100	0	27187	Fuel conservation
36	Aurahi 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	26835	Fuel conservation
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	135	2373408	Engine problem
38	Gazipur 100 MW PP	RPCL	6'17.5	105	88	1258512	Engine problem
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	92	1223040	Fuel shortage
40	Manikganj 162MW PP(MPGL)	IPP	9'18	162	162	1935360	
41	Spectro Solar Plant Ltd.	IPP	35	35	0	207171	
42	Kanchan Flutbatal Power Generation Ltd.	IPP	18.4'3	55	17	432720	Fuel shortage
<b>Dhaka area Total</b>				<b>5847</b>	<b>2903</b>	<b>5104151</b>	
43	Chattoagram TPP-1	PDB	1'210	180	0	0	Machine problem
44	Chattoagram TPP-2	PDB	1'210	180	0	0	Gas shortage
45	Raazon 25 MW PP	RPCL	3'8.9	25	8	194877	High voltage
46	Tafal 20MW PP (Solartech)	IPP	20	20	0	106629	Gas shortage
47	Palenga 50MW PP (Baraka)	IPP	8'6.98	50	39	678720	Engine problem
48	Kapali Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	154	3719636	Low water level
49	Sikalbaha 225MW	PDB	1'150+1'175	225	111	3537760	ST Under maint.
50	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	1199854	
52	Hathazari 100 MW Peaking PP	PDB	11'9.9	102	23	169596	Fuel shortage
53	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	51	494248	Fuel shortage
54	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	76	941880	Fuel shortage
55	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	50	734400	Fuel shortage
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	0	0	Engine problem
57	Manarha, Ch. EPZ (United)	IPP	5'8.73+9.34	0	29	760800	
58	Chattoagram 108 MW PP (ECPV)	IPP	16'3	108	0	0	Fuel shortage
59	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	18000	
60	Anwara 300 MW PP (United)	IPP	17'17+24	300	245	3056073	High voltage
61	Jodiak Power	IPP	3'18.55+1'3.6	54	36	707484	High voltage
62	Kanaphuli Power Ltd.	IPP	18.45'6+8.5	110	91	1732102	High voltage
63	Juldah unit-3 (Accorn)	IPP	8'13.5	100	50	755520	
64	Anlima Energy Ltd.	IPP	6'21.2	116	107	2269964	Engine problem
65	Minshahi 150 MW	BPDB-RPCL	18.5'9	0	0	0	On test.
<b>Chattoagram area Total</b>				<b>2382</b>	<b>1175</b>	<b>21674834</b>	
66	Ashuganj TPP Unit-3	APSCL	1'150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-4	APSCL	1'150	0	0	0	Contract Expired
68	Ashuganj TPP Unit-5	APSCL	1'150	134	0	0	Gas shortage
69	Ashuganj 225 MW CAPP	APSCL	1'142+1'175	221	178	4481000	Gas shortage
70	Ashuganj 450 MW CAPP(North)	APSCL	1'360	360	280	7318600	Gas shortage
71	Ashuganj 450 MW CAPP(South)	APSCL	1'360	360	0	0	Gas shortage
72	Ashuganj 420 MW CAPP(East)	APSCL	284'1+136'1	284	0	0	On test.
73	Ashuganj 50 MW PP	APSCL	14'3.068	45	51	1169496	
74	Ashuganj 50 MW PP (Precision)	QRPP	15'14	55	30	678240	Gas shortage
75	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+1'16	195	160	4148363	
76	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	0	0	Gas shortage
77	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	83	1219418	Fuel shortage
78	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	271744	Low demand
79	Chandpur 150 MW CAPP	PDB	1'106+1'57	163	49	1182750	Machine problem
80	Chandpur 200MW (Desh energy)	IPP	1'214.4	200	78	1352840	Engine problem
81	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	0	0	Engine problem
82	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	251280	
83	Impoport (Tripura)	Imported power	0	160	114	2476800	
84	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	25	597600	Engine problem
85	Jangalia 50 MW PP (Lakshmi)	IPP	6'8.92	52	23	528762	Engine problem
86	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	20	437640	Engine problem
87	Daudkandi 200 MW PP (B. Trac)	IPP	15'4.1	200	0	20352	Fuel conservation
88	Feni Lanka Power	IPP	7'18.415+1'9.78	114	96	571140	Engine problem
89	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	0	26880	Fuel shortage
90	Bharob 54.5 MW	IPP	3'18.2	54	17	443520	Fuel shortage
91	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	115	1678980	
<b>Cumilla Area Total</b>				<b>3169</b>	<b>1347</b>	<b>28934305</b>	
92	RPCL 210MW CAPP	IPP	4'35+1'70	202	50	1613760	Gas shortage
93	Tangal 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	15	365400	Engine problem
94	Jamalpur 95 MW PP (Powerpac)	IPP	12'8.924	0	0	0	Under maint.
95	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	12600	
96	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	88	1250400	Fuel shortage
97	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	99	1467600	Engine problem
98	Suliakhali 50 MW Solar PP	IPP	50	50	0	319440	
99	Tangal Pali Power Gen 22 MW	IPP	4'6.7	22	6	126000	Engine problem
<b>Mymensingh Area Total</b>				<b>614</b>	<b>258</b>	<b>5155200</b>	
100	Fenchuganj CAPP Phase-1	PDB	2'32+1'33	70	30	715000	Machine problem
101	Fenchuganj CAPP Phase-2	PDB	2'35+1'35	90	43	960940	Machine problem
102	Kushara 163 MW CAPP (KP)	IPP	1'109+1'154	163	0	0	Gas shortage
103	Shahjibazar 330 MW CAPP	PDB	3'110	330	0	0	Under maint.
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	6	87600	Gas shortage
105	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	5	88848	Gas shortage
106	Haldiganj 11MW PP (Confidence-E)	SIPP, REB	4'2.90	11	0	0	Gas shortage
107	Shahjibazar GTTP Unit-3 & 9	PDB	2'35	86	89	1357344	
108	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	81	549440	
109	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
110	Sylhet 225 MW CAPP	PDB	1'142+1'89	231	90	3189830	ST Under maint.
111	Sylhet 20 MW GTTP	PDB	1'20	20	0	212000	Gas shortage
112	Sylhet 50MW PP (EP)	NENP	2'72	50	11	139740	Gas shortage
113	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	0	9264	Gas shortage
114	Bitiyana-II 341 MW CAPP (Summit)	IPP	1'222+1'119	341	250	6971500	FGMO
115	Bitiyana-III 400 MW CAPP	PDB	400 MW	400	365	9125000	
116	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	240480	
117	Bitiyana South 400 MW	PDB	400 MW	383	350	8630100	
<b>Sylhet Area Total</b>				<b>2477</b>	<b>1310</b>	<b>32478786</b>	
118	Bheramara GTTP Unit-3	PDB	1'20	16	0	0	Fuel shortage
119	Bheramara (HVDC)	Imported power	2'500	1000	918	21109818	
120	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	49	284000	Fuel shortage
121	Fardpur 50 MW Peaking PP	PDB	6'8.89	54	2	48000	Engine problem
122	Khulna 225 MW CAPP	NWPGCL	1'150+1'175	230	0	0	Fuel shortage
123	Cazapara 100 MW Peaking PP	PDB	1'6'9.98	109	78	319080	Fuel shortage
124	Bheramara 410 MW CAPP	NWPGCL	1'278+1'132	410	190	4772736	Gas shortage
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	0	Fuel shortage
126	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0	Fuel conservation
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	94	961440	Engine problem
128	Madhumati 100 MW PP	NWPGCL	6'18	105	0	0	Fuel shortage
129	Mongia Orion 100 MW Solar PP	IPP	100	100	0	505440	
130	Khulna 330 MW CAPP (DIL)	BPDB	1'220+1'110	0	0	0	On test.
131	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	On test.
<b>Khulna Area Total</b>				<b>2384</b>	<b>1331</b>	<b>27999514</b>	
132	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	0	0	Line O/L
133	Bhola 53 MW PP (Venture)	NENP	1'34.50	40	21	398300	Engine problem
134	Bhola 225 MW CAPP	PDB	2'63+1'68	194	49	1319000	Gas shortage
135	Bhola 95 MW PP (Aggreko)	QRPP	96'11.0	0	0	0	Contract Expired
136	Payra 1320 MW	BCPCL	2'622	1244	690	17228800	Line O/L
137	Bhola Nutan Biddut BD LTD	IPP	220	220	220	4456145	Line O/L
138	United Payra Power Ltd.	IPP	6'18.5+1'9.5	150	0	0	Line O/L
139	Barisal 307 MW	BCPCL	0	0	129	2290909	On test.
<b>Barisal Area Total</b>				<b>1958</b>	<b>1109</b>	<b>25891554</b>	
140	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
141	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage
142	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	32	36768	Engine problem
143	Bera 70 MW Peaking PP	PDB	9'8.29	71	0	3350	Low demand
144	Amnura 50 MW PP (Sinha)	QRPP	7'7.9	0	0	0	Contract Expired
145	Katahal 50 MW PP (Northern)	QRPP	6'8.9	50	34	139405	Fuel shortage
146	Katahal 50 MW Peaking PP	PDB	6'8.7	50	40	91610	Engine problem
147	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'175	210	164	4087536	Gas shortage
148	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'175	220	0	0	
149	Sirajgonj Unit-3 225MW	NWPGCL	1'141	220	0	0	Gas shortage
150	Sirajgonj 400 MW CAPP Unit-4	NWPGCL	1'262+1'132	258	414	6185745	Gas shortage
151	Santalar 50 MW Peaking PP	PDB	6'8.7	50	35	62782	Engine problem
152	Bogra 22 MW PP (GBB)	RPP	6'4	22			