

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 5-Nov-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1210	180	0	0	Machine problem
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4378500	
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	140	1304600	
5	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
6	Ghorasal 108MW PP (Regent)	IPP	343.35	208	73	1651818	Engine problem
7	Haripur GTPP	SBU, PDB	232	0	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1273+1139	412	348	8445950	Gas shortage
9	Haripur 360MW CCGP(HPL)	IPP	1235+1125	360	192	5798000	Gas shortage
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2150+1150	450	190	4786100	Gas shortage
11	Meghnaghat 100 MW(IEI)	NENP	12*9	100	92	975360	Engine problem
12	Meghnaghat CCGP(Summit)	IPP	2110+1110	335	112	2693091	Gas shortage
13	Madanagar 100 MW(Summit)	NENP	6*17	102	0	0	Under maint.
14	Madanagar-55 MW PPS(Summit)	IPP	3*17.08+111.3	55	55	1319012	
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	454140	
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirgonj 210 MW GTPP	EGCB	2105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch) Bangla	NENP	12*9	100	88	1123200	Engine problem
20	Siddhirgonj 335 MW CCGP	EGCB	1217+118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	92	1580832	Engine problem
22	Kaipoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	660960	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	132	1494240	Fuel shortage
25	Kodda 55 MW PP (Northern)	IPP	3*19.3	55	55	781284	
26	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	905614	
27	Bosila 108MW PP(CLC)	IPP	12*8.775+113.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	51	1174200	Engine problem
29	Madhabdi 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	775980	
30	Ruaganj 30 MW PP(Summit)	SIPP, REB	4*8.73	33	29	712100	
31	Gazipur 52 MW PP	RPCL	6*8.9	52	49	702240	0.00
32	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	276	5678073	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Fuel conservation
35	Bramhanaga 100 MW PP (Aggreko)	IPP	114*9.959	100	0	0	Fuel conservation
36	Aurahi 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Fuel conservation
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	133	2919168	Engine problem
38	Gazipur 100 MW PP	RPCL	6*17.5	105	100	1387572	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	93	1479360	Fuel shortage
40	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	144	1797120	Engine problem
41	Spectro Solar Plant Ltd.	IPP	35	35	0	187306	
42	Kanchan Flatbatal Power Generation Ltd.	IPP	18.4*3	55	0	151560	Fuel shortage
Dhaka area Total				5847	2788	5537080	
43	Chattoagram TPP-1	PDB	1210	180	0	0	Machine problem
44	Chattoagram TPP-2	PDB	1210	180	0	0	Gas shortage
45	Raozan 25 MW PP	RPCL	3*8.9	25	25	311086	
46	Takani 20MW PP (Solartech)	IPP	20	20	0	130815	
47	Palenga 50MW PP (Baraka)	IPP	6*8.96	50	44	689280	Engine problem
48	Kapali Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	154	3390803	Low water level
49	Sikalbaha 225MW	PDB	1*150+1*175	225	150	3509324	ST Under maint.
50	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	105	1784799	
52	Haziganj 100 MW peaking PP	PDB	11*9.9	102	23	224388	Fuel shortage
53	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	51	616332	Fuel shortage
54	Juldah 100 MW Unit-1 (Accorn)	NENP	8*13.45	100	66	180520	Fuel shortage
55	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8*13.5	100	50	897600	Fuel shortage
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	6*2.90	22	0	0	Engine problem
57	Manarha, Ch. EPZ Unit-1	IPP	5*8.73+9.34	0	12	374880	
58	Chattoagram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Fuel shortage
59	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	24238	
60	Anwara 300 MW PP (United)	IPP	17*17+24	300	300	3131345	
61	Jodiak Power	IPP	3*18.55+113.6	54	36	830036	Engine problem
62	Kanapahuli Power Ltd.	IPP	18.15*6+8.5	110	91	1655883	Fuel shortage
63	Juldah unit-3 (Accorn)	IPP	8*13.5	100	50	613620	
64	Anlima Energy Ltd.	IPP	6*21.2	116	107	2295818	Engine problem
65	Minshahi 150 MW	BPDB-RPCL	18.5*9	0	0	5018	On test.
Chattoagram area Total				2382	1264	22866085	
66	Ashuganj TPP Unit-3	APSCL	1150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-4	APSCL	1150	0	0	0	Contract Expired
68	Ashuganj TPP Unit-5	APSCL	1150	134	0	0	Gas shortage
69	Ashuganj 225 MW CCGP	APSCL	11142+1175	221	191	4614000	Gas shortage
70	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	310	7698000	Gas shortage
71	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	0	0	Gas shortage
72	Ashuganj 420 MW CCGP(East)	APSCL	284*1+136*1	284	0	0	On test.
73	Ashuganj 50 MW PP	APSCL	14*3.968	45	30	1141632	
74	Ashuganj 50 MW PP (Precision)	QRPP	15*4	55	30	689280	Gas shortage
75	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+116	195	168	4064727	
76	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	0	0	Gas shortage
77	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	68	980218	Fuel shortage
78	Titas 50 MW Peaking PP	PDB	6*8.92	52	43	415328	Engine problem
79	Chandpur 150 MW CCGP	PDB	11*106+157	163	50	1193950	Machine problem
80	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	200	1534080	
81	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	168336	Engine problem
82	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	10	244260	
83	Imported (Tripura)	Imported power	0	160	136	2779200	
84	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	30	511200	
85	Jangalia 50 MW PP (Lakshmi)	IPP	6*8.92	52	29	453516	Engine problem
86	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	21	408090	Engine problem
87	Daudkandi 200 MW PP (B. Trac)	IPP	15*41.4	200	0	0	Fuel conservation
88	Feni Lanka Power	IPP	7*18.415+19.78	114	114	1322400	
89	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	0	14280	Fuel shortage
90	Bharob 54.5 MW	IPP	3*18.2	54	35	612720	Engine problem
91	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	115	1670400	
Cumilla Area Total				3169	1619	30815619	
92	RPCL 210MW CCGP	IPP	41*56+170	202	95	1656960	Gas shortage
93	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	13	325512	Engine problem
94	Jamalpur 95 MW PP (Powerpac)	IPP	12*8.924	0	0	0	Under maint.
95	Sarishabari 3 MW Solar Plant	IPP	1*3	0	0	12500	
96	Mymensingh 200 MW PP (United)	IPP	9*78*21	200	88	1444800	Fuel shortage
97	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	98	1472400	Engine problem
98	Suliakhali 50 MW Solar PP	IPP	50	50	0	290030	
99	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	6	144960	Engine problem
Mymensingh Area Total				614	261	5047162	
100	Fenchuganj CCGP Phase-1	PDB	2*32+133	70	30	716000	Machine problem
101	Fenchuganj CCGP Phase-2	PDB	2*35+135	90	42	965760	Machine problem
102	Kushara 163 MW CCGP (KP)	IPP	1100+1154	163	0	0	Gas shortage
103	Shahjibazar 330 MW CCGP	PDB	3*110	330	0	0	Under maint.
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	41	762600	
105	Fenchuganj 44MW (Energyprima)	NENP	12*3.3+5*2	50	30	577224	Gas shortage
106	Haldiganj 11MW PP (Confidence-E)	SIPP, REB	4*2.90	11	0	0	Gas shortage
107	Shahjibazar GTTP Unit-1 & 2	PDB	2*35	86	85	1403232	
108	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	81	778560	
109	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
110	Sylhet 225 MW CCGP	PDB	1142+1189	231	90	1298760	ST Under maint.
111	Sylhet 20 MW GTTP	PDB	1*20	20	18	433000	Gas shortage
112	Sylhet 50MW PP (EPZ)	NENP	2*12	50	16	310520	Gas shortage
113	Shahjibazar 25 MW PP	SIPP, REB	3*9.34	25	0	0	Gas shortage
114	Bitiana-II 341 MW CCGP (Summit)	IPP	1222+1119	341	270	7135000	FGMO
115	Bitiyana-III 400 MW CCGP	PDB	400 MW	400	415	9358000	
116	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	225180	
117	Bitiyana South 400 MW	PDB	400 MW	383	398	9031000	
Sylhet Area Total				2477	1508	32994636	
118	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
119	Bheramara (HVDC)	Imported power	2*500	1000	913	20866181	
120	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	49	390720	Fuel shortage
121	Fariapur 50 MW Peaking PP	PDB	6*8.89	54	42	165600	Engine problem
122	Khulna 225 MW CCGP	NWPGCL	1150+1175	230	0	0	Fuel shortage
123	Casapara 100 MW Peaking PP	PDB	12*8.98	109	82	404352	Engine problem
124	Bheramara 410 MW CCGP	NWPGCL	1278+1132	410	100	4656096	Gas shortage
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	8	34875	Fuel shortage
126	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Fuel conservation
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	54	473280	Fuel shortage
128	Madhumati 100 MW PP	NWPGCL	6*18	105	0	0	Fuel shortage
129	Mongia Orion 100 MW Solar PP	IPP	100	100	0	554400	
130	Khulna 330 MW CCGP (DIL)	BPDB	1220+1110	0	0	0	On test.
131	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	On test.
Khulna Area Total				2384	1318	27545504	
132	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Line O/L
133	Bhola 53 MW PP (Venture)	NENP	13*4.50	40	0	56350	Engine problem
134	Bhola 225 MW CCGP	PDB	2*63+1*68	194	60	1274000	Gas shortage
135	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	0	0	0	