

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022			Day : Tuesday				Date : 08.11.22					
Probable Maximum Demand : 11800 MW			Probable Maximum Generation : 11840 MW				Rule Curve = 104.30 ft.					
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 94.40 ft		Today = 94.16 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.11.22 (Yesterday)		08.11.22 (Today)		07.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Line Overload
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	110	110	110			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	150	200	200	200			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	12	13	10	13	95		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Hariapur GTPP	Gas (PDB)	1x 32	32	20	0	0	0	0			Contract Expired
7	Hariapur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	342	323	320	320			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225		Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Hariapur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412		Gas Shortage
11	Siddhirganj 2' 120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335		Gas Shortage
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335		Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	92	60	92			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	22	22			
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	52	51	50	51			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	45	48	45	48			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	132	116	110	116			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	273	285	280	285			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	132	136	135	135			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	201	13	0	150			
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	85	25	0	50			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	89	25	0	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	55	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	54	80	54	80			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	144	144	35	144			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	34			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	88	88	70	88			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	84	80	70	80			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0			
Dhaka Zone Total			6004	5847	2686	2497	2196	2683	1717	375		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	47	154	152	154			Unit 1 under rehabilitation
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	13	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	38	44	30	44			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	85	105	80	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	152	151	150	150		74	STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x6.04	300	300	281	300	150	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	90	25	90			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	29	37	30	37			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	7	7	10			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0	108		Fuel oil shortage
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	91	91	91	91			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	100	50	100			
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	33	78	50	78			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total			2442	2382	980	1368	1017	1370	310	404		
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	8	8	8	8			
60	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+1*75	221	221	178	163	160	163			
61	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	110	355	320	360			
62	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	360	300	300	300			
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCCL)	1x284	284	284	0	0	0	0	284		Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50		Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	0	0	0	51		Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	68	88	65	88			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	43	43	30	43			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	49	48	50	50		57	ST Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	200	51	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	21	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	8	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	33	20	33			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+6x1.515+15x1.098	200	200	100	10	0	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	15	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	7	7	7	106		Fuel Oil Shortage
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	115	53	115			
**	Impoport (Tripura)	India		160	160	128	146	143	166			
Cumilla Zone Total			3193	3169	1279	1763	1355	1880	812	57		
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	68	72	70	72	130		Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	10	8	8	8			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	89	50	89			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	95	48	75	105		Fuel oil shortage
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	12	0	50	0			
87	Tangail 22 MW PP(PPLG)	HFO (IPP)	4x6.7	22	22	6	12	12	12			
Mymensingh Zone Total			622	614	194	276	240	256	235	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.11.22 (Yesterday)		08.11.22 (Today)		07.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening					
88	Fenchugon CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugon CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30		60	GT-4 Under maint.	
90	Fenchugon 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	0	0	0	0				
91	Kushiera 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	63	60	63				
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	81	0	81				
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	178	219	200	220		12	ST Under maint.	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	16	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	9	10	10				
99	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
100	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	275	280	280				
101	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	402	401	400	400				
102	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchugani 44MW (Energyprima)	Gas (NENP)	12x3.345*2	50	50	0	0	0	0	50		Gas Shortage	
Sylhet Zone Total					2522	2477	1444	1542	1442	1548	218	596	
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	120	140	140	150	270		Gas Shortage	
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	43	0	43				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	85	0	85				
110	Khulna 225 MW CCGP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	10	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	76	67	76				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	85	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	65	32	65	50		Fuel oil shortage	
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8	32		Fuel oil shortage	
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCGP	Gas/HSD (PBDB)				200	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	894	893	920	920				
Khulna Zone Total					2388	2384	1299	1320	1259	1397	352	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	21	22	16	22				
119	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	65	65	65	65	129		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	640	790	850	850				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0				
122	Bhola 220MW CCGP (Nutan Bidvut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	162	222	220	220				
Barishal Zone Total					1958	1958	888	1099	1151	1157	129	260	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	10	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	15	0	15		56	Under maint.	
127	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	86	0	86				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	41	0	40				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	34	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35				
131	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	138	151	150	150	59		Gas Shortage	
132	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
134	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	135	171	270	270	243		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	18	18	18				
136	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	8	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	8	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	50	113	100	113				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	8	88	35	88				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
Ratahahi Zone Total					2129	2129	369	848	629	1035	693	276	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	79	78	79				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250			Under maint.	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2'3	113	113	42	70	50	70				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tazula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thekugaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	115	113	115				
148	Lalmohol 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	32	0	12	0				
Rangpur Zone Total					830	750	411	514	511	514	0	85	
Sub-total: Plants in operation					22088	21710	9550.0	11227	9800	11840	4466	2053	
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpohi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0	
Gross Total					22512	21710	9550	11227	9800	11840	4466	2053	
(C) Actual data of 07.11.22 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	11227	MW, at =	19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	10886	MW, at =	19:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	11227	MW, at =	19:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	8017	MW, at =	6:00 hrs	Dhaka	4249	4249	0	Mymensingh	830	830	0
05.	Day-peak Generation (Generation end)	:	9550	MW, at =	12:00 hrs	Chattogram	1298	1298	0	Sylhet	465	465	0
06.	Evening-peak Generation (Generation end)	:	11227	MW, at =	19:00 hrs	Khulna	1112	1112	0	Barishal	261	261	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs	Rajshahi	991	991	0	Rangpur	637	637	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7802	MW, at =	5:00 hrs	Cumilla	1043	1043	0				
09.	Generation shortfall at evening peak due to :									Total	10886	10886	0
a)	Gas/LF limitation	:	4466	MW		13.	Fuel cost :	(a) Gas = 114721486	Taka	(c) Coal = 206619476	Taka		
c)	Coal supply Limitation	:	0	MW			(b) Oil = 884337529	Taka	Total = 1205678491	Taka			
b)	Low water level in Kaptai lake	:	0	MW									
c)	Plants under shut down maintenance	:	2053	MW		14.	Maximum Temperature in Dhaka was :	32.1° C					
10.	Total Energy (Generation + India Import)	:	225.45	MKWh		15.	Export through East-West interconnections :						
	By Gas = 105.086	MKWh	By Oil = 66.033	MKWh		At evening peak-hour	:	9550	MW, at	19:00 hrs			
	By Coal = 26.122	MKWh	By Hydro = 3.185	MKWh		Maximum	:	520	MW, at	18:00 hrs			
	By Solar = 1.214	MKWh				Energy	:	0	MKWh				
11.	Total Gas Supplied	:	839.72	MMCFD									
(D) Forecast of 08.11.22 (Today) Tuesday :													
01.	Maximum Demand	:	11800	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	11840	MW	(Generation end)	05.	Total Generation	:	236.96	MKWh			
03.	Reserve / Shortage	:	40	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	28.9° C				

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation