

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date: 13-Nov-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CAPP-Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP-Unit-4	PDB	1210	180	0	0	Line O/L
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4378500	
4	Ghorasal 365 MW CAPP-Unit-7	PDB	1243+1122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
6	Ghorasal 108MW PP (Regent)	IPP	34*3.35	108	70	1569227	Gas shortage
7	Haripur GTPP	SBU, PDB	2*32	20	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1273+1139	412	0	137465	Gas line maintenance
9	Haripur 360MW CAPP(HPL)	IPP	1235+1125	360	284	6347000	Gas shortage
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2150+1150	450	225	5036400	Gas shortage
11	Meghnaghat 100 MW(IEEL)	NENP	12*9	100	78	1134720	Engine problem
12	Meghnaghat CAPP(Summit)	IPP	2110+1110	335	0	0	Gas shortage
13	Madanagar 102 PP(Summit)	NENP	6*17	102	0	0	Under maint.
14	Madanagar-55 MW PPS(Summit)	IPP	3*17.08+111.3	55	0	121743	Fuel shortage
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	460224	
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirgonj 2120 MW GTPP	EGCB	2105	210	167	1850000	Gas shortage
19	Siddhirgonj 100 PP(Dutch) Bangla	NENP	12*9	100	80	1023360	Engine problem
20	Siddhirgonj 335 MW CAPP	EGCB	1217+118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	75	1205568	Engine problem
22	Kaipoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	40	525600	Fuel shortage
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	150	133	1497120	Engine problem
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	669336	Fuel shortage
26	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	906808	
27	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	51	1144500	Engine problem
29	Madhabdi 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	599540	Engine problem
30	Ruaganj 30 MW PP(Summit)	SIPP, REB	4*8.73	30	28	730500	Engine problem
31	Gazipur 52 MW PP	RPCL	6*8.9	52	49	749280	0.00
32	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	230	3848945	Fuel shortage
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	100	992365	Fuel conservation
35	Bramhanaga 100 MW PP (Aggreko)	IPP	11*19.959	100	50	654599	Fuel conservation
36	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	50	653818	Fuel conservation
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	134	2011392	Engine problem
38	Gazipur 100 MW PP	RPCL	6*17.5	105	105	1850124	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	54	1160640	Fuel shortage
40	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	1732250	
41	Spectro Solar Plant Ltd.	IPP	35	0	0	179480	
42	Kanchan Flatbatal Power Generation Ltd.	IPP	18.4*3	55	17	433080	Fuel shortage
<b>Dhaka area Total</b>				<b>5847</b>	<b>2516</b>	<b>44213154</b>	
43	Chattoagram TPP-1	PDB	1210	180	0	0	Machine problem
44	Chattoagram TPP-2	PDB	1210	180	0	0	Gas shortage
45	Raozan 25 MW PP	RPCL	3*8.9	25	17	298488	Engine problem
46	Takraf 20MW PP (Solartech)	IPP	20	20	0	0	
47	Palenga 50MW PP (Baraka)	IPP	8*6.98	50	39	594720	Engine problem
48	Kapila Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	151	3636367	Low water level
49	Sikalbaha 225MW	PDB	1*1150+1*175	225	150	3556596	ST Under maint.
50	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	102	1519673	
52	Hathazari 100 MW peaking PP	PDB	11*9.9	100	37	622536	Fuel shortage
53	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	51	610251	Fuel shortage
54	Juldah 100 MW Unit-1 (Accorn)	NENP	8*13.45	100	55	843720	Fuel shortage
55	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8*13.5	100	40	736320	Fuel shortage
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	0	0	Engine problem
57	Manaraha, Ch. EPZ Unit-2	IPP	5*8.73+9.34	0	2	294240	
58	Chattoagram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Fuel shortage
59	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	25922	
60	Anwara 300 MW PP (United)	IPP	17*17+24	300	255	2998364	Engine problem
61	Jodiak Power	IPP	3*18.55+1*3.6	54	36	953429	Engine problem
62	Kanapathu Power Ltd.	IPP	18.415*6+8.5	110	87	1646793	Fuel shortage
63	Juldah unit-3 (Accorn)	IPP	8*13.5	100	27	727680	
64	Anlima Energy Ltd.	IPP	6*21.2	116	107	2471455	Engine problem
65	Minshahi 150 MW	BPDB-RPCL	18.5*9	0	0	26763	On test.
<b>Chattoagram area Total</b>				<b>2382</b>	<b>1156</b>	<b>21592422</b>	
66	Ashuganj TPP Unit-3	APSCL	1*150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-4	APSCL	1*150	0	0	0	Contract Expired
68	Ashuganj TPP Unit-5	APSCL	1*150	134	0	0	Gas shortage
69	Ashuganj 225 MW CAPP	APSCL	1*1142+1*175	221	179	4421000	FGMO
70	Ashuganj 450 MW CAPP(North)	APSCL	1*360	360	0	335000	FGMO
71	Ashuganj 450 MW CAPP(South)	APSCL	1*360	360	320	7452000	FGMO
72	Ashuganj 420 MW CAPP(East)	APSCL	284*1+136*1	284	0	0	On test.
73	Ashuganj 50 MW PP	APSCL	14*3.968	45	44	1075320	Gas shortage
74	Ashuganj 50 MW PP (Precision)	QRPP	15*14	55	51	1118360	
75	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	148	3378900	Gas shortage
76	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	5	63036	Gas shortage
77	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	99	1388363	Fuel shortage
78	Titas 50 MW Peaking PP	PDB	6*8.92	52	40	393728	Engine problem
79	Chandpur 150 MW CAPP	PDB	1*1106+1*57	163	50	1187140	Machine problem
80	Chandpur 200MW (Desh energy)	IPP	12*12.4	75	20	1592160	High voltage
81	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	468324	
82	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	10	225180	
83	Impoport (Tripura)	Imported power	0	160	118	2333760	
84	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	669900	
85	Jangalia 33 MW PP (Lakshmi)	IPP	6*8.92	33	10	316123	Fuel shortage
86	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	19	307570	
87	Daudkandi 200 MW PP (B.Trac)	IPP	15*14	200	0	437760	Fuel conservation
88	Feni Lanka Power	IPP	7*18.415+1*9.78	114	95	612180	Fuel shortage
89	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	108	1880760	Engine problem
90	Bharad 54.5 MW	IPP	3*18.2	54	17	443880	Engine problem
91	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	53	674880	Fuel shortage
<b>Cumilla Area Total</b>				<b>3169</b>	<b>1496</b>	<b>30866033</b>	
92	RPCL 210MW CAPP	IPP	4*55+1*70	202	42	1863360	Gas shortage
93	Tangail 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	5	124236	Gas shortage
94	Jamalpur 95 MW PP (Powerpac)	IPP	12*8.924	0	0	0	Under maint.
95	Sarishabari 3 MW Solar Plant	IPP	1*3	0	0	11350	
96	Mymensingh 200 MW PP (United)	IPP	9*78*21	85	200	1315200	Fuel shortage
97	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	97	1521600	Engine problem
98	Suliakhali 50 MW Solar PP	IPP	50	50	0	268560	
99	Tangail Pali Power Gen 22 MW	IPP	4*6.7	22	6	208560	Engine problem
<b>Mymensingh Area Total</b>				<b>614</b>	<b>235</b>	<b>5312866</b>	
100	Fenchuganj CAPP Phase-1	PDB	2*32+1*33	70	30	717000	Machine problem
101	Fenchuganj CAPP Phase-2	PDB	2*35+1*35	90	42	953280	Machine problem
102	Kushkhara 163 MW CAPP (KP)	IPP	11*109+1*54	163	0	0	Gas shortage
103	Shahjibazar 330 MW CAPP	PDB	3*110	330	0	0	Under maint.
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	11	405000	Gas shortage
105	Fenchuganj 44MW (Energyprima)	NENP	12*3.3+5*2	50	10	538560	Gas shortage
106	Haldiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	2	61056	Gas shortage
107	Shahjibazar GTTP Unit-3 & 9	PDB	2*35	66	69	1391616	
108	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	78	674880	
109	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
110	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	152	3766760	Machine problem
111	Sylhet 20 MW GTTP	PDB	1*20	20	18	440000	
112	Sylhet 50MW PP (EPZ)	NENP	2*12	50	30	634220	Gas shortage
113	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	8	171936	Gas shortage
114	Bitiana-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	275	6954500	FGMO
115	Bitiyana-III 400 MW CAPP	PDB	400 MW	400	362	9444000	
116	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	243180	
117	Bitiyana South 400 MW	PDB	400 MW	383	300	7359900	Machine problem
<b>Sylhet Area Total</b>				<b>2477</b>	<b>1397</b>	<b>33754888</b>	
118	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
119	Bheramara (HVDC)	Imported power	2*500	1000	898	20916363	
120	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	49	46080	Engine problem
121	Fardpur 50 MW Peaking PP	PDB	6*8.89	54	25	28320	Line O/L
122	Khulna 225 MW CAPP	NWP/GCL	1*150+1*75	230	0	0	Fuel shortage
123	Casapara 100 MW Peaking PP	PDB	1*61.98	109	47	54400	Engine problem
124	Bheramara 410 MW CAPP	NWP/GCL	1*278+1*132	410	160	4187808	Gas shortage
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	0	0	Fuel shortage
126	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Fuel conservation
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	22	404160	Engine problem
128	Madhumati 160 MW PP	NWP/GCL	6*18	105	0	0	Fuel shortage
129	Mongia Orion 100 MW Solar PP	IPP	100	100	0	510480	
130	Khulna 330 MW CAPP (DIL)	BPDB	1*220+1*110	0	237	4669909	On test.
131	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	On test.
<b>Khulna Area Total</b>				<b>2384</b>	<b>1438</b>	<b>30814520</b>	
132	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Line O/L
133	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	17	355600	Engine problem
134	Bhola 225 MW CAPP	PDB	2*63+1*68	194	87	205944	Gas shortage