

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 16-Nov-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CAPP-Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP-Unit-4	PDB	1210	180	0	0	Line O/L
3	Ghorasal 365 MW CAPP-Unit-7	PDB	1243+1122	365	0	0	Under maint.
4	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
5	Ghorasal 108MW PP (Regent)	IPP	343.35	108	70	1673772	Gas shortage
6	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
7	Haripur 412 MW CAPP	EGCB	1273+1139	412	361	9052160	Gas shortage
8	Haripur 360MW CAPP(HPL)	IPP	1235+1125	360	313	7398000	Gas shortage
9	Meghnaghat 450 MW CAPP(MPL)	IPP	2150+1150	450	225	5178600	Gas shortage
10	Meghnaghat 100 MW(IEI)	NENP	12*9	100	73	1105920	Engine problem
11	Meghnaghat CAPP(Summit)	IPP	2110+1110	335	0	0	Gas shortage
12	Madanagar 102 PP(Summit)	NENP	6*17	102	0	0	Under maint.
13	Madanagar-55 MW PPS(Summit)	IPP	3*17.08+11*1.3	55	55	1325619	
14	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	428436	
16	210 MW Siddhirgonj TFP	PDB	1210	115	0	0	Under maint.
17	Siddhirgonj 2120 MW GTTP	EGCB	2105	210	0	0	Gas shortage
18	Siddhirgonj 100 PP(Dutch) Bangla	NENP	12*9	100	85	1488960	Engine problem
19	Siddhirgonj 335 MW CAPP	EGCB	1217+118	335	0	0	Gas shortage
20	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	75	1163952	Engine problem
21	Kalipoti 52 MW PP (Siraha)	IPP	7*7.9	0	0	0	Fuel shortage
22	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	531720	
23	Kodda 150MW PP	BPDB-RRCL	9*17.06	150	133	1107360	Engine problem
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	573427	
25	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	35	905643	Engine problem
26	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	0	0	0	
27	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	45	1202820	Engine problem
28	Madhabdi 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	813300	
29	Ruaganj 30 MW PP(Summit)	SIPP, REB	4*8.73	30	20	526400	Engine problem
30	Gazipur 52 MW PP	RPCL	6*8.9	52	49	686880	0.00
31	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	205	3377236	Fuel shortage
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	60	492419	Fuel conservation
34	Bramhanaga 100 MW PP (Aggreko)	IPP	11*19.959	100	60	272168	Fuel conservation
35	Aurahi 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	60	230800	Fuel conservation
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	85	1500048	Engine problem
37	Gazipur 100 MW PP	RPCL	6*17.5	105	105	1827276	Engine problem
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	61	1203840	Fuel shortage
39	Manikganj 162MW PP(MPGL)	IPP	9*18	162	162	1607040	
40	Spectro Solar Plant Ltd.	IPP	35	35	0	205072	
41	Kanchan Flatbatal Power Generation Ltd.	IPP	18.4*3	55	17	433200	Fuel shortage
<b>Dhaka area Total</b>				<b>5847</b>	<b>2695</b>	<b>51322668</b>	
41	Chattoagram TPP-1	PDB	1210	180	0	0	Machine problem
42	Chattoagram TPP-2	PDB	1210	180	0	0	Gas shortage
43	Raozan 25 MW PP	RPCL	3*8.9	25	17	274519	Engine problem
44	Takani 20MW PP (Solartech)	IPP	20	20	0	139995	
45	Palenga 50MW PP (Baraka)	IPP	8*6.98	50	44	576480	Engine problem
46	Kapali Hydro Unit-1,2,3,4, 5	IPP	2*40+3*50	230	81	2630011	Low water level
47	Sikalbaha 225MW	PDB	1*1150+1*175	225	151	3548756	ST Under maint
48	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	87	1415127	Engine problem
50	Hathazari -Kalaish 100 MW Peaking	PDB	11*9.9	100	24	335652	Fuel shortage
51	Juldah 100 MW Unit-1 (Accorn)	NENP	8*13.45	100	44	794880	Fuel shortage
52	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8*13.5	100	40	763200	Fuel shortage
53	Barakunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	0	0	Engine problem
54	Chattoagram 108 MW PP (ECPV)	IPP	5*8.73+9.34	108	0	7200	
55	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	25320	
56	Anwara 300 MW PP (United)	IPP	17*17+24	300	258	3023455	Engine problem
57	Jodiak Power	IPP	3*18.55+1*3.6	54	36	819510	Engine problem
58	Kanapathu Power Ltd.	IPP	18.415*6+8.5	110	92	1727919	Fuel shortage
59	Juldah unit-3 (Accorn)	IPP	8*13.5	100	38	743040	
60	Anlima Energy Ltd.	IPP	6*21.2	116	107	2569055	Engine problem
61	Minshahi 150 MW	BPDB-RRCL	18.5*9	0	0	23418	On test.
<b>Chattoagram area Total</b>				<b>2382</b>	<b>1072</b>	<b>19981704</b>	
61	Ashuganj TPP Unit-3	APSCL	1150	0	0	0	Contract Expired
62	Ashuganj TPP Unit-4	APSCL	1150	0	0	0	Contract Expired
63	Ashuganj TPP Unit-5	APSCL	1150	134	0	0	Gas shortage
64	Ashuganj 225 MW CAPP	APSCL	11142+175	221	179	4387000	Gas shortage
65	Ashuganj 450 MW CAPP(North)	APSCL	1*360	360	0	0	Gas shortage
66	Ashuganj 450 MW CAPP(South)	APSCL	1*360	360	305	7328000	FGMO
67	Ashuganj 420 MW CAPP(East)	APSCL	284*1+136*1	284	288	7159900	On test.
68	Ashuganj 50 MW PP	APSCL	14*3.068	45	5	125568	Gas shortage
69	Ashuganj 100 MW PP (Precision)	QRPP	55	55	5	107520	Gas shortage
70	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+1*16	195	8	200727	Gas shortage
71	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	5	207694	Gas shortage
72	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	92	1602472	Fuel shortage
73	Titas 50 MW Peaking PP	PDB	6*8.92	52	43	398655	Engine problem
74	Chandpur 150 MW CAPP	PDB	12106+157	163	40	1033520	Machine problem
75	Chandpur 200MW (Desh energy)	IPP	12*14.4	200	68	1359360	High voltage
76	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	22	497340	
77	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	10	221040	
78	Imported (Tripura)	Imported power	0	160	120	2410560	
79	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	16	5752000	Engine problem
80	Jangalia 50 MW PP (Lakshmi)	IPP	6*8.92	52	24	333154	Fuel shortage
81	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	9	208580	Engine problem
82	Daudkandi 200 MW PP (B. Trac)	IPP	15*4.1	200	10	30528	Fuel conservation
83	Feni Lanka Power	IPP	7*18.415+1*9.78	114	97	705660	Fuel shortage
84	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	106	1627920	Engine problem
85	Bharob 54.5 MW	IPP	3*18.2	54	17	443880	Engine problem
86	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	115	1281440	
<b>Cumilla Area Total</b>				<b>3169</b>	<b>1584</b>	<b>37402518</b>	
87	RPCL 210MW CAPP	IPP	4*35+1*70	202	37	1700160	Gas shortage
88	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	10	238248	Gas shortage
89	Jamalpur 95 MW PP (Powerpac)	IPP	12*8.924	0	0	0	Under maint.
90	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	13800	
91	Mymensingh 200 MW PP (United)	IPP	9*78*21	85	200	1101600	Fuel shortage
92	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	97	1470000	Engine problem
93	Suliakhali 50 MW Solar PP	IPP	50	50	0	288480	
94	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	12	298080	Engine problem
<b>Mymensingh Area Total</b>				<b>614</b>	<b>241</b>	<b>5110368</b>	
95	Fenchuganj CAPP Phase-1	PDB	2*32+1*33	70	241	716000	Machine problem
96	Fenchuganj CAPP Phase-2	PDB	2*35+1*35	42	90	963720	Machine problem
97	Kushara 163 MW CAPP (KP)	IPP	11109+154	163	0	0	Gas shortage
98	Shahjibazar 330 MW CAPP	PDB	3*110	330	0	0	Under maint.
99	Fenchuganj 51 MW PP (Barakattullah)	RPP	19*2.90	51	0	0	Gas shortage
100	Fenchuganj 44MW (Energyprima)	NENP	12*3.5+2	50	0	0	Gas shortage
101	Haldiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	2	61104	Gas shortage
102	Shahjibazar GTTP Unit-3 & 9	PDB	2*35	86	68	166880	Gas shortage
103	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	80	509800	
104	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
105	Sylhet 225 MW CAPP	PDB	1*142+1*89	231	140	3371260	Machine problem
106	Sylhet 20 MW GTTP	PDB	1*20	20	18	437000	
107	Sylhet 50MW PP (EP)	NENP	2*7.2	50	0	0	Gas shortage
108	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	0	0	Gas shortage
109	Bitiana-II 341 MW CAPP (Summit)	IPP	1*222+1*119	341	290	7075500	FGMO
110	Bitiana-III 400 MW CAPP	PDB	400 MW	400	421	9738000	
111	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	242260	
112	Bitiyana South 400 MW	PDB	400 MW	383	400	9217000	
<b>Sylhet Area Total</b>				<b>2477</b>	<b>1507</b>	<b>34025604</b>	
113	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
114	Bheramara (HVDC)	Imported power	2*500	1000	905	20858181	
115	Khulina 115 PP MW (KPCL-2)	NENP	7*17	115	84	268800	Engine problem
116	Fardpur 50 MW Peaking PP	PDB	6*8.89	54	45	44640	Line O/L
117	Khulina 225 MW CAPP	NWPGCL	1150+175	230	0	0	Fuel shortage
118	Casapara 100 MW Peaking PP	PDB	12*8.98	109	87	157312	Engine problem
119	Bheramara 410 MW CAPP	NWPGCL	1278+1132	410	125	3672288	Gas shortage
120	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	0	0	Fuel shortage
121	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Fuel conservation
122	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	60	662880	Engine problem
123	Madhumati 100 MW PP	NWPGCL	6*18	105	0	0	Fuel shortage
124	Mongia Orion 100 MW Solar PP	IPP	100	100	0	506880	
125	Khulina 330 MW CAPP (DIL)	BPDB	1220+1110	0	0	0	On test.
126	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	On test.
<b>Khulina Area Total</b>				<b>2384</b>	<b>1306</b>	<b>26170981</b>	
127	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Line O/L
128	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	21	365700	Engine problem
129	Bhola 225 MW CAPP	PDB	2*63+1*63	134	87	2060890	Gas shortage
130	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	0	0	0	Contract Expired
131	Payra 1320 MW	BCPCL	2*622	1244	520	13686800	Line O/L
132	Bhola Nutan Biddut BD LTD	IPP	220	220	222	4426036	
133	United Payra Power Ltd.	IPP	6*18.5+1*9.5</				