

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022			Day : Thursday				Date : 17.11.22							
Probable Maximum Demand : 10700 MW			Yesterday = 91.46 ft				Today = 91.24 ft				Rule Curve = 107.40 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.11.22 (Yesterday)		17.11.22 (Today)		16.11.22 (Yesterday)		17.11.22 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)	Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Contract Expired				
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0				Line Overload	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	70	70	70	70					
5	Tongj 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Gas Shortage	
6	Hariapur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				Contract Expired	
7	Hariapur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	321	313	300	315					
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225			225	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
10	Hariapur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	390	361	350	360			51	Gas Shortage	
11	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0			210	Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0			335	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0			335	Gas Shortage	
14	Madanganj 55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	75	33	75					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	22	22					
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	52	45	42	45					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	22	20	20	20					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	49	50	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	117	133	100	133					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	112	205	175	230					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	44	85	125	133					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	200	60	100	150					
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	60	50	60					
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	60	50	60					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	61	55	61					
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	162	162	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	86	85	75	85					
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	67	73	70	73					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0					
Dhaka Zone Total			6004	5847	2496	2695	2581	2863	1261	740				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	152	81	80	80				Unit 1 under rehabilitation	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17					
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	20	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x8.89	50	50	26	44	26	44					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	69	87	68	87					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	150	151	150	150			74	STG Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	123	258	260	260					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	40	25	40					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	24	20	25					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0			22	Gas Shortage	
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	2	2	2					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	73	92	70	92					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	38	25	50					
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	33	44	33	44					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0				on test	
Chattogram Zone Total			2442	2382	879	1072	961	1085	202	404				
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0			134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	5	5	5	5					
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	199	179	180	180					
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	340	305	300	305					
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	0	0	0	0			360	Minor Inspection	
63	Ashuganj 420 MW CCPP(East) GT	Gas (APSCl)	1x284	284	284	288	288	288	300					
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	5	5	5			50	Gas Shortage	
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8			187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	5	5	5			46	Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	66	92	65	92					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	37	43	0	43					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	40	40	40	40			57	ST Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	73	68	51	100					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	13	16	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	24	8	25					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	9	9	9	9					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+8x11.515+1x1.098	200	200	0	10	100	100					
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	97	17	17					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	73	106	80	106					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	118	115	35	115					
**	Impoort (Tripura)	India		160	160	110	120	143	166					
Cumilla Zone Total			3193	3169	1356	1584	1421	1703	417	417				
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	42	37	70	70			165	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10					
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	97	50	85					
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	49	85	75	85					
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3</										

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	16.11.22 (Yesterday)		17.11.22 (Today)		16.11.22 Gen. shortfall for : Gas/Coal/Water Limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening					
88	Fenchugon CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugon CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.	
90	Fenchugon 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	0	0				
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	2	2	2	2				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	68	66	66				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	80	0	80				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	140	140	140	140				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0	25		Gas Shortage	
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	290	300	300				
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	413	421	400	400				
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	393	400	300	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0	50		Gas Shortage	
105	Fenchugon 44MW (Energyprima)	Gas (NENP)	12x3.345*2	50	50	0	0	0	0	50		Gas Shortage	
Sylhet Zone Total					2522	2477	1429	1501	1308	1488	234	572	
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	125	125	140	150	285		Gas Shortage	
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	45	0	45				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	87	0	87				
110	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	60	0	95				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	80	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	84	16	84				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CAPP	Gas/HSD (PBDB)				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	905	905	922	922				
Khulna Zone Total					2388	2384	1110	1306	1178	1433	285	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	13	21	12	21				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	75	87	85	87	107		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	490	520	800	800				
121	Potukhali 150MW PP (LUPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				160	180	0	0				
122	Bhola 220MW CAPP (Nutan Bidvut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	182	222	220	220				
Barishal Zone Total					1958	1958	920	1030	1117	1128	107	260	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	30				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	20		67	Under maint.	
127	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	82	0	82				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	42	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	0	34				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	148	144	140	144			Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	66		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Under maint.	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	158	140	200	250	274		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	17	17	17				
136	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	34	8	34				
138	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	55	95	90	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	80	85	113				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
Ratahahi Zone Total					2129	2129	458	747	591	1012	731	287	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Storage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	159	160	160				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	49	111	90	113				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tazula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	57	113	67	113				
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	29	0	30	0				
Rangpur Zone Total					830	750	300	383	355	386	85	85	
Sub-total: Plants in operation					22088	21710	9141.0	10559	9781	11360	3487	2765	
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpohi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0	
Gross Total					22512	21710	9141	10559	9781	11360	3487	2765	
(C) Actual data of 16.11.22 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	10559	MW, at = 18:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10233	MW, at = 18:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	10559	MW, at = 18:00 hrs	Dhaka	4013	4013	0	Mymensingh	788	788	0	
04.	Minimum Generation (Generation end)	:	7153	MW, at = 5:00 hrs	Chattogram	1176	1176	0	Sylhet	381	381	0	
05.	Day-peak Generation (Generation end)	:	9141	MW, at = 12:00 hrs	Khulna	1120	1120	0	Barishal	258	258	0	
06.	Evening-peak Generation (Generation end)	:	10559	MW, at = 18:00 hrs	Rajshahi	982	982	0	Rangpur	667	667	0	
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at = 18:00 hrs	Cumilla	849	849	0					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7056	MW, at = 5:00 hrs					Total	10233	10233	0	
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :							
a) Gas/LF Limitation	:	3402	MW		(a) Gas =	122363736	Taka	(c) Coal =	144096559	Taka			
d) Coal supply Limitation	:	85	MW		(b) Oil =	694037428	Taka	Total =	960497824	Taka			
b) Low water level in Kaptai lake	:	0	MW										
c) Plants under shut down maintenance	:	2765	MW		14.	Maximum Temperature in Dhaka was : 30.7° C							
10.	Total Energy (Generation + India Import)	:	217.20	MKWh	15.	Export through East-West interconnections :							
	By Gas =	116.667	MKWh	By Oil =	52.034	MKWh	At evening peak-hour	:	9141	MW, at	18:00 hrs		
	By Coal =	21.176	MKWh	By Hydro =	2.630	MKWh	Maximum	:	214	MW, at	21:00 hrs		
	By Solar =	1.423	MKWh				Energy	:	0	MKWh			
11.	Total Gas Supplied	:	863.60	MMCFD									
(D) Forecast of 17.11.22 (Today) Thursday :													
01.	Maximum Demand	:	10700	MW (Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	:	11360	MW (Generation end)	05.	Total Generation : 220.10 MKWh							
03.	Reserve / Shortage	:	660	MW (Generation end)	06.	Probable Max. Temperature in Dhaka : 28.3° C							

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation