

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 22-Nov-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
		Unit No. X Capacity		MW	MW	KWH	
1	Ghorasal Repowered CAPP Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CAPP Unit-4	PDB	1210	180	0	0	Line O/L
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4376500	
4	Ghorasal 365 MW CAPP Unit-7	PDB	1243+1122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP (MAX)	ORPP	240	0	0	0	
6	Ghorasal 108MW PP (Regent)	IPP	34.3.35	108	71	1679000	Gas shortage
7	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
8	Haripur 412 MW CAPP	EGCB	1273+1139	412	308	7595920	Gas shortage
9	Haripur 360MW CAPP(HPL)	IPP	1235+1125	360	286	6528000	Gas shortage
10	Meghnaghat 450 MW CAPP(MPL)	IPP	2150+1150	450	225	5205500	GT-2 S/D due to Gas shortage
11	Meghnaghat 100 MW (IEL)	NENP	12.9	100	92	1138560	Engine problem
12	Meghnaghat CAPP(Summit)	IPP	2110+1110	335	0	0	Gas shortage
13	Madanagar 102 PP(Summit)	NENP	617	102	0	0	Under maint.
14	Madanagar-55 MW PPS(Summit)	IPP	317.08+111.3	55	45	969318	Engine problem
15	Keraniganj 100 MW PP (Powerpac)	ORPP	813.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	82.90	22	19	460512	
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirgonj 210 MW GTPP	EGCB	2105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch) Bangla	NENP	128.9	100	85	1267200	Fuel shortage
20	Siddhirgonj 335 MW CAPP	EGCB	1217+118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12.8.924	102	33	372816	Fuel shortage
22	Kalipoti 52 MW PP (Sinha)	IPP	77.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	31.8	54	54	529920	
24	Kodda 150MW PP	BPDB-RPCL	917.06	149	133	1702680	Engine problem
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	55	732300	
26	Nabaganj 55 MW PP (Southern power)	IPP	319.3	55	35	548166	Engine problem
27	Bosila 108MW PP(CLC)	IPP	12.8.775+113.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	33.67+4.873	80	48	1180860	Engine problem
29	Madhabdi 33 MW PP (APR)	SIPP, REB	48.73	33	33	779400	
30	Ruaganj 30 MW PP (Summit)	SIPP, REB	48.73	33	28	740100	Engine problem
31	Gazipur 52 MW PP	RPCL	69.8	52	49	692160	0.00
32	Tongi 80 MW GTPP	PDB	11105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	188	3864000	Fuel shortage
34	Keraniganj 300 MW PP (APR)	IPP	2561.4	300	86	521665	Fuel conservation
35	Bramhanaga 100 MW PP (Aggreko)	IPP	1149.959	100	80	363633	Fuel conservation
36	Auraha 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	50	367323	Fuel conservation
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.45+8.97	149	92	2933712	Engine problem
38	Gazipur 100 MW PP	RPCL	617.5	105	105	1952832	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.56	104	35	491520	Fuel shortage
40	Manikgonj 162MW PPS(MGL)	IPP	91.8	162	162	1340640	
41	Spectro Solar Plant Ltd.	IPP	35	0	0	180625	
42	Kanchan Flatbatal Power Generation Ltd.	IPP	18.43	55	17	434160	Fuel shortage
Dhaka area Total				5847	2574	48860431	
43	Chattogram TPP-1	PDB	1210	180	0	0	Machine problem
44	Racozan TPP-2	PDB	1210	180	0	0	Gas shortage
45	Racozan 25 MW PP	RPCL	39.8	25	8	178023	Engine problem
46	Takraf 20MW PP (Solaritech)	IPP	20	20	0	133380	
47	Palenga 50MW PP (Baraka)	IPP	86.98	50	43	654720	Engine problem
48	Kapla Hydro Unit-1,2,3,4, 5	PDB	240+350	230	46	1050540	Low water level
49	Sikabaha 225MW	PDB	1150+1175	225	150	3665040	ST Under maint
50	Sikabaha Peaking GT	PDB	1150	150	0	0	Under maint.
51	Sikabaha 105 MW PP (Baraka Sikabaha)	IPP	817.5	105	97	1558472	Engine problem
52	Hathazari 100 MW Peaking PP	PDB	119.9	108	32	167746	Fuel shortage
53	Dohazari -Kalaish 100 MW Peaking	PDB	617	102	51	509207	Fuel shortage
54	Juldah 100 MW Unit-1 (Accom)	NENP	813.45	100	44	694440	Fuel shortage
55	Juldah 100 MW PP Unit-3 (Accom)	IPP	813.5	100	50	756480	Fuel shortage
56	Barakunda 22 MW PP (Regent)	SIPP, PDB	82.90	22	0	0	Engine problem
57	Manaraha, Ch. EPZ Unit-1	IPP	58.73+9.34	0	2	161520	
58	Chattogram 108 MW PP (ECPV)	IPP	167	108	0	0	Fuel shortage
59	Kapla 7 MW Solar PP	PDB	7.4 MW	7	0	26281	
60	Anwara 300 MW PP (United)	IPP	1717+24	300	300	3078655	
61	Jodica Power	IPP	318.55+113.6	54	36	793333	Engine problem
62	Kanapathi Power Ltd.	IPP	18.156+6.5	110	91	1639266	Fuel shortage
63	Juldah unit-3 (Accom)	IPP	813.5	100	50	787200	
64	Anlima Energy Ltd.	IPP	621.2	116	107	2347255	Engine problem
65	Minshahi 150 MW	BPDB-RPCL	18.59	0	0	58545	On test.
Chattogram area Total				2382	1107	18264123	
66	Ashuganj TPP Unit-3	APSCL	1150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-4	APSCL	1150	0	0	0	Contract Expired
68	Ashuganj TPP Unit-5	APSCL	1150	134	0	0	Gas shortage
69	Ashuganj 225 MW CAPP	APSCL	1142+1175	221	0	0	Gas shortage
70	Ashuganj 450 MW CAPP(North)	APSCL	1360	360	0	0	Gas shortage
71	Ashuganj 450 MW CAPP(South)	APSCL	1360	360	250	6021000	Gas shortage
72	Ashuganj 420 MW CAPP(East)	APSCL	2841+1361	284	402	9603300	On test.
73	Ashuganj 50 MW PP	APSCL	14.3.068	45	44	1023480	Engine problem
74	Ashuganj 150 MW PP (Precision)	ORPP	1514	30	55	769440	Gas shortage
75	Ashuganj 195MW PP (APSCL-United)	IPP	209.73+116	195	0	0	Gas shortage
76	Ashuganj 51 MW PP (Midland)	IPP	69.34	51	5	217844	Gas shortage
77	Ashuganj 150MW PP (Midland)	IPP	237.015	150	120	1873454	Fuel shortage
78	Titas 50 MW Peaking PP	PDB	69.82	50	30	253472	Engine problem
79	Chandpur 150 MW CAPP	PDB	1106+157	163	86	1541150	Machine problem
80	Chandpur 200MW (Desh energy)	IPP	1218.4	147	200	1342080	High voltage
81	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	22	446760	
82	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	8	174780	Engine problem
83	Impoprt (Tripura)	Imported power	0	160	120	2364480	
84	Jangalia 33MW PP (Summit)	SIPP, PDB	48.73	33	16	584000	Engine problem
85	Jangalia 50 MW PP (Lakshmi)	IPP	89.82	52	8	212553	Fuel shortage
86	Cumilla 25 MW PP (Summit)	SIPP, REB	33.67+26.97	25	15	345910	Engine problem
87	Daudkandi 200 MW PP (B. Trac)	IPP	1541.4	200	20	214656	Fuel conservation
88	Feni Lanka Power	IPP	718.415+19.78	114	0	55860	Fuel shortage
89	Chowmuhani 113 MW	IPP	129.78+23.1	113	108	1986360	Engine problem
90	Bharob 54.5 MW	IPP	318.2	54	34	550440	Engine problem
91	Chandpur 115(Doreen)	IPP	418.5+22.5	115	115	1290240	
Cumilla Area Total				3169	1560	30883269	
92	RPCL 210MW CAPP	IPP	4156+170	202	39	1647360	Gas shortage
93	Tangal 22 MW PP (Doreen)	SIPP, PDB	82.90	22	10	252108	Gas shortage
94	Jamalpur 95 MW PP (Powerpac)	IPP	12.8.924	0	0	0	Under maint.
95	Saishahabani 3 MW Solar Plant	IPP	13	3	0	12700	
96	Mymensingh 200 MW PP (United)	IPP	97821	200	87	1276200	Engine problem
97	Jamalpur 115 MW PP (United)	IPP	97812	115	97	1557600	Engine problem
98	Suliakhali 50 MW Solar PP	IPP	50	50	0	312480	
99	Tangal Pali Power Gen 22 MW	IPP	46.7	22	12	293760	Engine problem
Mymensingh Area Total				614	245	5355208	
100	Fenchuganj CAPP Phase-1	PDB	232+133	70	30	327000	Machine problem
101	Fenchuganj CAPP Phase-2	PDB	235+135	90	43	894200	Machine problem
102	Kushara 163 MW CAPP (KP)	IPP	1109+1154	163	0	0	Gas shortage
103	Shahbazar 330 MW CAPP	PDB	3110	330	0	0	Under maint.
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	192.90	51	53	1145400	
105	Fenchuganj 44MW (Energyprima)	NENP	123.3+52	50	25	628488	Gas shortage
106	Haldiganj 11MW PP Confidence-E	SIPP, REB	42.90	11	3	72336	Gas shortage
107	Shahbazar GTPP Unit-3 & 9	PDB	235	86	89	147392	
108	Shahbazar 86MW PP (Shahbazar)	RPP	322.90	86	83	676800	
109	Shahbazar 100 MW GTPP	PDB	1100	100	0	0	Under maint.
110	Sylhet 225 MW CAPP	PDB	1142+1189	231	178	4122810	Gas shortage
111	Sylhet 20 MW GTPP	PDB	120	20	18	421000	Gas shortage
112	Sylhet 50MW PP (EPZ)	NENP	272	50	27	536220	Gas shortage
113	Shahjahanulla 25 MW PP	SIPP, REB	39.34	25	24	451210	Gas shortage
114	Bitiana-II 341 MW CAPP (Summit)	IPP	1222+1119	341	0	536420	FGMO
115	Bitiyana-III 400 MW CAPP	PDB	400 MW	400	391	9496000	
116	Sylhet 10MW PP (Desh)	RPP	61.95	10	10	225000	
117	Bitiyana South 400 MW	PDB	400 MW	383	400	9136800	
Sylhet Area Total				2477	1354	38113476	
118	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
119	Bheramara (HVDC)	Imported power	2500	1000	895	19460363	
120	Khulina 115 PP MW (KPCL-2)	NENP	717	115	99	613440	Engine problem
121	Fardpur 50 MW Peaking PP	PDB	86.89	54	50	98880	Engine problem
122	Khulina 225 MW CAPP	NWP/GCL	1150+1175	230	0	0	Fuel shortage
123	Casapara 100 MW Peaking PP	PDB	116.98	100	50	228224	High voltage
124	Bheramara 410 MW CAPP	NWP/GCL	1278+1132	410	145	4077216	Gas shortage
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	59.5	40	32	188625	Fuel shortage
126	Noapara 100 MW PP (Bangla Trac)	IPP	701.4	100	0	0	Fuel conservation
127	Rupsha 105 MW PP (Orion rupsha)	IPP	618.445	105	94	1614240	Engine problem
128	Madhumati 160 MW PP	NWP/GCL	618	105	0	0	Fuel shortage
129	Mongia Orion 100 MW Solar PP	IPP	100	100	0	481880	
130	Khulina 330 MW CAPP (DIL)	BPDB	1220+1110	0	0	0	On test.
131	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	On test.
Khulina Area Total				2384	1365	26762668	
132	Barisal 110 MW PP (Summit)	IPP	717.076	110	0	0	Line O/L
133	Bhola 33 MW PP (Venture)	NENP	134.50	40	20	421400	Engine problem
134	Bhola 225 MW CAPP	PDB	2633+1168	114	115	2852000	Gas shortage
135	Bhola 95 MW PP (Aggreko)	ORPP	961.10	0	0	0	Contract Expired
136	Payra 1320 MW	BCPCL	2622	1244	630	16658300	Line O/L