

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date: 23-Nov-22

Page-2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks		
				Capacity	Hour	Generated			
			Unit No. X Capacity	MW	MW	KWH			
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1260	260	0	0		Under maint.	
2	Ghorasal Repowered CCGP Unit-4	PDB	1210	180	0	0		Line O/L	
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4410000			
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0		Under maint.	
5	Ghorashal 78.5 MW PP(MAX)	QRPP	2'40	0	0	0			
6	Ghorashal 108MW PP (Regent)	IPP	34'3.35	108	71	1649727		Gas shortage	
7	Haripur GTPP	SBU, PDB	2'32	20	0	0		Under maint.	
8	Haripur 412 MW CCGP	EGCB	1'273+1139	412	325	8032260		Gas shortage	
9	Haripur 360MW CCGP(HPL)	IPP	1'235+1125	360	289	6862000		Gas shortage	
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2'150+1150	450	225	5336000		GT-2 S/D due to Gas shortage	
11	Meghnaghat 100 MW(HEL)	NENP	12'8.9	100	81	1214400		Engine problem	
12	Meghnaghat CCGP(Summit)	IPP	2'110+1110	335	0	0		Gas shortage	
13	Madangan 102 PP(Summit)	NENP	6'17	102	0	0		Under maint.	
14	Madangan-55 MW PP(Summit)	IPP	3'17.08+111.3	55	45	1051952		Engine problem	
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0		Contract Expired	
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	19	372924			
17	210 MW Siddhirgonj TPP	PDB	1'210	115	0	0		Under maint.	
18	Siddhirgonj 2'120 MW GTPP	EGCB	2'105	210	0	0		Gas shortage	
19	Siddhirgonj 100 PP(Dutch) Bangla	NENP	12'8.9	100	85	1244160		Fuel shortage	
20	Siddhirgonj 335 MW CCGP	EGCB	1'217+118	335	0	0		Gas shortage	
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	33	380304		Fuel shortage	
22	Katipoti 52 MW PP (Siraha)	IPP	7'7.9	0	0	0		Fuel shortage	
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	529200			
24	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	133	1760160		Engine problem	
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	720292			
26	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	476179			
27	Bosila 108MW PP(CLC)	IPP	12'8.775+113.5	0	0	0			
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	44	1158540		Engine problem	
29	Madhabdi 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	604600			
30	Rupsha 33 MW PP(Summit)	SIPP, REB	4'8.73	33	30	767400		Engine problem	
31	Gazipur 52 MW PP	RPCL	6'8.9	52	50	731040		0.00	
32	Tongi 80 MW GTPP	PDB	1' 105	0	0	0		Under maint.	
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	145	3101236		Fuel shortage	
34	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	102	540769		Fuel conservation	
35	Brangantha 100 MW PP (Aggreko)	IPP	11'49.959	100	50	394785		Fuel conservation	
36	Auraha 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	50	340547		Fuel conservation	
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	125	2825280		Engine problem	
38	Gazipur 100 MW PP	RPCL	6'17.5	105	105	2122716			
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	17	435840		Fuel shortage	
40	Manikgonj 162MW PP(MPGL)	IPP	9'18	162	139	1336520		Engine problem	
41	Spectro Solar Plant Ltd.	IPP	9	35	0	181083			
42	Kanchan Flatbatal Power Generation Ltd.	IPP	18.4'3	55	17	433080		Fuel shortage	
Dhaka area Total				5847	2657	49202794			
43	Chattoagram TPP-1	PDB	1'210	180	0	0		Machine problem	
44	Chattoagram TPP-2	PDB	1'210	20	0	0		Gas shortage	
45	Racozan 25 MW PP	RPCL	3'8.9	25	0	219585		Engine problem	
46	Takraf 28MW PP (Solarloch)	IPP	20	20	0	133245			
47	Palanga 50MW PP (Baraka)	IPP	8'6.98	50	0	481440		Engine problem	
48	Kaptai Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	46	1059180		Low water level	
49	Sikalbaha 225MW	PDB	1'150+1'175	225	151	3510239		ST Under maint	
50	Sikalbaha Peaking GT	PDB	1'150	150	0	0		Under maint.	
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	105	154390			
52	Halizhan 100 MW peaking PP	PDB	11'9.8	102	48	596202		Fuel shortage	
53	Dohazari -Kalasha 100 MW Peaking	PDB	6'17	102	51	564002		Fuel shortage	
54	Jullaha 100 MW Unit-1 (Accom)	NENP	8'13.45	100	10	424080		Fuel shortage	
55	Jullaha 100 MW PP Unit-3 (Accom)	IPP	8'13.5	100	12	483840		Fuel shortage	
56	Barakunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	0	2		Engine problem	
57	Malancha, Cox EPZ Unit-2	IPP	5'8.73+9'9.34	0	2	221760			
58	Chattoagram 108 MW PP (ECPV)	IPP	16'3	108	0	0		Fuel shortage	
59	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	26160			
60	Anwara 300 MW PP (United)	IPP	17'17+24	300	271	2270727		Fuel shortage	
61	Jodiak Power	IPP	3'18.55+11'3.6	54	36	716040		Engine problem	
62	Kanapahuli Power Ltd.	IPP	18.15'6+8.5	110	91	1538		Fuel shortage	
63	Jullaha unit-1 (Accom)	IPP	8'13.5	100	10	477120			
64	Anlima Energy Ltd.	IPP	6'21.2	116	79	2007273		Engine problem	
65	Minshaha 150 MW	BPDB-RPCL	18.5'9	0	0	50181		On test.	
Chattoagram area Total				2382	910	14788702			
66	Ashuganj TPP Unit-3	APSCL	1'150	0	0	0		Contract Expired	
67	Ashuganj TPP Unit-4	APSCL	1'150	0	0	0		Contract Expired	
68	Ashuganj TPP Unit-5	APSCL	1'150	134	0	0		Gas shortage	
69	Ashuganj 225 MW CCGP	APSCL	1'142+1'175	221	0	0		Gas shortage	
70	Ashuganj 450 MW CCGP(North)	APSCL	1'360	360	0	0		Gas shortage	
71	Ashuganj 450 MW CCGP(South)	APSCL	1'360	360	240	5817000		Gas shortage	
72	Ashuganj 420 MW CCGP(East)	APSCL	284'1+136'1	284	432	9772200		On test.	
73	Ashuganj 50 MW PP	APSCL	14'3.068	45	44	1044936		Engine problem	
74	Ashuganj 50 MW PP (Precision)	QRPP	15'14	55	30	765380		Gas shortage	
75	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+11'6	195	0	0		Gas shortage	
76	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	5	207878		Gas shortage	
77	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	105	1860072		Fuel shortage	
78	Titash 50 MW Peaking PP	PDB	6'8.92	52	30	434400		Engine problem	
79	Chandpur 150 MW CCGP	PDB	1'106+1'57	163	70	1389590		Machine problem	
80	Chandpur 225MW (Desh energy)	IPP	12'14.4	200	134	1157160		High voltage	
81	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	504144			
82	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	204300			
83	Import (Tripura)	Imported power	0	160	116	2310720			
84	Jangjala 33MW PP (Summit)	SIPP, PDB	4'8.73	33	21	629300		Engine problem	
85	Jangjala 53 MW PP (Lakshmi)	IPP	6'8.92	52	14	213144		Fuel shortage	
86	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	15	361080		Engine problem	
87	Daudkandi 200 MW PP (B. Trac)	IPP	15'4.1	200	100	274752		Fuel conservation	
88	Feni Lanka Power	IPP	7'18.415+1'9.78	114	0	74100		Fuel shortage	
89	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	109	1742160		Engine problem	
90	Bharosh 54.5 MW	IPP	3'18.2	54	33	532080		Engine problem	
91	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	98	1164480		Engine problem	
Cumilla Area Total				3169	1626	31085816			
92	RPCL 210MW CCGP	IPP	4'35+1'70	202	35	1594560		Gas shortage	
93	Tangal 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	8	207324		Gas shortage	
94	Jamalpur 95 MW PP(Powerpac)	IPP	12'8.924	0	0	0		Under maint.	
95	Sarihashaban 3 MW Solar Plant	IPP	1'3	3	0	13300			
96	Mymensingh 200 MW PP (United)	IPP	9'78'21	200	57	1032000		Fuel shortage	
97	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	59	1213200		Fuel shortage	
98	Sutiakhali 50 MW Solar PP	IPP	50	50	0	309840			
99	Tangal Pali Power Gen 22 MW	IPP	4'6.7	22	12	287040		Engine problem	
Mymensingh Area Total				614	171	4628464			
100	Fenchuganj CCGP Phase-1	PDB	2'32+1'33	70	30	716000		Machine problem	
101	Fenchuganj CCGP Phase-2	PDB	2'35+1'35	90	43	1078520		Machine problem	
102	Kushihara 163 MW CCGP (KP)	IPP	1'109+1'54	163	0	0		Gas shortage	
103	Shahjibazar 330 MW CCGP	PDB	3'110	330	0	0		Under maint.	
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	1032000			
105	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5'2	50	35	819936		Gas shortage	
106	Haliganj 11 MW PP (Confidence-E)	SIPP, REB	4'2.90	11	3	72576		Gas shortage	
107	Shahjibazar GTTP Unit-3 & 9	PDB	2'35	86	86	1349592			
108	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	84	644160			
109	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0		Under maint.	
110	Sylhet 225 MW CCGP	PDB	1'142+1'89	231	90	3316730		Gas shortage	
111	Sylhet 20 MW GTTP	PDB	1'20	20	18	440000		Gas shortage	
112	Sylhet 50MW PP (EPCL)	NENP	2'72	50	26	617120		Gas shortage	
113	Sylhet Shahjibazar 25 MW PP	SIPP, REB	3'9.34	25	16	509712		Gas shortage	
114	Bibiana-II 341 MW CCGP (Summit)	IPP	1'222+1'119	341	0	0		Under maint.	
115	Bibiyana-III 400 MW CCGP	PDB	400 MW	400	419	9329000			
116	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	244620			
117	Bibiyana South 400 MW	PDB	400 MW	383	400	9084900			
Sylhet Area Total				2477	1293	29249766			
118	Bheramara GTTP Unit-3	PDB	1'20	16	0	0		Fuel shortage	
119	Bheramara (HVDC)	Imported power	2'500	1000	895	19446545			
120	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	83	480960		Engine problem	
121	Fardpur 50 MW Peaking PP	PDB	6'8.89	54	45	62400		Engine problem	
122	Khulna 225 MW CCGP	NWP/GCL	1'150+1'175	230	0	0		Fuel shortage	
123	Cazipara 100 MW Peaking PP	PDB	1'6'9.98	109	46	205312		High voltage	
124	Bheramara 410 MW CCGP	NWP/GCL	1'278+1'132	410	155	4060800		Gas shortage	
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	32	136125		Fuel shortage	
126	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	10	10560		Fuel conservation	
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	74	117			