

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCPP-Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP-Unit-4	PDB	1210	180	0	0	Line O/L
3	Ghorasal 365 MW CCPP-Unit-7	PDB	1243+1122	365	200	4787300	GBC problem
4	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
5	Ghorasal 108MW PP (Regent)	IPP	343.35	208	22	548863	Gas shortage
6	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
7	Haripur 412 MW CCPP	EGCB	1273+1139	412	377	8419330	Gas shortage
8	Haripur 360MW CCPP(HPL)	IPP	1235+1125	360	0	1824000	Gas shortage
9	Meghnaghat 450 MW CCPP(MPL)	IPP	2150+1150	450	225	5075100	GT-2 S/D due to Gas shortage
10	Meghnaghat 100 MW (IEL)	NENP	128.9	100	47	860160	Fuel shortage
11	Meghnaghat CCPP(Summit)	IPP	2110+1110	335	10	161920	GT-2 Synchronized at 18:47
12	Madanganj 102 PP(Summit)	NENP	617	102	0	0	Under maint.
13	Madanganj-55 MW PP(Summit)	IPP	317.08+111.3	55	45	992067	Engine problem
14	Keraniganj 100 MW PP (Powerpac)	QRPP	813.45	0	0	0	Contract Expired
15	Nashingdi 22 MW PP (Doreen)	SIPP, REB	82.90	22	7	389376	Engine problem
16	210 MW Siddhiganj TPP	PDB	1210	115	0	0	Under maint.
17	Siddhiganj 2120 MW GTTP	EGCB	2105	210	38	2295000	Gas shortage
18	Siddhiganj 100 PP(Dutch Bangla)	NENP	128.9	100	55	1045440	Fuel shortage
19	Siddhiganj 335 MW CCPP	EGCB	1217+118	335	0	0	Gas shortage
20	Gagnagar 102 MW PP (Digital Power)	IPP	128.924	102	50	550224	Fuel shortage
21	Kaipoti 52 MW PP (Sinha)	IPP	77.9	0	0	0	Fuel shortage
22	Kamatnagar 54 MW PP (Sanco Energy)	IPP	319.8	54	54	53840	Engine problem
23	Kodda 150MW PP	BPDB-RPCL	971.06	149	48	576480	Fuel shortage
24	Manikganj 55 MW PP (Northern)	IPP	319.3	55	35	713943	Engine problem
25	Nababganj 55 MW PP (Southern power)	IPP	319.3	55	35	515437	Engine problem
26	Bosila 108MW PP(CLC)	IPP	128.975+113.5	0	0	0	
27	Summit Power (Madhabdi+Ashulia)	SIPP, REB	33.67+48.73	80	38	1101480	Engine problem
28	Matca 33 MW PP(Summit)	SIPP, REB	48.73	33	25	681360	Engine problem
29	Rugganj 33 MW PP(Summit)	SIPP, REB	48.73	33	28	696700	Engine problem
30	Gazipur 52 MW PP	RPCL	67.9	52	37	686880	Engine problem
31	Tongi 80 MW GTTP	PDB	1105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18717.076	300	264	3354582	Engine problem
33	Keraniya 32 MW PP (AEP)	IPP	2581.4	300	0	140589	Fuel shortage
34	Bramhanganj 100 MW PP (Aggreko)	IPP	1140.959	100	0	86456	Fuel conservation
35	Aurahati 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	0	112850	Fuel conservation
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.45+8.97	149	130	2708064	Engine problem
37	Gazipur 100 MW PP	RPCL	67.9	100	105	1768752	Engine problem
38	Meghnaghat 104 MW PP (OPCL)	IPP	185.6	104	17	439660	Fuel shortage
39	Manikganj 162 MW PP (MPGL)	IPP	31.8	162	144	1933920	Engine problem
40	Spectra Solar Plant Ltd.	IPP	35	35	0	197993	
41	Kanchan Purbachal Power Generation Ltd.	IPP	18.43	55	17	426240	Fuel shortage
	Dhaka area Total			5847	2234	47978336	
41	Chattoagram TPP-1	PDB	1210	180	0	0	Machine problem
42	Chattoagram TPP-2	PDB	1210	180	0	0	Gas shortage
43	Razzer 25 MW PP	RPCL	319.8	25	117	154906	Engine problem
44	Teknaf 20MW PP (Solartech)	IPP	20	20	0	132840	Engine problem
45	Patenga 50MW PP (Baraka)	IPP	876.98	50	26	392160	Engine problem
46	Kapila Hydro: Unit-1,2,3,4, 5	PDB	240+350	230	76	1819140	Low water level
47	Sikalbaha 225MW	PDB	1150+1175	225	151	3460633	ST Under maint
48	Sikalbaha Peaking GT	PDB	1150	0	150	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	617.5	105	105	933381	
50	Hathazari 100 MW peaking PP	PDB	118.9	98	25	390720	Fuel shortage
51	Dohazari-Kataish 100 MW Peaking	PDB	617	102	51	231288	Fuel shortage
52	Julladah 100 MW Unit-1 (Accorn)	NENP	813.45	100	10	261360	Fuel shortage
53	Julladah 100 MW Unit-3 (Accorn)	IPP	813.5	100	12	332160	Fuel shortage
54	Barakunda 32 MW PP (Regent)	SIPP, PDB	82.90	22	0	0	Engine problem
55	Malancha, Ctg. EPZ (Unltd)	IPP	578.73+3.34	0	25	628800	
56	Chattoagram 108 MW PP (ECPV)	IPP	167	108	0	0	Fuel shortage
57	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	26160	
58	Anwara 300 MW PP (Unltd)	IPP	1717+24	300	270	2318400	Engine problem
59	Jodiach Power	IPP	318.55+13.6	54	36	791760	Engine problem
60	Kamarghata Power Ltd	IPP	18.415+9.65	110	73	1455266	Fuel shortage
61	Julladah Unit-2 (Accorn)	IPP	813.6	100	12	295680	Engine problem
62	Anilima Energy Ltd.	IPP	621.2	116	107	2477727	Engine problem
63	Mirshahi 150 MW	BPDB-RPCL	18.59	0	0	0	On test.
	Chattoagram area Total			2382	996	16102381	
61	Ashuganj TPP Unit-3	APSCL	1150	0	0	0	Contract Expired
62	Ashuganj TPP Unit-4	APSCL	1150	0	0	0	Contract Expired
63	Ashuganj TPP Unit-5	APSCL	1150	134	0	0	Gas shortage
64	Ashuganj 225 MW CCPP	APSCL	1142+1175	221	0	0	Gas shortage
65	Ashuganj 450 MW CCPP(North)	APSCL	1360	360	0	0	Gas shortage
66	Ashuganj 450 MW CCPP(South)	APSCL	1360	360	270	5740000	Gas shortage
67	Ashuganj 420 MW CCPP(East)	APSCL	2841+1361	284	432	10270200	On test.
68	Ashuganj 50 MW PP	APSCL	143.968	44	45	1026548	
69	Ashuganj 55 MW PP (Precision)	QRPP	154	55	30	744000	Gas shortage
70	Ashuganj 195MW PP (APSCL-United)	IPP	209.73+116	195	0	0	Gas shortage
71	Ashuganj 51 MW PP (Midland)	IPP	69.34	51	5	216796	Gas shortage
72	Ashuganj 150MW PP (Midland)	IPP	237.015	150	83	1739636	Fuel shortage
73	Titas 50 MW Peaking PP	PDB	678.9	52	22	169956	Engine problem
74	Chandpur 150 MW CCPP	PDB	1106+1157	163	78	1871380	Machine problem
75	Chandpur 200MW (Desh energy)	IPP	1218.4	200	41	723360	High voltage
76	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	22	491328	
77	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	11	239580	
78	Imporit (Tripura)	Imported power	0	180	106	2101440	
79	Jangalia 30 MW (Summit)	SIPP, PDB	48.73	33	33	752100	
80	Jangalia 52 MW PP (Lakshadweep)	IPP	678.92	52	8	211291	Fuel shortage
81	Cumilla 25 MW PP (Summit)	SIPP, REB	313.67+216.97	25	15	349240	Engine problem
82	Daudkandi 200 MW PP (B.Trac)	IPP	1541.4	200	0	74496	Fuel conservation
83	Feni Lanka Power	IPP	718.415+19.78	114	17	429780	Fuel shortage
84	Chowmuhani 113 MW	IPP	129.78+2.31	113	108	1420440	Engine problem
85	Bharat 54 MW	IPP	318.2	54	17	444240	Engine problem
86	Chandpur 115(Doreen)	IPP	418.5+222.5	115	115	1233600	
	Cumilla Area Total			3169	1457	30249411	
87	RPCL 210MW CCPP	IPP	4135+170	202	44	1613760	Gas shortage
88	Tangal 22 MW PP (Doreen)	SIPP, PDB	82.90	22	8	193608	Gas shortage
89	Jamalpur 95 MW PP(Powerpac)	IPP	128.924	0	0	0	Under maint.
90	Sainshahi 3 MW Solar Plant	IPP	15	3	0	13690	
91	Mymensingh 200 MW PP (Unltd)	IPP	978.21	200	56	955200	Fuel shortage
92	Jamalpur 115 MW PP (Unltd)	IPP	978.12	115	58	1203600	Fuel shortage
93	Sulakhali 50 MW Solar PP	IPP	50	50	0	327360	
94	Tangal Pali Power Gen 22 MW	IPP	46.7	22	12	298560	Engine problem
	Mymensingh Area Total			614	178	4065688	
91	Fenchuganj CFP Phase-1	PDB	232+133	70	30	171000	Machine problem
92	Fenchuganj CCPP Phase-2	PDB	235+135	90	43	977880	Machine problem
93	Kushiana 163 MW CCPP (KP)	IPP	1109+154	163	0	0	Gas shortage
94	Shahjibazar 330 MW CCPP	PDB	3110	330	0	0	Under maint.
95	Fenchuganj 51 MW PP (Barakattullah)	RPP	192.90	51	50	1189200	
96	Fenchuganj 44MW (Energyprima)	NENP	123.3+572	50	37	869856	Gas shortage
97	Hobiganj 11MW PP Confidence-E	SIPP, REB	42.90	11	2	97600	Gas shortage
98	Shahjibazar GTTP Unit-8 & 9	PDB	235	66	68	1541952	
99	Shahjibazar 86MW PP (Shahjibazar)	RPP	322.90	86	84	901440	
100	Shahjibazar 100 MW GTTP	PDB	1100	100	0	0	Under maint.
101	Syhet 225 MW CCPP	PDB	1142+1189	231	90	2173420	Machine problem
102	Syhet 20 MW GTTP	PDB	120	19	20	442000	
103	Syhet 50MW PP (EPL)	NENP	272	50	30	655860	Gas shortage
104	Shahjahanula 25 MW PP	SIPP, REB	319.34	25	24	544680	Gas shortage
105	Bitiana-II 341 MW CCPP (Summit)	IPP	1222+1119	341	0	0	Under maint.
106	Bitiyana-III 400 MW CCPP	IPP	400 MW	400	402	9584000	
107	Syhet 10MW PP (Desh)	RPP	61.95	10	10	241520	
108	Bitiyana South 400 MW	PDB	400 MW	383	400	7238300	
	Syhet Area Total			2477	1289	27292108	
107	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
**	Bheramara (HVDC)	Imported power	2500	1000	691	13512000	
108	Khulina 115 PP MW (KPCL-2)	NENP	717	115	82	640320	Engine problem
109	Rangpur 50 MW Peaking PP	PDB	678.99	54	34	35040	Line O/L
110	Khulina 225 MW CCPP	NWPGCL	1150+1175	230	0	0	Fuel shortage
111	Gopalganj 100 MW Peaking PP	PDB	1676.98	109	40	47616	
112	Bheramara 410 MW CCPP	NWPGCL	1278+1132	410	165	4222944	Gas shortage
113	Noapara 40 MW PP (Khanjahan Ali)	NENP	57.5	40	32	126750	Engine problem
114	Noapara 100 MW PP (Bangla Trac)	IPP	707.4	100	0	0	Fuel conservation
115	Rupsha 100 MW PP (Oron rupsha)	IPP	618.445	50	60	708000	High voltage
116	Madhumati 100 MW PP	NWPGCL	618	105	0	0	Fuel shortage
117	Mongla Oron 100 MW Solar PP	IPP	100	100	0	490320	
118	Khulina 330 MW CCPP (OIL)	BPDB	1220+1110	0	0	0	On test.
119	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	274	5930900	On test.
	Khulina Area Total			2384	1368	25713890	
117	Barisal 110 MW PP (Summit)	IPP	717.076	110	0	0	Line O/L
118	Bhola 33 MW PP (Vestare)	NENP	134.50	16	16	336000	Engine problem
119	Bhola 225 MW CCPP	PDB	2163+1168	194	111	3057000	Gas shortage
120	Bhola 95 MW PP (Aggreko)	QRPP	961.10	0	0	0	Contract Expired
121	Payra 1320 MW	BCPCL	2622	1244	370	12109600	Line O/L
122	Bhola Nutan Biddut BD LTD	IPP	220	220	0	0	Under maint.
123	United Payra Power Ltd.	IPP	818.5+19.5	150	0	0	Line O/L
124	Barisal 307 MW	BCPCL	0	0	0	0	On test.
	Barisal Area Total			1958	497	15502600	
124	Baghabari 71 MW GTTP	PDB	1171	71	0	0	Gas shortage
125	Baghabari 100 MW GTTP	PDB	1100	100	0	0	Gas shortage
126	Baghabari 50 MW Peaking PP	PDB	678.9	52	30	112451	Engine problem
127	Bera 70 MW Peaking PP	PDB	978.29	71	4	3510	
128	Anmura 50 MW PP(Sinha)	QRPP	77.9	0	0	0	Contract Expired
129	Kalakhali 50 MW PP (Northern)	QRPP	67.9	50	25	412032	Engine problem
130	Kalakhali 50 MW Peaking PP	PDB	67.9	50	22	139975	Engine problem
131	Sirajgonj Unit-1 225MW	NWPGCL	1150+1175	210	163	4244036	Gas shortage
132	Sirajgonj Unit-2 225MW	NWPGCL	1150+1175	220	0	0	
133	Sirajgonj Unit-3 225MW	NWPGCL	1141	220	0	0	Gas shortage
134	Sirajgonj 400 MW CCPP Unit-4	SNWPGCL	1282+1132	414	210	5467309	Gas shortage
135	Santalaha 50 MW Peaking PP	PDB	67.9	50	35	94153	Engine problem
136	Bogra 22 MW PP (GBB)	RPP	64	22	20	454080	Engine problem
137	Bogra 20 MW PP (Energyprima)	NENP	57.3+57.2	0	0	0	
138	Ullapara 1 MW PP (Summit)	SIPP, REB	42.90				