

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022			Day : Sunday				Date : 27.11.22					
Probable Maximum Demand : 10500 MW			Yesterday = 90.44 ft				Today = 90.14 ft				Rule Curve = 106.50 ft	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.11.22 (Yesterday)		27.11.22 (Today)		26.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	0	0	0	0			Line Overload
3	Ghorasal 365 MW CCP Unit-7	Gas (PDB)	1 x 210	210	190	180	180	180	180			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	1x 254+1x 126	365	365	200	200	200	200		165	Under maint.
5	Tongi 80 MW GTPP	Gas (PDB)	3x3.35	108	108	22	22	22	22			Gas Shortage
6	Hari pur GTTP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Contract Expired
7	Hari pur 360MW CCP(HPL)	Gas (IPP)	1 x 32	32	20	0	0	0	0		360	Gas Shortage
8	Meghnaghat 450 MW CCP(MPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0		225	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	2x140+1x170	450	450	225	225	225	225		225	
10	Hari pur 412 MW CCP	Gas (EGCB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
11	Siddhirganj 2 nd 120 MW GTTP	Gas (EGCB)	1x273+1x139	412	412	400	376	350	350			
12	Siddhirganj 335 MW CCP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210	Gas Shortage
13	Meghnaghat CCP(Summit)	Gas (IPP)	1 x 217+1x118	335	335	0	0	0	0		335	Gas Shortage
14	Madanganj 55 MW PP(Summit)	HFO (IPP)	2x110+1x110	335	335	123	210	230	230		125	Gas Shortage
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	5x17.08+1x11.3	55	55	40	45	45	45			
16	Narshingdi 22 MW PP (Doreen)	HFO (IPP)	12x8.924	102	102	24	50	25	50			
17	Summit Power,(Madhabdi+Ashulia)	HFO (IPP)	8x2.90	22	22	13	19	19	19			
18	Maona 33 MW PP(Summit)	Gas (SI/PP, REB)	8x3.67+7x3.73	80	80	45	46	48	48			
19	Rugganj 33 MW PP(Summit)	Gas (SI/PP, REB)	4x8.73	33	33	22	22	25	25			
20	Gazipur 52 MW PP	HFO (RPCL)	4x8.73	33	33	28	26	33	33			
21	Gazipur 100 MW PP	HFO (RPCL)	6x8.90	52	52	49	44	44	50			
22	Kodda 150MW PP	HFO (BRPgen)	6x18.415	105	105	105	105	105	105			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	9x17.06	149	149	48	48	48	48			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	3x18.69	54	54	17	47	17	54			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	18x17.076	300	300	95	238	95	290			
26	Keranganj 300 MW PP (AFR)	HSD (IPP)	8x18.415+1x8.97	149	149	133	139	45	149			
27	Bramhanagar 100 MW PP (Aggreko)	HSD (IPP)	256x1.4	300	300	0	252	100	150			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	70	50	50			
29	Nababganj 55 MW PP (Southern power)	HSD (IPP)	23x0.85+91x.959	100	100	0	98	50	50			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
32	Manikganj 162 MW PP(MPGL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	9x18	162	162	90	162	90	162			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	1x35	35	35	0	0	30	0			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	3x19.404	55	55	9	15	17	17			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	80	80	80	80			
37	Madanganj 102 PP(Summit)	HFO (NENP)	12x8.9	100	100	73	72	50	92			
Dhaka Zone Total			6004	5847	2108	2898	2310	2851	1360	540		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	76	76	76	76		154	Low water level
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Gas Shortage Under maint.
40	Kapla 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	19	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x8.9	50	50	26	23	25	43			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	105	68	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CCP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	151	151		74	STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	70	255	100	280			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	12	12	12			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	17	51			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	13	40	22	40			
51	Barabkunda 22 MW PP (Regent)	Gas (SI/PP, PDB)	8x2.90	22	22	0	0	0	0		22	Gas Shortage
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	5x8.73+3x9.34	108	108	2	4	5	20			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
54	Karnaphuli Power Ltd.	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36			
55	Juldah unit-2 (Acom)	HFO (IPP)	6x18.41+1x6.4	110	110	54	51	53	91			
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.6	100	100	12	12	12	12			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	8x13.45	100	100	10	10	10	10			
58	Mirshara 150 MW	HFO (BRPgen)	6x21.06	116	116	89	94	89	107			
Chattogram Zone Total			2442	2382	621	937	718	1051	356	404		
58	Ashuganj TPP Unit- 5	Gas (AFSCL)	1 x 150	150	134	0	0	0	134			Gas Shortage
59	Ashuganj 50 MW PP	Gas (AFSCL)	14x3.968	55	45	44	44	44	44			
60	Ashuganj 225 MW CCP	Gas (AFSCL)	1x142+1*75	221	221	0	0	150	180		221	Minor Inspection
61	Ashuganj 450 MW CCP(South)	Gas (AFSCL)	1x360	360	360	230	270	220	250			
62	Ashuganj 450 MW CCP(North)	Gas (AFSCL)	1x361	360	360	0	0	0	0		360	Minor Inspection
63	Ashuganj 420 MW CCP(East) GT	Gas (AFSCL)	1x284	284	284	423	430	260	260			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	30	35	15	15		20	Gas Shortage
65	Ashuganj 195MW PP (AFSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	0	0	195			Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	5	5	5		46	Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	68	102	85	135			
68	Titaz 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	28	22	0	30			
69	Chandpur 150 MW CCP	Gas (PDB)	1X106+1x57	163	163	84	84	85	85		57	ST Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	83	51	200			
71	Feni 22MW PP (Doreen)	Gas (SI/PP, PDB)	8x2.90	22	22	19	16	16	16			
72	Feni 11 MW PP (Doreen)	Gas (SI/PP, REB)	4x2.90	11	11	11	11	11	11			
73	Jangalia 33MW PP (Summit)	Gas (SI/PP, PDB)	4x8.73	33	33	17	32	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SI/PP, REB)	3x3.67+2x6.97	25	25	15	15	15	15			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x18.415+1*9.78	200	200	0	163	100	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	0	17	17			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	116	109	63	108			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	115	52	115			
**	Impoort (Tripura)	India		160	160	96	116	143	166			
Cumilla Zone Total			3193	3169	1314	1677	1390	1810	395	638		
81	RPCL 210MW CCP	Gas (IPP)	4x35+1x70	210	202	34	34	75	105		168	Gas Shortage
82	Tangali 22 MW PP (Doreen)	Gas (SI/PP, PDB)	8x2.90	22	22	8	8	11	11			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	58	49	59			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	57	55	55			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhirai 50 MW Solar PP	Solar (IPP)	1x50	50	50	51	0	50	0			
87	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total			622	614	202	169	254	242	168	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	26.11.22 (Yesterday)		27.11.22 (Today)		26.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening					Day	Evening	
88	Fenchugon CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.				
89	Fenchugon CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	GT-4 Under maint.				
90	Fenchugon 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	50	50							
91	Kushiera 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54	STG Under maint.				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	3	3							
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	68	66	66							
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	84	0	84							
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	90	90	90	90							
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19							
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10							
99	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	22	19	21	21							
100	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Major Inspection	31/12/2022			
101	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	412	423	400	400							
102	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400							
103	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work				
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	31	32	32	32							
105	Fenchugani 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	37	37	37	37							
Sylhet Zone Total				2522	2477	1214	1314	1201	1285		109	912				
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
107	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	150	160	175	175	250		Gas Shortage				
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	45	0	50							
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	75							
110	Khulna 225 MW CCGP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0							
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	84	0	84							
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	70	75	60	75							
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0							
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	76	0	100	0							
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	49	65	83	115							
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	8	32							
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0							
	Khulna 330 MW CCGP	Gas/HSD (PBDB)				0	0	0	0							
**	Bheramara (HVDC)	India		1000	1000	782	897	866	914							
Khulna Zone Total				2388	2384	1127	1350	1292	1520		250	0				
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	12	17	15	20							
119	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	150	145	90	145	49		Gas Shortage				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	520	560	622	622							
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload				
	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0							
122	Bhola 220MW CCGP (Nutan Bidvut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	130	130							
Barishal Zone Total				1958	1958	682	722	857	917		49	260				
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage				
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage				
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	34							
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0							
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	12	0	20							
127	Chapanawabaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	42	75	0	75							
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	40	0	40							
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	34	34	34							
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	28	0	34							
131	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	168	166	165	165			Gas Shortage				
132	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage				
133	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.				
134	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	204	206	220	220	208		Gas Shortage				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	18	18	18							
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11							
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	35	43							
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	37	95	35	95							
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	88	50	113							
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0							
Ratahahi Zone Total				2129	2129	581	840	574	902		643	220				
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			Under Overhauling				
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160	114		Coal Shortage				
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	84	34	84							
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
146	Majpara, Tazulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	0	0	8	0							
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	82	108	113	113							
148	Lalmohar 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	30	0	30	0							
Rangpur Zone Total				830	750	306	352	345	357		199	85				
Sub-total: Plants in operation				22088	21710	8155.0	10259	8941	10935		3529	3059				
(B) Plants under long term maintenance/ contract expired																
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0							
150	Katpohi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0							
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0							
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0							
153	Boogra 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0				Contract Expired on 12/11/2020			
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022			
Sub-Total: Plants under long term maintenance/ contract expired				424	0	0	0	0	0		0	0				
Gross Total				22512	21710	8155	10259	8941	10935		3529	3059				
(C) Actual data of 26.11.22 (Yesterday) Saturday :																
01.	Max. Demand at eve. peak (Generation end)	:	10259 MW, at = 18:00 hrs													
02.	Max. Demand at eve. peak (Sub-station end)	:	9993 MW, at = 18:00 hrs													
03.	Highest Generation (Generation end)	:	10259 MW, at = 18:00 hrs													
04.	Minimum Generation (Generation end)	:	6286 MW, at = 5:00 hrs													
05.	Day-peak Generation (Generation end)	:	8155 MW, at = 12:00 hrs													
06.	Evening-peak Generation (Generation end)	:	10259 MW, at = 18:00 hrs													
07.	Evening Peak Load-shed (Sub-station end)	:	0 MW, at = 18:00 hrs													
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6639 MW, at = 5:00 hrs													
09.	Generation shortfall at evening peak due to :	:														
a)	Gas/LF limitation	:	3176 MW													
c)	Coal supply Limitation	:	199 MW													
b)	Low water level in Kaptai lake	:	154 MW													
c)	Plants under shut down/ maintenance	:	3059 MW													
10.	Total Energy (Generation + India Import)	:	191.15 MKWh													
	By Gas =	105.733 MKWh	By Oil =	46.554 MKWh												
	By Coal =	16.502 MKWh	By Hydro =	1.579 MKWh												
	By Solar =	1.152 MKWh														
11.	Total Gas Supplied	:	MMCFD													
				12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :												
				Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW					
				Dhaka	3933	3933	0	Mymensingh	689	689	0					
				Chattogram	1118	1118	0	Sylhet	381	381	0					
				Khulna	1163	1163	0	Barishal	232	232	0					
				Rajshahi	949	949	0	Rangpur	695	695	0					
				Cumilla	833	833	0									
											Total	9993	9993	0		
											(a) Gas =	108788913 Taka	(c) Coal =	134159181 Taka		
											(b) Oil =	634901983 Taka	Total =	877850076 Taka		
				13. Fuel cost :												
				14. Maximum Temperature in Dhaka was : 31.1° C												
				15. Export through East-West interconnections :												
				At evening peak-hour : 8155 MW, at 18:00 hrs												
				Maximum : 190 MW, at 18:30 hrs												
				Energy : 0 MKWh												
(D) Forecast of 27.11.22 (Today) Sunday :																
01.	Maximum Demand	:	10500 MW (Generation end)													
02.	Maximum Generation	:	10935 MW (Generation end)													
03.	Reserve / Shortage	:	435 MW (Generation end)													
04.	Maximum Load-shed	:	0 MW At evening peak (Sub-station end)													
05.	Total Generation	:	195.64 MKWh													
06.	Probable Max. Temperature in Dhaka :	:	28.4° C													

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation