

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month November, 2022				Day : Tuesday				Date : 29.11.22			
Probable Maximum Demand : 10400 MW				Probable Maximum Generation : 10638 MW				Rule Curve = 106.20 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 89.94 ft				Today = 89.85 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.11.22 (Yesterday)		29.11.22 (Today)		28.11.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		Line Overload
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200	165	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	22	22	22	22		
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Hariapur GTPP	Gas (PDB)	1x 32	32	20	0	0	0	0		Contract Expired
7	Hariapur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	0	0	0	360	Gas Shortage
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	215	225	225	225	225	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hariapur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	323	279	300	280	133	Gas Shortage
11	Siddhirganj 2 120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	230	235	250	250	100	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	45	45	45	45		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	50	33	50		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	16	16		
17	Summit Power,(Madhadi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	44	43	46	46		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	25	33		
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	22	25	25		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	45	49	44	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	88	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	32	32	32		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	17		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	80	145	80	273		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	43	60	45	100		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x6.14	300	300	183	302	100	150		
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	90	144	90	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	29	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	54	80	80	80		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	78	82	80	80		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	0	0		
Dhaka Zone Total				6004	5847	2183	2513	2157	2602	1468	540
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	44	26	44		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	87	17	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	151	151	74	STG Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	233	283	200	290		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	17	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	46	22	50		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34	108	108	2	8	5	10		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	36	36	36	36		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	74	53	74		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12		
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	10	10	10	10		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	89	107		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	150	150	0	0	0	0		on test
Chattogram Zone Total				2442	2382	719	984	738	1015	386	404
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	5	5	43	43		
60	Ashuganj 225 MW CAPP	Gas (APSCl)	1x142+1*75	221	221	210	192	215	200	29	Minor Inspection
61	Ashuganj 450 MW CAPP(South)	Gas (APSCl)	1x360	360	360	220	310	270	280		
62	Ashuganj 450 MW CAPP(North)	Gas (APSCl)	1x361	360	360	0	0	0	0	360	Minor Inspection
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCl)	1x284	284	284	298	288	260	272		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	48	48	50	Gas Shortage
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	80	80	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	5	5	5	46	Gas Shortage
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	73	88	80	120		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	21	21	21	30		
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	70	64	70	70	57	ST Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	136	17	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	19	19	21		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	11	11		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	28	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	16		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+8x11.515+1x1.098	200	200	130	120	100	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	17	17	17		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	106	75	104	113		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	115	34	115		
**	Impoort (Tripura)	India		160	160	90	118	143	166		
Cumilla Zone Total				3193	3169	1398	1664	1610	1972	417	446
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	33	46	33	60	156	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	8	6	7	7		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	58	49	58		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	57	58	48	57		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	47	0	50	0		
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total				622	614	218	180	201	194	156	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.11.22 (Yesterday)		29.11.22 (Today)		28.11.22 Gen. shortfall for : Gas/Coal/Water Limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening					
88	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	0	0		47	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakattallah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
91	Kushiara 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	112	85	85	85	109	54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	65	68	66	66				
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	86	0	86				
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanula 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	24	21	24				
100	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Major Inspection 31/12/2022	
101	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	418	421	400	400				
102	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	400	380	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	31	32	32	32				
105	Fenchugani 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	40	40	40	40				
Sylhet Zone Total					2522	2477	1246	1298	1161	1250	109	912	
106	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
107	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	155	160	170	170	250		Gas Shortage	
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	39	0	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	75	0	75				
110	Khulna 225 MW CCGP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	89	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	75	75	56	75				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	72	0	100	0				
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	81	16	32				
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	8	0	0	8				
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CCGP	Gas/HSD (BPDB)				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	902	888	918	918				
Khulna Zone Total					2388	2384	1212	1407	1260	1368	250	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	12	18	15	19				
119	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	85	81	86	86	113		Gas Shortage	
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	320	460	622	622				
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0				
122	Bhola 220MW CCGP (Nutan Bidvut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	221	200	220				
Barishal Zone Total					1958	1958	639	780	923	947	113	260	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	18	0	20				
127	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	9	100	0	100				
128	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	32				
129	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	25	50	34	34				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	35				
131	Siraiganj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	167	167	165	165	43		Gas Shortage	
132	Siraiganj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Siraiganj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Under maint.	
134	Siraiganj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	231	232	230	230	182		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	22	20	22				
136	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	8	43				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6x18.55	113	113	35	96	35	95				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	113	50	113				
140	Siraiganj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
Ratahahi Zone Total					2129	2129	556	951	559	932	616	220	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Storage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160	114		Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7x16x 2'3	113	113	34	78	34	85				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tazula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thekugaon 119MW PP (Energypac)	HFO (IPP)	6'20	115	115	55	55	0	113				
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	30	0	30	0				
Rangpur Zone Total					830	750	285	293	232	358	199	85	
Sub-total: Plants in operation					22088	21710	8456.0	10070	8841	10638	3714	2867	
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpohi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Bogura 20 MW PP (Energyprima)	Gas (NENP)	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020	
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0	
Gross Total					22512	21710	8456	10070	8841	10638	3714	2867	
(C) Actual data of 28.11.22 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	10284	MW, at =	20:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9721	MW, at =	20:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	10070	MW, at =	20:00 hrs	Dhaka	3781	3672	109	Mymensingh	731	687	44
04.	Minimum Generation (Generation end)	:	6771	MW, at =	5:00 hrs	Chattogram	1110	1110	0	Sylhet	369	343	26
05.	Day-peak Generation (Generation end)	:	8456	MW, at =	12:00 hrs	Khulna	1078	1078	0	Barishal	265	265	0
06.	Evening-peak Generation (Generation end)	:	10070	MW, at =	20:00 hrs	Rajshahi	911	911	0	Rangpur	594	576	18
07.	Evening Peak Load-shed (Sub-station end)	:	197	MW, at =	20:00 hrs	Cumilla	883	883	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7048	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :												
a)	Gas/LF limitation	:	3331	MW						Total	9721	9524	197
c)	Coal supply Limitation	:	199	MW						(a) Gas =	116637923	Taka	109748985
b)	Low water level in Kaptai lake	:	184	MW						(b) Oil =	717921952	Taka	944308860
c)	Plants under shut down maintenance	:	2867	MW						Total =			
10.	Total Energy (Generation + India Import)	:	200.12	MKWh						14.	Maximum Temperature in Dhaka was :	30.6° C	
	By Gas =	110.592	MKWh	By Oil =	50.701	MKWh				15.	Export through East-West interconnections :		
	By Coal =	13.790	MKWh	By Hydro =	1.087	MKWh				At evening peak-hour	:	8456	MW, at 20:00 hrs
	By Solar =	1.294	MKWh							Maximum	:	414	MW, at 7:00 hrs
11.	Total Gas Supplied	:	875.66	MMCFD						Energy	:	0	MKWh
(D) Forecast of 29.11.22 (Today) Tuesday :													
01.	Maximum Demand	:	10400	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	10638	MW	(Generation end)	05.	Total Generation	:	206.68	MKWh			
03.	Reserve / Shortage	:	238	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	28.8° C				

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation