

Sl. No.	Name of the Power Stations	Producer	Installed Capacity		Present Capacity		Peak Hour Generation		Energy Generated		Remarks
			Unit No.	X Capacity	MW	MW	MW	MW	KWH	KWH	
1	Ghorasal Repowered CCPP Unit-3 (GT)	PDB	1260		260	0	0	0	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1210		180	0	0	0	0	0	Line O/L
3	Ghorasal TPP Unit-5	PDB	1210		190	180	4391100				GBC problem
4	Ghorasal 365 MW CCPP Unit-7	PDB	1243+1122		365	200	3669100				0
5	Ghorasal 78.5 MW PP (MAX)	QRPP	240		0	0	0				0
6	Ghorasal 108MW PP (Regent)	IPP	34.3.35		108	22	547818				Gas shortage
7	Haripur GTPP	SBU, PDB	232		0	0	0				Under maint.
8	Haripur 412 MW CCPP	EGCB	1273+1139		412	397	942990				
9	Haripur 360MW CCPP(HPL)	IPP	1235+1125		360	345	793600				
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2150+1150		450	225	5305400				GT-2 S/D due to Gas shortage
11	Meghnaghat 100 MW (IEL)	NENP	12.9		100	30	255360				Engine problem
12	Meghnaghat CCPP(Summit)	IPP	2110+1110		335	0	0				Gas shortage
13	Madanagar 102 MW (Summit)	NENP	6117		102	0	0				Engine problem
14	Madanagar-55 MW PPS(Summit)	IPP	317.08+111.3		55	7	189787				Engine problem
15	Keraniganj 100 MW PP (Powerpac)	QRPP	813.45		0	0	0				Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	82.90		22	16	397728				Engine problem
17	210 MW Siddhirgonj TPP	PDB	1210		115	0	0				Under maint.
18	Siddhirgonj 2120 MW GTPP	EGCB	2105		210	0	0				Gas shortage
19	Siddhirgonj 100 PP(Dutch) Bangla	NENP	128.9		100	70	356160				Engine problem
20	Siddhirgonj 335 MW CCPP	EGCB	1217+118		335	0	0				Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	128.924		102	50	789408				Fuel shortage
22	Kaipoti 52 MW PP (Sinha)	IPP	77.9		0	0	0				Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	318		54	54	338040				
24	Kodda 150MW PP	BPDB-RPCL	917.06		149	32	151680				Fuel shortage
25	Manikganj 55 MW PP (Northern)	IPP	319.3		55	17	432987				Engine problem
26	Nabaganj 55 MW PP (Southern power)	IPP	319.3		55	17	431055				Engine problem
27	Bosila 108MW PP(CLC)	IPP	128.775+113.5		0	0	0				0
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	33.67+48.73		80	55	1089240				Engine problem
29	Madhabdi 33 MW PP (Summit)	SIPP, REB	48.73		33	25	627500				Engine problem
30	Ruaganj 33 MW PP (Summit)	SIPP, REB	48.73		33	28	727800				Engine problem
31	Gazipur 52 MW PP	RPCL	69.9		52	50	383520				0.00
32	Tongi 80 MW GTPP	PDB	1105		105	0	0				Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076		300	279	2744945				Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	2567.4		300	0	0				Fuel conservation
35	Bramhartha 100 MW PP (Aggreko)	IPP	1149.959		100	0	0				Fuel conservation
36	Aurahat 100MW PP (Aggreko)	IPP	0.8523+0.9591		100	0	0				Fuel conservation
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.45+8.97		149	131	1456992				Engine problem
38	Gazipur 100 MW PP	RPCL	617.5		105	105	1088400				
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.56		104	54	1049280				Fuel shortage
40	Manikganj 162MW PP(MPGL)	IPP	918		162	53	612000				Fuel shortage
41	Spectro Solar Plant Ltd.	IPP	35		35	0	158701				
42	Kanchan Flurbachal Power Generation Ltd.	IPP	18.43		55	17	298540				Fuel shortage
Dhaka area Total					5847	2459	44855631				
43	Chattogram TPP-1	PDB	1210		180	0	0				Machine problem
44	Raozan TPP-2	PDB	1210		180	0	0				Gas shortage
45	Raozan 25 MW PP	RPCL	39.9		25	17	153342				Engine problem
46	Tafzal 20MW PP (Salarlech)	IPP	20		20	0	68015				
47	Palenga 50MW PP (Baraka)	IPP	69.96		50	19	201120				Engine problem
48	Kapila Hydro Unit-1,2,3,4, 5	PDB	240+350		230	46	1100580				Low water level
49	Sikalbaha 225MW	PDB	1150+1175		225	145	3587098				ST Under maint
50	Sikalbaha Peaking GT	PDB	1150		150	0	0				Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	617.5		105	85	863127				Engine problem
52	Hathazari 100 MW peaking PP	PDB	119.9		102	38	245448				Gas shortage
53	Dohazari -Kalaisih 100 MW Peaking	PDB	617		102	51	468493				Fuel shortage
54	Juldah 100 MW Unit-1 (Accorn)	NENP	813.45		100	10	234480				Fuel shortage
55	Juldah 100 MW PP Unit-3 (Accorn)	IPP	813.5		100	25	386880				Fuel shortage
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	62.90		22	0	0				Engine problem
57	Maranda Ch. EPZ Unit-1	IPP	58.73+9.34		0	5	434880				0
58	Chattogram 108 MW PP (ECPV)	IPP	167		108	0	0				Fuel shortage
59	Kapila 7 MW Solar PP	PDB	7.4 MW		7	0	19922				
60	Anwara 300 MW PP (United)	IPP	1717+24		300	287	2037382				Engine problem
61	Jodiac Power	IPP	318.55+113.6		54	36	681743				Engine problem
62	Kanapathuli Power Ltd.	IPP	18.415+6.5		110	72	1170904				Fuel shortage
63	Juldah unit-1 (Accorn)	IPP	813.5		100	12	365260				
64	Anlima Energy Ltd.	IPP	621.2		116	70	1607073				Engine problem
65	Minshahi 150 MW	BPDB-RPCL	18.59		0	0	0				On test.
Chattogram area Total					2382	912	13546767				
66	Ashuganj TPP Unit-3	APSCCL	1150		0	0	0				Contract Expired
67	Ashuganj TPP Unit-4	APSCCL	1150		0	0	0				Contract Expired
68	Ashuganj TPP Unit-5	APSCCL	1150		0	134	0				Gas shortage
69	Ashuganj 225 MW CCPP	APSCCL	1142+1175		221	183	4846000				Gas shortage
70	Ashuganj 450 MW CCPP(North)	APSCCL	1360		360	280	735800				Gas shortage
71	Ashuganj 450 MW CCPP(South)	APSCCL	1360		360	300	6626000				FGMO
72	Ashuganj 420 MW CCPP(East)	APSCCL	2841+1361		284	0	32300				On test.
73	Ashuganj 50 MW PP	APSCCL	143.968		45	10	690096				Gas shortage
74	Ashuganj 15 MW PP (Precision)	QRPP	157.4		55	23	384000				Gas shortage
75	Ashuganj 195MW PP (APSCCL-United)	IPP	209.73+116		195	8	1020363				Gas shortage
76	Ashuganj 51 MW PP (Midland)	IPP	69.34		51	5	435852				Gas shortage
77	Ashuganj 150MW PP (Midland)	IPP	237.015		150	102	879854				Fuel shortage
78	Titas 50 MW Peaking PP	PDB	68.92		52	38	231684				Engine problem
79	Chandpur 150 MW CCPP	PDB	1106+157		163	0	0				Machine problem
80	Chandpur 200 MW (Desh energy)	IPP	1214.4		200	33	570240				High voltage
81	Feni 22MW PP (Doreen)	SIPP, PDB	82.90		22	21	492408				
82	Feni 11 MW PP (Doreen)	SIPP, REB	42.90		11	10	236160				Engine problem
83	Import (Tripura)	Imported power	0		160	102	1955520				
84	Jangjala 33MW PP (Summit)	SIPP, PDB	48.73		33	26	763700				Engine problem
85	Jangjala 50 MW PP (Lakshmi)	IPP	69.96		52	8	122520				Fuel shortage
86	Cumilla 25 MW PP (Summit)	SIPP, REB	33.67+26.97		25	15	361910				Engine problem
87	Daudkandi 200 MW PP (B. Trac)	IPP	1541.4		200	0	0				Fuel conservation
88	Feni Lanka Power	IPP	718.415+19.78		114	17	150480				Fuel shortage
89	Chowmuhani 113 MW	IPP	129.78+23.1		113	116	1318800				
90	Bharoh 54.5 MW	IPP	318.2		54	17	385920				Engine problem
91	Chandpur 115 (Doreen)	IPP	418.5+222.5		115	70	889280				High voltage
Cumilla Area Total					3169	1384	29227457				
92	RPCL 210MW CCPP	IPP	4135+170		202	42	1988160				Gas shortage
93	Tangal 22 MW PP (Doreen)	SIPP, PDB	82.90		22	19	431280				Gas shortage
94	Jamalpur 95 MW PP (Powerpac)	IPP	128.924		0	0	0				Under maint.
95	Sarishabari 3 MW Solar Plant	IPP	13		3	0	12300				
96	Mymensingh 200 MW PP (United)	IPP	978921		200	57	545600				Fuel shortage
97	Jamalpur 115 MW PP (United)	IPP	97812		115	59	944400				Fuel shortage
98	Suliakhali 50 MW Solar PP	IPP	50		50	0	262690				
99	Tangal Pali Power Gen 22 MW	IPP	46.7		22	12	309600				Engine problem
Mymensingh Area Total					614	189	4894030				
100	Fenchuganj CCPP Phase-1	PDB	232+133		70	39	716000				Machine problem
101	Fenchuganj CCPP Phase-2	PDB	235+135		90	42	954390				Machine problem
102	Kushara 163 MW CCPP (KP)	IPP	1104+154		163	0	0				Gas shortage
103	Shahjibazar 330 MW CCPP	PDB	3110		330	0	0				Under maint.
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	192.90		51	33	475200				Gas shortage
105	Fenchuganj 44MW (Energyprima)	NENP	123.3+52		50	49	942912				
106	Haldiganj 11MW PP (Confidence-E)	SIPP, REB	42.90		11	8	192284				Engine problem
107	Shahjibazar GTTP Unit-1 & 2	PDB	235		86	20	615552				GT-9 under maint.
108	Shahjibazar 86MW PP (Shahjibazar)	RPP	322.90		86	84	648960				
109	Shahjibazar 100 MW GTTP	PDB	1100		100	0	0				Under maint.
110	Sylhet 225 MW CCPP	PDB	1142+189		231	218	5204120				
111	Sylhet 20 MW GTTP	PDB	120								