

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2022			Day : Sunday				Date : 11.12.22					
Probable Maximum Demand : 10200 MW			Yesterday = 88.96 ft				Today = 88.88 ft				Rule Curve = 105.10 ft	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.12.22 (Yesterday)		11.12.22 (Today)		10.12.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		Line Overload	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	0	0			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	22	22	32	32	86	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Hariapur GTPP	Gas (PDB)	1x 32	32	20	0	0	0	0		Contract Expired	
7	Hariapur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	353	345	350	350			
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Hariapur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	402	397	400	400			
11	Siddhirganj 2' 120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	Gas Shortage	
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	7	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	33	50	33	50			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	16	16	16	16		
17	Summit Power,(Madhadi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	56	55	49	49			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	25	25	25	25			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.75	33	33	25	28	31	31			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	24	50	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	70	105	70	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	32	32	32			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	110	279	98	282			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	51	131	90	135			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	150			
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	17	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	17	17	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	39	54	55	55			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	53	17	54			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	25	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	1	70	60	70			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	30	42	42			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	100	100			
Dhaka Zone Total			6004	5847	1942	2459	2108	2769	1178	493		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	46	46	46	46	184	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	1	17	17	17			
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	7	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	6x8.89	50	50	2	19	19	19			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	21	85	17	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	146	145	150	150	80	STG Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	70	287	200	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	20	25	12	12			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	51	17	50			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	25	32	22	40			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage	
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	5	5	10			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	36	36			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	43	72	54	73			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	10	10	10	10			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	70	70	89	89			
**	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test	
Chattogram Zone Total			2442	2382	513	912	731	969	386	410		
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	43	10	10	10			
60	Ashuganj 225 MW CAPP	Gas (APSCl)	1x142+1*75	221	221	206	183	220	220			
61	Ashuganj 450 MW CAPP(South)	Gas (APSCl)	1x360	360	360	300	300	250	300			
62	Ashuganj 450 MW CAPP(North)	Gas (APSCl)	1x361	360	360	325	280	0	0			
63	Ashuganj 420 MW CAPP(East) GT	Gas (APSCl)	1x284	284	284	0	0	330	330			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	23	5	32		Gas Shortage	
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	5	5	5	46		Gas Shortage	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	102	15	102			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	38	38	30	35			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	57	ST Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	78	33	34	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	27	26	30	30			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+8x11.515+1x1.098	200	200	0	0	0	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	17	17			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	8	116	36	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	70	34	94			
**	Impoort (Tripura)	India		160	160	66	102	143	166			
Cumilla Zone Total			3193	3169	1208	1384	1238	1806	399	57		
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	71	42	70	75	160	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	19	19			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	59	47	59			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	47	57	50	57			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	29	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total			622	614	225	189	250	222	160	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.12.22 (Yesterday)		11.12.22 (Today)		10.12.22 (Yesterday) Gen. shortfall for : Gas/Coal/Water Limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)							
					Day	Evening	Day	Evening						
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.		
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.		
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	25	33	33	33					
91	Kushihara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	STG Under maint.		
92	Hobighanj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	20	33	33					
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	0	84	0	86					
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	219	218	218	220					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	16	22	22					
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0		341	Major Inspection	31/12/2022	
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	417	375	400	400					
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	260	225	260	260					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	11	11	11	11					
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	40	49	30	44					
Sylhet Zone Total					2522	2477	1131	1139	1116	1218	0	913		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
107	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Under maint.		
108	Fairdipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	38					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	32	0	80					
110	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	50					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	56	55	94					
113	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	62	0	100	0					
115	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	83	32	115					
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	24	0	24					
	Rampal 1320 MW	Coal (BIFPCL)				472	562	550	550					
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				0	0	0	0					
**	Bheramara (HVDC) India		1000	1000	845	893	920	920	920					
Khulna Zone Total					2388	2384	1396	1650	1657	1871	0	410		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	16		110	Line Overload		
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	19	19	19					
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	172	160	187	187					
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	250	370	300	370					
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	6x18.415+1x9.78	150	150	0	0	0	35		150	Line Overload		
	Barisal Electric 307 MW	Coal (IPP)				0	0	0	0					
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	158	220	200	220					
Barishal Zone Total					1958	1958	596	769	706	847	0	260		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32					
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	25					
127	Chapinawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	43	0	89					
128	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40					
129	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	34	34	34					
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	26	0	35					
131	Sirajganj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	180	170	190	190					
132	Sirajganj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0		220	Gas Shortage		
133	Sirajganj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.		
134	Sirajganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	346	290	330	350					
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	43	43	43					
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	100	35	113					
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	86	35	113					
140	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	0	0	6	0					
	Adani Power Jharkhanda Ltd	Coal	1x6	6	6	0	106	160	160					
Ratahali Zone Total					2135	2135	633	1003	866	1257	391	220		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160		114	Coal Shortage		
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	49	34	113					
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Majpara, Tazula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
147	Thekugaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	108	35	113					
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	29	0	30	0					
	Teesta Solar Limited	Solar (IPP)				87	0	0	0					
Rangpur Zone Total					830	750	351	317	267	386	199	85		
Sub-total: Plants in operation					22094	21716	7995.0	9822.0	8939.0	11345.0	2713.0	2848.0		
(B) Plants under long term maintenance/ contract expired														
149	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
150	Kaptoti 32 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
151	Bosila 108MW PP (CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
153	Bogura 20 MW PP (Energyprima)	Gas NENP	5x3.3+5x2.0	20	0	0	0	0	0			Contract Expired on 12/11/2020		
154	Ammura 30 MW PP (Sinha)	HFO (QRPP)	7x7.90	50	0	0	0	0	0			Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired					424	0	0	0	0	0	0	0		
Gross Total					22518	21716	7995	9822	8939	11345	2713	2848		
(C) Actual data of 10.12.22 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	: 9822 MW, at = 18:00 hrs												
02.	Max. Demand at eve. peak (Sub-station end)	: 9362 MW, at = 18:00 hrs												
03.	Highest Generation (Generation end)	: 9822 MW, at = 18:00 hrs												
04.	Minimum Generation (Generation end)	: 6021 MW, at = 5:00 hrs												
05.	Day-peak Generation (Generation end)	: 7995 MW, at = 12:00 hrs												
06.	Evening-peak Generation (Generation end)	: 9822 MW, at = 18:00 hrs												
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 18:00 hrs												
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6264 MW, at = 5:00 hrs												
09.	Generation shortfall at evening peak due to :													
a)	Gas/Lf limitation	: 2330 MW												
c)	Coal supply Limitation	: 199 MW												
b)	Low water level in Kaptai lake	: 184 MW												
c)	Plants under shut down/ maintenance	: 2848 MW												
10.	Total Energy (Generation + India Import)	: 187.92 MMCFD												
	By Gas = 111.294 MKWH	By Oil = 29.689 MKWH												
	By Coal = 25.052 MKWH	By Hydro = 1.101 MKWH												
	By Solar = 1.621 MKWH													
11.	Total Gas Supplied	: 860.96 MMCFD												
			12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
			Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
			Dhaka	3457	3457	0	Mymensingh	768	768	0				
			Chattogram	1078	1078	0	Sylhet	366	366	0				
			Khulna	1114	1114	0	Barishal	244	244	0				
			Rajshahi	827	827	0	Rangpur	695	695	0				