

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 12-Dec-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1210	180	0	0	Line O/L
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4350150	
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243*1122	365	0	0	GBC problem
5	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
6	Ghorasal 108MW PP (Regent)	IPP	343.35	108	56	1285900	Gas shortage
7	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1273*1139	412	397	9551800	
9	Haripur 360MW CCGP(HPL)	IPP	1235*1125	360	302	7052000	Gas shortage
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2150*1150	450	225	5435000	GT-2 S/D due to Gas shortage
11	Meghnaghat 100 MW(IEI)	NENP	12*9	100	34	471360	Engine problem
12	Meghnaghat CCGP(Summit)	IPP	2110*1110	335	0	0	Gas shortage
13	Madanagar 102 MW(Summit)	NENP	6*17	102	63	729519	Engine problem
14	Madanagar-55 MW PPS(Summit)	IPP	3*17.08*111.3	55	15	559216	Engine problem
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	16	393730	Engine problem
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirgonj 210 MW GTPP	EGCB	2105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch) Bangla	NENP	12*9	100	30	394560	Fuel shortage
20	Siddhirgonj 335 MW CCGP	EGCB	1217*118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	50	695800	Fuel shortage
22	Kaipoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	330120	
24	Kodda 150MW PP	BPDB-RPCL	9*17.06	149	64	348960	Fuel shortage
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	484967	Engine problem
26	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	17	436077	Engine problem
27	Bosila 108MW PP(CLC)	IPP	12*8.775*113.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67*4*8.73	80	22	845160	Engine problem
29	Madhabdi 33 MW PP(Summit)	SIPP, REB	4*8.73	33	25	616800	Engine problem
30	Ruaganj 30 MW PP(Summit)	SIPP, REB	4*9.73	30	28	705700	Engine problem
31	Gazipur 52 MW PP	RPCL	6*8.9	52	41	548640	0.00
32	Tongi 80 MW GTPP	PDB	1*105	0	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	273	3005889	Engine problem
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	112828	Fuel conservation
35	Bramhanaga 100 MW PP (Aggreko)	IPP	1149.959	100	0	70723	Fuel conservation
36	Aurahi 100MW PP (Aggreko)	IPP	0.85*23*0.95*91	100	0	53760	Fuel conservation
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	129	1483344	Engine problem
38	Gazipur 100 MW PP	RPCL	6*17.5	105	105	1508400	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	55	961920	Fuel shortage
40	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	54	585200	Fuel shortage
41	Spectro Solar Plant Ltd.	IPP	35	35	0	144397	
42	Kanchan Flatbatal Power Generation Ltd.	IPP	18.4*3	55	18	378720	Fuel shortage
Dhaka area Total				5847	2288	43580137	
43	Chattoagram TPP-1	PDB	1210	180	0	0	Machine problem
44	Chattoagram TPP-2	PDB	1210	180	0	0	Gas shortage
45	Raozan 25 MW PP	RPCL	3*8.9	25	25	270289	Engine problem
46	Takraf 20MW PP (Sadarlech)	IPP	20	20	0	129465	
47	Palenga 50MW PP (Baraka)	IPP	6*8.96	50	20	298080	Engine problem
48	Kapali Hydro Unit-1,2,3,4, 5	PDB	2*40*3*50	230	46	1102980	Low water level
49	Sikalbaha 225MW	PDB	1*1150*1175	225	145	3555221	ST Under maint
50	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	51	597163	Engine problem
52	Hathazari 100 MW peaking PP	PDB	11*9.9	100	98	281472	Fuel conservation
53	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	50	471523	Fuel shortage
54	Juldah 100 MW Unit-1 (Accom)	NENP	8*13.45	100	10	231960	Fuel shortage
55	Juldah 100 MW PP Unit-3 (Accom)	IPP	8*13.5	100	12	1064640	Fuel shortage
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	6*2.90	22	0	0	Engine problem
57	Manarcho. Ch. EPZ (United)	IPP	5*8.73*9.34	0	5	339360	
58	Chattoagram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Fuel shortage
59	Kapali 7 MW Solar PP	PDB	7.4 MW	7	0	22918	
60	Anwara 300 MW PP (United)	IPP	17*17*24	300	270	2243127	Engine problem
61	Jodiach Power	IPP	3*18.55+11*3.6	54	36	551330	Engine problem
62	Kanapahuli Power Ltd.	IPP	18.415*6+8.5	110	75	1411776	Fuel shortage
63	Juldah unit-3 (Accom)	IPP	8*13.5	100	12	269760	
64	Anlima Energy Ltd.	IPP	6*21.2	116	107	1983436	
65	Minshahi 150 MW	BPDB-RPCL	18.5*9	0	0	18400	On test.
Chattoagram area Total				2382	896	14842900	
66	Ashuganj TPP Unit-3	APSCL	1150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-4	APSCL	1150	0	0	0	Contract Expired
68	Ashuganj TPP Unit-5	APSCL	1150	134	0	0	Gas shortage
69	Ashuganj 225 MW CCGP	APSCL	1142*1175	221	162	4485000	FGMO
70	Ashuganj 450 MW CCGP(North)	APSCL	1*360	360	0	0	FGMO
71	Ashuganj 450 MW CCGP(South)	APSCL	1*360	360	295	7201000	FGMO
72	Ashuganj 420 MW CCGP(East)	APSCL	284*11*116*1	400	328	8376000	On test.
73	Ashuganj 50 MW PP	APSCL	14*3.968	45	30	384336	Gas shortage
74	Ashuganj 100 MW PP (Precision)	QRPP	5	55	5	76800	Gas shortage
75	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+11*6	195	8	100363	Gas shortage
76	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	5	405524	Gas shortage
77	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	103	804581	Fuel shortage
78	Titas 50 MW Peaking PP	PDB	6*8.92	50	37	306576	Engine problem
79	Chandpur 150 MW CCGP	PDB	1210*1157	163	0	0	Machine problem
80	Chandpur 200MW (Desh energy)	IPP	12*14.4	200	36	584960	High voltage
81	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	20	383940	
82	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	10	242820	
83	Impoport (Tripura)	Imported power	0	160	114	2221440	
84	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	22	661700	Engine problem
85	Jangalia 50 MW PP (Lakshmi)	IPP	6*8.92	52	8	135149	Fuel shortage
86	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67*2*6.97	25	15	343850	Engine problem
87	Daudkandi 200 MW PP (B.Trac)	IPP	15*41.4	200	0	11904	Fuel conservation
88	Feni Lanka Power	IPP	7*18.415+1*9.78	114	17	220020	Fuel shortage
89	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	117	1779120	
90	Bharob 54.5 MW	IPP	3*18.2	54	17	445230	Engine problem
91	Chandpur 115 (Doreen)	IPP	4*18.5*2*22.5	115	95	854240	High voltage
Cumilla Area Total				3285	1464	30104643	
92	RPCL 210MW CCGP	IPP	4*35*170	202	46	1807620	Gas shortage
93	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	444456	Gas shortage
94	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
95	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	9950	
96	Mymensingh 200 MW PP (United)	IPP	9*78*21	200	57	1008000	Fuel shortage
97	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	59	992400	Fuel shortage
98	Suliakhali 50 MW Solar PP	IPP	50	50	0	211860	
99	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	12	299280	Engine problem
Mymensingh Area Total				614	193	4772666	
100	Fenchuganj CCGP Phase-1	PDB	2*32*133	60	30	716000	Machine problem
101	Fenchuganj CCGP Phase-2	PDB	2*35*135	42	90	948240	Machine problem
102	Kushara 163 MW CCGP (KP)	IPP	1100*1154	163	0	0	Gas shortage
103	Shahjibazar 330 MW CCGP	PDB	3*110	330	0	0	Under maint.
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	5	450600	Gas shortage
105	Fenchuganj 44MW (Energyprima)	NENP	12*3.3*5.2	50	30	759294	
106	Haldiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	9	192394	Engine problem
107	Shahjibazar GTTP Unit-3 & 9	PDB	2*35	86	84	1281600	GT-9 under maint.
108	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	84	821760	
109	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
110	Sylhet 225 MW CCGP	PDB	1142*1189	231	218	5145350	
111	Sylhet 20 MW GTTP	PDB	1*20	20	18	439000	
112	Sylhet 50MW PP (EPL)	NENP	2*72	50	11	286160	Gas shortage
113	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	22	530208	
114	Bitiana-II 341 MW CCGP (Summit)	IPP	1*222*1119	341	0	0	Under maint.
115	Bitiyana-III 400 MW CCGP	PDB	400 MW	400	418	9264000	
116	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	10	248220	
117	Bitiyana South 400 MW	PDB	400 MW	383	255	5774900	ST Under maint
Sylhet Area Total				2477	1215	26558662	
118	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
119	Bheramara (HVDC)	Imported power	2*500	1000	911	20106181	
120	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	16	84480	low demand
121	Fariapur 50 MW Peaking PP	PDB	6*8.89	54	0	0	Line O/L
122	Khulna 225 MW CCGP	NWPGCL	1150*1175	230	160	469440	
123	Casapara 100 MW Peaking PP	PDB	16*9.98	100	0	0	Line O/L
124	Bheramara 410 MW CCGP	NWPGCL	1278*1132	410	0	0	Under maint.
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	40	47250	
126	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Fuel conservation
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	35	465120	Engine problem
128	Madhumati 160 MW PP	NWPGCL	6*18	105	0	0	Fuel shortage
129	Mongia Orion 100 MW Solar PP	IPP	100	100	0	409880	
130	Khulna 330 MW CCGP (DIL)	BPDB	1220*1110	0	0	0	On test.
131	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	519	12872250	On test.
Khulna Area Total				2384	1681	34544401	
132	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Line O/L
133	Bhola 33 MW PP (Venture)	NENP	1*34.50	40	22	479500	Engine problem
134	Bhola 225 MW CCGP	PDB	2*63*1168	194	167	4298480	
135	Bhola 95 MW PP (Aggreko)	QRPP					