

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month December, 2022			Day : Monday				Date : 26.12.22					
Probable Maximum Demand : 10000 MW			Yesterday = 87.02 ft				Today = 86.95 ft				Rule Curve = 103.60 ft	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.12.22 (Yesterday)		26.12.22 (Today)		25.12.22 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		Line Overload	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200		ST under maint	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	71	72	70	70	36	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Harijpur GTTP	Gas (PDB)	1x 32	32	20	0	0	0	0		Contract Expired	
7	Harijpur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	312	336	330	330			
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Harijpur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	408	409	400	412			
11	Siddhirganj 2' 120 MW GTTP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	Gas Shortage	
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	0	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	16	16	16			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22			
17	Summit Power,(Madhadi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	52	50	51	51			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	25	25			
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	29	32	32			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	49	41	50	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	90	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	32	32	32			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	95	32	95			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	36	35	35	35			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	145	152	0	150			
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	65	81	0	50			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	25	86	0	50			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	35	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	17	17	17			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	22	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	24	17	33	38			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	19	17	34	34			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	34	34	34			
Dhaka Zone Total			6004	5847	2069	2414	1879	2431	1128	683		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	17	17	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x8.89	50	50	0	0	0	19			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	85	85	17	85			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	151	150	30	150	75	STG Under maint.	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	66	290	51	290			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	12	12	12	12			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	50			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	32	4	32			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage	
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			5	12	5	10			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	8			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	35			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	72	72	72	72			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	12	12	12			
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	10	10	10	10			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
**	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test	
Chattogram Zone Total			2442	2382	631	916	409	939	402	405		
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	35	10	5	5			
60	Ashuganj 225 MW CCGP	Gas (APSCl)	1x142+1'75	221	221	208	206	210	220			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCl)	1x360	360	360	335	305	320	320			
62	Ashuganj 450 MW CCGP(North)	Gas (APSCl)	1x361	360	360	0	0	0	0	360	Gas Shortage	
63	Ashuganj 420 MW CCGP(East)	Gas (APSCl)	1x284+1x116	400	400	258	288	350	330			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	15	0	5	5			
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	65	3	70	85	Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	29	21	25	30			
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	28	17	51			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	20	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	20	20	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+8x11.515+1x1.098	200	200	62	50	0	100			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	17	17			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	9	8	9			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	53	36	72			
**	Impoort (Tripura)	India		160	160	88	108	135	152			
Cumilla Zone Total			3309	3285	1232	1284	1294	1544	766	163		
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	33	32	70	100	170	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	19	19			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	47	53	46	48			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	24	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12			
Mymensingh Zone Total			622	614	163	163	227	226	170	0		

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25.12.22 (Yesterday)		26.12.22 (Today)		25.12.22 (Yesterday)		Status of Machines under shut-down/ Maintenance			
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
						Day	Evening	Day	Evening						
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30			40	GT-1 Under maint.		
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43			47	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	53	53						
91	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	109	54		STG Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	63	65	66						
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x.90	86	86	40	84	30	86						
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	100	130	130	130						
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	19	18	19	19						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	21	21	21	25						
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	0	0			341	Major Inspection 31/12/2022		
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	408	402	400	400						
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	395	400	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work		
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	25	26	26	26						
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4*5*2	50	50	46	46	30	40						
Sylhet Zone Total						2522	2477	1260	1334	1265	1336	109	912		
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
107	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0			410	Under maint.		
108	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	5	0	40						
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	12	0	70						
110	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0						
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	50						
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	18	17	17						
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0						
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	64	0	100	0						
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	32	16	0	16						
116	Noapara 40 MW PP (Khanjehan Ali)	HFO (NENP)	5*8.5	40	40	16	0	0	40						
	Rampal 1320 MW	Coal (BIFPCL)				402	416	400	400						
	Khulna 330 MW CAPP	Gas/HSD (B/PDB)				0	0	0	0						
**	Bheramara (H/DC) India			1000	1000	817	911	726	918						
Khulna Zone Total						2388	2384	1331	1378	1243	1551	0	410		
117	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0			110	Line Overload		
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	23	19	24						
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	157	156	150	150						
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	250	280	400	400						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	35			150	Line Overload		
	Barisal Electric 307 MW	Coal (IPP)				200	308	172	172						
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	108	108	110	110						
Barishal Zone Total						1958	1958	733	875	851	891	0	260		
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100	Gas Shortage		
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	34						
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	100						
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	25						
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	58	0	58						
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	16	0	40						
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	42	42	42						
130	Santzhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	27	0	30						
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	154	152	190	190						
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	12	0	15	15			220	Gas Shortage		
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0			220	Under maint.		
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	231	155	350	350			259	Gas Shortage		
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	16	20	20						
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8						
138	Baqura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	95	35	113						
139	Baqura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	94	35	95						
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0						
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0						
Raishahi Zone Total						2129	2129	517	709	709	1128	870	220		
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling		
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	159	160	160			115	Coal Shortage		
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	70	113	34	113						
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
146	Majpara, Tatulia 8 MW Solar PP (Syma Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0						
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	90	114	35	113						
148	Malmonhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	20	0	30	0						
	Treeta Solar Limited	Solar (IPP)				67	0	0	0						
Rangpur Zone Total						830	750	412	386	267	386	200	85		
Sub-total: Plants in operation						22204	21826	8348.0	9459	8144	10432	3645	3138		
(B) Plants under long term maintenance/ contract expired															
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0						
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
153	Ammura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0	0	0	0		
Gross Total						22608	21826	8348	9459	8144	10432	3645	3138		
(C) Actual data of 25.12.22 (Yesterday) Sunday :															
01.	Max. Demand at eve. peak (Generation end)	:	9459	MW, at =	18:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	9049	MW, at =	18:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	:	9459	MW, at =	18:00 hrs	Dhaka	3294	3294	0	Mymensingh	750	750	0		
04.	Minimum Generation (Generation end)	:	6121	MW, at =	5:00 hrs	Chattogram	965	965	0	Sylhet	354	354	0		
05.	Day-peak Generation (Generation end)	:	8348	MW, at =	12:00 hrs	Khulna	1101	1101	0	Barishal	243	243	0		
06.	Evening-peak Generation (Generation end)	:	9459	MW, at =	18:00 hrs	Rajshahi	909	909	0	Rangpur	653	653	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	18:00 hrs	Cumilla	780	780	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6243	MW, at =	5:00 hrs	Total							9049	9049	0
09.	Generation shortfall at evening peak due to :	:				13. Fuel cost :							(a) Coal =	92723040	Taka
	a) Gas/LF limitation	:	3245	MW		(b) Oil =							418368489	Taka	
	d) Coal supply Limitation	:	200	MW		Total =							621822731	Taka	
	b) Low water level in Kaptai lake	:	200	MW		14. Maximum Temperature in Dhaka was :							28.0° C		
	c) Plants under shut down/ maintenance	:	3138	MW		15. Export through East-West interconnections :									
10.	Total Energy (Generation + India Import)	:	188.46	MKWh		At evening peak-hour							8348	MW, at	18:00 hrs
	By Gas =	107.375	MKWh	By Oil =	30.930	MKWh	Maximum						34	MW, at	18:30 hrs
	By Coal =	27.200	MKWh	By Hydro =	0.732	MKWh	Energy						0	MKWh	