

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present	Peak	Energy	Remarks
				Capacity	Hour	Generated	
				MW	Generation	KWH	
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1210	180	240	422600	
3	Ghorasal TPP Unit-5	PDB	1210	190	0	0	Machine problem
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
6	Ghorasal 108MW PP (Regent)	IPP	343.35	108	70	1501272	Machine problem
7	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1273+1139	412	344	8787970	Gas shortage
9	Haripur 360MW CCGP(HPL)	IPP	1235+1125	360	263	6810000	Gas shortage
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2150+1150	450	225	5906350	GT-2 S/D due to Gas shortage
11	Meghnaghat 100 MW(HEL)	NENP	12'8.9	100	17	235200	Fuel shortage
12	Meghnaghat CCGP(Summit)	IPP	2110+1110	335	0	0	Gas shortage
13	Madanagar 102 MW(Summit)	NENP	6'11	102	17	528759	Fuel shortage
14	Madanagar-55 MW PPS(Summit)	IPP	3'17.08+111.3	55	15	131280	Fuel shortage
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	13	369936	
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirgonj 2120 MW GTPP	EGCB	2105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch) Bangla	NENP	12'8.9	100	9	120000	Fuel shortage
20	Siddhirgonj 335 MW CCGP	EGCB	1217+118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	16	302112	Fuel shortage
22	Kaipoti 52 MW PP (Sirha)	IPP	7'7.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	54	54	387720	
24	Kodda 150MW PP	BPDB-RPCL	9'17.06	149	0	317280	Fuel shortage
25	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	55	633369	
26	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	55	610703	
27	Bosila 108MW PP(CLC)	IPP	12'8.775+113.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3'3.67+4'8.73	80	46	1049100	Engine problem
29	Madhabdi 33 MW PP(Summit)	SIPP, REB	4'8.73	33	20	565700	Engine problem
30	Ruzganj 30 MW PP(Summit)	SIPP, REB	4'8.73	33	33	755000	Engine problem
31	Gazipur 52 MW PP	RPCL	6'8.9	52	8	208800	High voltage
32	Tongi 80 MW GTPP	PDB	1'105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	98	1021200	Fuel shortage
34	Keraniganj 300 MW PP (APR)	IPP	256'1.4	300	0	234775	Fuel conservation
35	Bramhanaga 100 MW PP (Aggreko)	IPP	1149.959	100	0	0	Fuel shortage
36	Auraha 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	0	105000	Fuel shortage
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	40	992160	Fuel shortage
38	Gazipur 100 MW PP	RPCL	6'17.5	105	17	756000	High voltage
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	17	320640	Fuel shortage
40	Manikganj 162MW PP(MPGL)	IPP	9'18	162	162	1087200	
41	Spectro Solar Plant Ltd.	IPP	35	0	0	108949	
42	Kanchan Flatbatal Power Generation Ltd.	IPP	18.4'3	55	17	410040	Fuel shortage
Dhaka area Total				5847	1851	38485615	
43	Chattoagram TPP-1	PDB	1210	180	140	3000000	Machine problem
44	Chattoagram TPP-2	PDB	1210	180	0	0	Gas shortage
45	Raozan 25 MW PP	RPCL	3'8.9	25	8	362953	Low Demand
46	Tafal 20MW PP (Solartech)	IPP	20	20	0	115425	
47	Palanga 50MW PP (Baraka)	IPP	8'6.98	50	6	268320	High voltage
48	Kapila Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	30	1048320	Low water level
49	Sikalbaha 225MW	PDB	1'1150+1'175	225	0	0	Gas shortage
50	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	17	462561	Fuel shortage
52	Hathazari 100 MW peaking PP	PDB	11'9.9	98	0	247296	Low Demand
53	Dohazari -Kalash 100 MW Peaking	PDB	6'17	102	0	92017	Fuel shortage
54	Juldah 100 MW Unit-1 (Accorn)	NENP	8'13.45	100	22	516960	Fuel shortage
55	Juldah 100 MW PP Unit-3 (Accorn)	IPP	8'13.5	100	25	603840	Fuel shortage
56	Barakunda 22 MW PP (Regent)	SIPP, PDB	8'2.90	22	0	62000	Engine problem
57	Manaraha Cn EPZ Unit-1	IPP	5'8.73+9.34	0	30	828000	
58	Chattoagram 108 MW PP (ECPV)	IPP	16'7	108	0	31680	Fuel shortage
59	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	18723	
60	Anwara 300 MW PP (United)	IPP	17'17+24	300	294	1944545	
61	Jodiak Power	IPP	3'18.55+113.6	54	17	449888	Engine problem
62	Kanapathuli Power Ltd.	IPP	18.415+8.5	110	72	1688611	Fuel shortage
63	Juldah unit-1 (Accorn)	IPP	8'13.6	100	25	605760	High voltage
64	Anlima Energy Ltd.	IPP	6'21.2	116	68	1799018	Engine problem
65	Minshahi 150 MW	BPDB-RPCL	18.5'9	0	0	0	On test.
Chattoagram area Total				2382	754	14103937	
66	Ashuganj TPP Unit-3	APSCL	1'150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-4	APSCL	1'150	0	0	0	Contract Expired
68	Ashuganj TPP Unit-5	APSCL	1'150	134	0	0	Gas shortage
69	Ashuganj 225 MW CCGP	APSCL	1142+1175	221	190	4599500	FCMO
70	Ashuganj 450 MW CCGP(North)	APSCL	1'360	360	290	7555000	FCMO
71	Ashuganj 450 MW CCGP(South)	APSCL	1'360	360	0	0	Gas shortage
72	Ashuganj 420 MW CCGP(East)	APSCL	2841+1161*	400	348	7796000	Gas shortage
73	Ashuganj 50 MW PP	APSCL	14'3.968	45	5	148680	Gas shortage
74	Ashuganj 100 MW PP (Precision)	QRPP	15'14	55	5	144480	Gas shortage
75	Ashuganj 195MW PP (APSCL-United)	IPP	20'9.73+11.6	195	8	200727	Gas shortage
76	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	51	1126140	
77	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	75	575418	Fuel shortage
78	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	0	Machine problem
79	Chandpur 150 MW CCGP	PDB	11'106+1'57	163	0	0	Machine problem
80	Chandpur 200MW (Desh energy)	IPP	12'14.4	200	17	432480	Fuel shortage
81	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	21	503064	
82	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	10	243180	
83	Import (Tripura)	Imported power		160	100	1977600	
84	Jangjala 33MW PP (Summit)	SIPP, PDB	4'8.73	33	25	670100	Engine problem
85	Jangjala 50 MW PP (Lakshmi)	IPP	8'9.92	52	8	179563	Fuel shortage
86	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	21	379660	Engine problem
87	Daudkandi 200 MW PP (B.Trac)	IPP	154'1.4	200	0	88512	Fuel conservation
88	Feni Lanka Power	IPP	7'18.415+1'9.78	114	17	705660	Fuel shortage
89	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	107	798000	Engine problem
90	Bharoh 54.5 MW	IPP	3'18.2	54	17	435600	Engine problem
91	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	0	0	Fuel shortage
Cumilla Area Total				3285	1315	28599364	
92	RPCL 210MW CCGP	IPP	4'35+1'70	202	107	1653120	Gas shortage
93	Tangal 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	20	247680	Gas shortage
94	Jamalpur 95 MW PP (Powerpac)	IPP	12'8.924	0	0	0	Under maint.
95	Sarishabari 3 MW Solar Plant	IPP	1'3	0	0	3600	
96	Mymensingh 200 MW PP (United)	IPP	9'78'21	48	200	1130400	Fuel shortage
97	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	47	747600	Fuel shortage
98	Sulakhali 50 MW Solar PP	IPP	50	50	0	122830	
99	Tangal Pali Power Gen 22 MW	IPP	4'6.7	22	12	288000	
Mymensingh Area Total				614	234	4193230	
100	Fenchuganj CCGP Phase-1	PDB	2'32+1'33	70	30	716000	Machine problem
101	Fenchuganj CCGP Phase-2	PDB	2'35+1'35	90	31	589320	Machine problem
102	Kushihara 163 MW CCGP (KP)	IPP	1109+1154	163	112	2765154	ST under maint
103	Shahjibazar 330 MW CCGP	PDB	3'110	330	0	0	Under maint.
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	1104600	
105	Fenchuganj 44MW (Energyprima)	NENP	12'9.3+5'2	50	46	906552	
106	Haldiganj 1 MW PP (Confidence-E)	SIPP, REB	4'2.90	11	9	162432	Engine problem
107	Shahjibazar TPP Unit-3 & 9	PDB	2'35	86	84	122934	
108	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	86	898560	
109	Shahjibazar 100 MW GTPP	PDB	1'100	100	0	0	Under maint.
110	Sylhet 225 MW CCGP	PDB	1142+1189	231	0	0	Under maint.
111	Sylhet 20 MW GTPP	PDB	1'20	20	19	45800	
112	Sylhet 50MW PP (EPL)	NENP	2'72	50	26	582320	Gas shortage
113	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	389760	Gas shortage
114	Bibiana-II 341 MW CCGP (Summit)	IPP	1'222+1119	341	0	0	Under maint.
115	Bibiana-III 400 MW CCGP	PDB	400 MW	400	400	8862000	
116	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	249660	
117	Bibiyana South 400 MW	PDB	400 MW	383	400	9146400	
Sylhet Area Total				2477	1307	28993042	
118	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
119	Bheramara (HVDC)	Imported power	2'500	1000	871	16525090	
120	Khulna 115 PP MW (KPCL-2)	NENP	7'17	115	32	1053120	Fuel shortage
121	Fardpur 50 MW Peaking PP	PDB	8'6.89	54	0	47040	Line O/L
122	Khulna 225 MW CCGP	NWP/GCL	1150+1175	230	0	0	Fuel conservation
123	Cazapara 100 MW Peaking PP	PDB	18'6.98	109	109	112128	Line O/L
124	Bheramara 410 MW CCGP	NWP/GCL	1278+1132	410	0	0	Under maint.
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	70125	Fuel shortage
126	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0	Fuel conservation
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	17	201120	Fuel shortage
128	Madhumati 160 MW PP	NWP/GCL	6'18	160	0	0	Fuel shortage
129	Mongia Orion 100 MW Solar PP	IPP	100	100	0	379440	
130	Khulna 330 MW CCGP (DIL)	BPDB	1220+1110	0	0	0	On test.
131	Rampal 1320 MW (BIFPCL)	NTPCBPDB	0	0	0	0	Demi water shortage
Khulna Area Total				2384	920	16388063	
132	Barisal 110 MW PP (Summit)	IPP	7'17.076	110	0	0	Line O/L
133	Bhola 33 MW PP (Venture)	NENP	1'34.50	40	23	452900	Engine problem
134	Bhola 225 MW CCGP	PDB	2'63+1'68	162	104	3289186	
135							