

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 31-Dec-22

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1210	180	240	516900	
3	Ghorasal TPP Unit-5	PDB	1210	190	0	0	Machine problem
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
6	Ghorasal 108MW PP (Regent)	IPP	34.3.35	108	73	1500227	Machine problem
7	Haripur GTPP	SBU, PDB	232	0	0	0	Under maint.
8	Haripur 412 MW CCGP	EGCB	1273+1139	412	396	8904700	Gas shortage
9	Haripur 360MW CCGP(HPL)	IPP	1235+1125	360	360	7164000	
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2150+1150	450	225	5900650	GT-2 S/D due to Gas shortage
11	Meghnaghat 100 MW(IEI)	NENP	12.9	100	17	25400	Fuel shortage
12	Meghnaghat CCGP(Summit)	IPP	2110+1110	335	0	0	Gas shortage
13	Madanagar 102 MW(Summit)	NENP	6117	102	34	279933	Fuel shortage
14	Madanagar-55 MW PPS(Summit)	IPP	317.08+111.3	55	30	120633	Fuel shortage
15	Keraniganj 100 MW PP (Powerpac)	QRPP	813.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	82.90	22	10	311580	Engine problem
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirgonj 2120 MW GTTP	EGCB	2105	210	0	0	Gas shortage
19	Siddhirgonj 100 PP(Dutch) Bangla	NENP	129.9	100	8	128640	Fuel conservation
20	Siddhirgonj 335 MW CCGP	EGCB	1217+118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12.8.924	102	16	251280	Fuel shortage
22	Kaipoti 52 MW PP (Sinha)	IPP	77.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	318	54	54	392400	
24	Kodda 150MW PP	BPDB-RPCL	917.06	149	32	486720	Fuel shortage
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	55	666607	
26	Nabaganj 55 MW PP (Southern power)	IPP	319.3	55	55	566931	
27	Bosila 108MW PP(CLC)	IPP	128.775+113.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	33.67+48.73	80	44	1102200	Engine problem
29	Madhabdi 33 MW PP(Summit)	SIPP, REB	48.73	33	25	471960	Engine problem
30	Ruaganj 30 MW PP(Summit)	SIPP, REB	48.73	30	30	683600	Engine problem
31	Gazipur 52 MW PP	RPCL	69.9	52	50	483360	0.00
32	Tongi 80 MW GTTP	PDB	11105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	97	948436	Fuel shortage
34	Keraniganj 300 MW PP (APR)	IPP	2567.14	300	12	71574	Fuel conservation
35	Bramhantha 100 MW PP (Aggreko)	IPP	1149.959	100	0	0	Fuel conservation
36	Auraha 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	51	102890	Fuel conservation
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.45+8.97	149	131	789408	Fuel shortage
38	Gazipur 100 MW PP	RPCL	617.5	105	105	1396200	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.56	104	17	323520	Fuel shortage
40	Manikganj 162MW PP(MPGL)	IPP	918	162	162	1105920	
41	Spectro Solar Plant Ltd.	IPP	35	35	0	114792	
42	Kanchan Flutbatal Power Generation Ltd.	IPP	18.43	55	17	369720	Fuel shortage
Dhaka area Total				5847	2346	40051331	
43	Chattoagram TPP-1	PDB	1210	180	70	220000	Machine problem
44	Chattoagram TPP-2	PDB	1210	180	0	0	Gas shortage
45	Raozan 25 MW PP	RPCL	39.9	25	25	386602	
46	Tafal 20MW PP (Solartech)	IPP	20	20	0	98415	
47	Palenga 50MW PP (Baraka)	IPP	69.96	50	20	298080	High voltage
48	Kapila Hydro Unit-1,2,3,4, 5	PDB	240+350	230	46	1046940	Low water level
49	Sikalbaha 225MW	PDB	1150+1175	225	55	702494	Gas shortage
50	Sikalbaha Peaking GT	PDB	1150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	617.5	105	51	523563	Fuel shortage
52	Hathazari 100 MW peaking PP	PDB	119.9	102	51	416139	Fuel shortage
53	Dohazari -Kalaish 100 MW Peaking	PDB	617	102	51	235856	Fuel shortage
54	Juldah 100 MW Unit-1 (Accorn)	NENP	813.45	100	22	518640	Fuel shortage
55	Juldah 100 MW PP Unit-3 (Accorn)	IPP	813.5	100	35	635520	Fuel shortage
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	62.90	22	0	0	Engine problem
57	Manaraha Cst. EPZ (United)	IPP	58.73+9.34	0	31	725760	
58	Chattoagram 108 MW PP (ECPV)	IPP	167	108	0	116160	Fuel shortage
59	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	20	
60	Anwara 300 MW PP (United)	IPP	1717+24	300	274	1811564	Engine problem
61	Jodiak Power	IPP	318.55+113.6	54	17	450118	Engine problem
62	Kanapathu Power Ltd.	IPP	18.15+6+8.5	110	72	1355740	Fuel shortage
63	Juldah unit-3 (Accorn)	IPP	813.5	100	25	612480	
64	Anlima Energy Ltd.	IPP	621.2	116	68	1457782	Engine problem
65	Minshahi 150 MW	BPDB-RPCL	18.59	0	0	28436	On test.
Chattoagram area Total				2382	894	13620309	
66	Ashuganj TPP Unit-3	APSCL	1150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-4	APSCL	1150	0	0	0	Contract Expired
68	Ashuganj TPP Unit-5	APSCL	1150	134	0	0	Gas shortage
69	Ashuganj 225 MW CCGP	APSCL	1142+1175	221	183	4587000	FGMO
70	Ashuganj 450 MW CCGP(North)	APSCL	1360	360	290	7445000	FGMO
71	Ashuganj 450 MW CCGP(South)	APSCL	1360	360	0	0	Gas shortage
72	Ashuganj 420 MW CCGP(East)	APSCL	2841+1161	400	318	7713200	Gas shortage
73	Ashuganj 50 MW PP	APSCL	143.068	45	5	148752	Gas shortage
74	Ashuganj 100 MW PP (Precision)	QRPP	1514	55	5	144860	Gas shortage
75	Ashuganj 195MW PP (APSCL-United)	IPP	209.73+116	195	8	200727	Gas shortage
76	Ashuganj 51 MW PP (Midland)	IPP	69.34	51	51	1017260	
77	Ashuganj 150MW PP (Midland)	IPP	237.015	150	63	505163	Fuel shortage
78	Titas 50 MW Peaking PP	PDB	68.92	52	38	160672	Machine problem
79	Chandpur 150 MW CCGP	PDB	1106+157	163	0	0	Machine problem
80	Chandpur 200MW (Desh energy)	IPP	1214.4	200	17	330240	Fuel shortage
81	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	21	508428	
82	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	10	242640	
83	Import (Tripura)	Imported power	0	180	108	2195520	
84	Jangalia 33MW PP (Summit)	SIPP, PDB	48.73	33	25	690500	Engine problem
85	Jangalia 50 MW PP (Lakshmi)	IPP	69.96	52	52	121406	Fuel shortage
86	Cumilla 25 MW PP (Summit)	SIPP, REB	33.67+26.97	25	21	368050	Engine problem
87	Daudkandi 200 MW PP (B. Trac)	IPP	1541.4	200	10	37632	Fuel conservation
88	Feni Lanka Power	IPP	718.415+19.78	114	17	251940	Fuel shortage
89	Chowmuhani 113 MW	IPP	129.78+23.1	113	106	1578360	Engine problem
90	Bharob 54.5 MW	IPP	318.2	54	17	445320	Engine problem
91	Chandpur 115 (Doreen)	IPP	418.5+222.5	115	0	0	Fuel shortage
Cumilla Area Total				3285	1321	28666770	
92	RPCL 210MW CCGP	IPP	4135+170	202	35	1781760	Gas shortage
93	Tangal 22 MW PP (Doreen)	SIPP, PDB	82.90	22	22	471276	
94	Jamalpur 95 MW PP(Powerpac)	IPP	128.924	0	0	0	Under maint.
95	Sarishabari 3 MW Solar Plant	IPP	13	0	0	6400	
96	Mymensingh 200 MW PP (United)	IPP	9789.21	200	57	892800	Fuel shortage
97	Jamalpur 115 MW PP (United)	IPP	9781.12	115	47	648000	Fuel shortage
98	Suliakhali 50 MW Solar PP	IPP	50	50	0	97200	
99	Tangal Pali Power Gen 22 MW	IPP	46.7	22	12	210720	
Mymensingh Area Total				614	173	4108156	
100	Fenchuganj CCGP Phase-1	PDB	232+133	70	30	716000	Machine problem
101	Fenchuganj CCGP Phase-2	PDB	235+135	31	31	294800	Machine problem
102	Kushihara 163 MW CCGP (KP)	IPP	1109+1154	163	112	2619491	ST under maint
103	Shahjibazar 330 MW CCGP	PDB	3110	330	0	0	Under maint.
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	192.90	50	50	934200	
105	Fenchuganj 44MW (Energyprima)	NENP	123.3+52	51	47	908084	
106	Haldiganj 11MW PP (Confidence-E)	SIPP, REB	42.90	11	8	192384	Engine problem
107	Shahjibazar GTTP Unit-3 & 9	PDB	235	86	85	128688	
108	Shahjibazar 86MW PP (Shahjibazar)	RPP	322.90	86	85	1437120	
109	Shahjibazar 100 MW GTTP	PDB	1100	100	0	0	Under maint.
110	Sylhet 225 MW CCGP	PDB	1142+1189	231	0	39190	Under maint.
111	Sylhet 20 MW GTTP	PDB	120	20	19	455000	
112	Sylhet 50MW PP (EPZ)	NENP	2712	50	27	634160	Gas shortage
113	Shahjahanulla 25 MW PP	SIPP, REB	39.34	25	16	277680	Gas shortage
114	Bibiana-II 341 MW CCGP (Summit)	IPP	1222+1119	341	0	0	Under maint.
115	Bibiana-III 400 MW CCGP	PDB	400 MW	400	396	864000	
116	Sylhet 10MW PP (Desh)	RPP	61.95	10	10	250920	
117	Bibiyana South 400 MW	PDB	400 MW	383	400	9225200	
Sylhet Area Total				2477	1296	27918657	
118	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
119	Bheramara (HVDC)	Imported power	2500	1000	919	17760727	
120	Khulna 115 PP MW (KPCL-2)	NENP	717	115	114	910080	
121	Fariapur 50 MW Peaking PP	PDB	69.89	54	33	135840	Engine problem
122	Khulna 225 MW CCGP	NWP/GCL	1150+1175	230	0	0	Fuel conservation
123	Casapara 100 MW Peaking PP	PDB	116.98	109	76	315136	Engine problem
124	Bheramara 410 MW CCGP	NWP/GCL	1278+1132	410	0	0	Under maint.
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	59.5	40	40	219000	
126	Noapara 100 MW PP (Bangla Trac)	IPP	701.4	100	0	0	Fuel conservation
127	Rupsha 105 MW PP (Orion rupsha)	IPP	618.445	105	17	280800	Fuel shortage
128	Madhumati 100 MW PP	NWP/GCL	618	105	0	0	Fuel shortage
129	Mongia Orion 100 MW Solar PP	IPP	100	100	0	378720	
130	Khulna 330 MW CCGP (DIL)	BPDB	1220+1110	0	0	0	On test.
131	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	0	0	0	0	
Khulna Area Total				2384	1199	20000303	
132	Barisal 110 MW PP (Summit)	IPP	717.076	110	0	0	Line O/L
133	Bhola 33 MW PP (Venture)	NENP	134.50	40	25	417900	Engine problem
134	Bhola 225 MW CCGP	PDB	2933+1168	194	181	4357937	Machine problem
135	Bhola 95 MW PP (Aggreko)	QRPP	961.10	0	0	0	Contract Expired
136	Payra 1320 MW	BCPCL	2622	1244	450	1134080	