

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023			Day : Tuesday				Date : 03.01.23				
Probable Maximum Demand : 9800 MW			Probable Maximum Generation : 10061 MW				Rule Curve = 102.62 ft.				
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 86.23 ft		Today = 86.16 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.01.22 (Yesterday)		03.01.23 (Today)		02.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Under maint.
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	200	200	200	165	ST under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	71	76	70	76	32	Gas Shortage
5	Tongj 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Hariapur GTPP	Gas (PDB)	1x 32	32	20	0	0	0	0		Contract Expired
7	Hariapur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	340	354	340	360		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Hariapur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	403	366	390	400		
11	Siddhirganj 2 120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	Gas Shortage
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage
14	Madanganj 55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	30	0	30		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	13	16	16	16		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19		
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	50	44	48	48		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	33	25	25		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	30	30	30		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	50	50	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	32	16	16		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	98	32	98		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	35	35	35		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	239	40	150	150		
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	70	0	0	0		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	0	17		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	49	8	8	8		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	43	17	17	17		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	34	34	34		
Dhaka Zone Total			6004	5847	1928	2155	1961	2302	1124	848	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	0	46	46	46	184	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	19	19	19		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	151	151		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x6.04	300	300	52	295	51	300		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	44	40	24	40		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage
*	Malancha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	15	5	15		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	13	0	10		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	72	52	72		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25		
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	22	22	22	22		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	51	51	51	51		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test
Chattogram Zone Total			2442	2382	528	918	555	920	386	330	
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	38	35	5	5		
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1*75	221	221	191	182	190	200		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0	360	Under maint.
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	355	355	350	350		
63	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	60	0	60		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	30	5	5	5	50	Gas Shortage
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*116	195	195	150	16	16	16	179	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	55	6	55	95	Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	37	22	25	38		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	0	17	17		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	23	25	25	25		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	3	8	8	8		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	18	21	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+6x1.515+1x1.098	200	200	80	140	100	100		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	0	0	0		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	65	106	105	108		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	52	94	70	94		
**	Impoort (Tripura)	India		160	160	102	110	135	152		
Cumilla Zone Total			3309	3285	1260	1330	1177	1353	458	523	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	32	58	75	75	144	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	48	48	48		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	42	0	50	0		
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12		
Mymensingh Zone Total			622	614	186	187	237	213	144	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.01.22 (Yesterday)		03.01.23 (Today)		02.01.22 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening					
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	GT-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	31	31		59	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	50	45	50				
91	Kushiara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	75	75	0	0		54	STG Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	64	64	64				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	84	50	84				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	85	172	170	170				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16				
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	0	0	200	200				
101	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	280	232	252	252				
102	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0				
105	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.4*5*2	50	50	49	50	44	44				
Sylhet Zone Total					2522	2477	1168	1240	1339	1378	0	583	
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	15	0	0	0	0				
107	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0		410	Under maint.	
108	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	0	40				
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	70	0	76				
110	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	50	0	50				
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17				
113	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	0	0				
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	61	0	100	0				
115	Khulna 115 MW PP (KFCL-2)	HFO (NENP)	7x17	115	115	83	49	16	16				
116	Noapara 40 MW PP (Khanjehan Ali)	HFO (NENP)	5*8.5	40	40	0	40	40	40				
	Rampal 1320 MW	Coal (BIFPCL)				0	0	0	0				
	Khulna 330 MW CAPP	Gas/HSD (BFPDB)				0	0	0	0				
**	Bheramara (H/DC)	India		1000	1000	823	916	838	935				
Khulna Zone Total					2388	2384	967	1180	1011	1174	0	410	
117	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0		110	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	23	19	25				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	68	68	68	68				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	350	590	500	622				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0		150	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				308	244	308	308				
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	221	220	220				
Barisal Zone Total					1958	1958	963	1146	1115	1243	0	260	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	0	34				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	91	80	0	100				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	15	0	25				
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	42	0	65				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	5	40	0	40				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	50	42	50				
130	Santzhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	0	36				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	142	125	150	160		95	Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0		220	Under maint.	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	273	290	280	300		124	Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	20	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8				
138	Baqura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	55	35	55				
139	Baqura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	50	35	50				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				0	82	180	180				
Raishahi Zone Total					2129	2129	660	926	766	1133	600	220	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	160	160	160	160		114	Coal Shortage	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	70	34	70				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	93	113	115	115				
148	Malmonhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	23	0	30	0				
	Trestle Solar Limited	Solar (IPP)				152	0	0	0				
Rangpur Zone Total					830	750	466	343	347	345	199	85	
Sub-total: Plants in operation					22204	21826	8126.0	9425	8508	10061	2911	3259	
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Ammura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
	Sub-Total: Plants under long term maintenance/ contract expired			404	0	0	0	0	0				
Gross Total					22608	21826	8126	9425	8508	10061	2911	3259	
(C) Actual data of 02.01.22 (Yesterday) Monday :													
01.	Max. Demand at eve. peak (Generation end)	:	9425	MW, at =	19:00 hrs								
02.	Max. Demand at eve. peak (Sub-station end)	:	9036	MW, at =	19:00 hrs								
03.	Highest Generation (Generation end)	:	9425	MW, at =	19:00 hrs								
04.	Minimum Generation (Generation end)	:	5954	MW, at =	5:00 hrs								
05.	Day-peak Generation (Generation end)	:	8126	MW, at =	12:00 hrs								
06.	Evening-peak Generation (Generation end)	:	9425	MW, at =	19:00 hrs								
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	19:00 hrs								
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6081	MW, at =	5:00 hrs								
09.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	2528	MW									
	d) Coal supply Limitation	:	199	MW									
	b) Low water level in Kaptai lake	:	184	MW									
	c) Plants under shut down/ maintenance	:	3259	MW									
10.	Total Energy (Generation + India Import)	:	841.33	MMCFD									
	By Gas =	106.263	By Oil =	35.740	By Coal =	23.378	By Hydro =	0.611					
	By Solar =	1.957											
11.	Total Gas Supplied	:											
(D) Forecast of 03.01.23 (Today) Tuesday :													
01.	Maximum Demand	:	9800	MW	(Generation end)								
02.	Maximum Generation	:	10061	MW	(Generation end)								
03.	Reserve / Shortage	:	261	MW	(Generation end)								
04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)								
05.	Total Generation	:	196.28	MW									
06.	Probable Max. Temperature in Dhaka :	:	25.5° C										
(E) Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :													
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW					
	Dhaka	3354	3354	0	Mymensingh	769	769	0					
	Chattogram	894	894	0	Sylhet	355	355	0					
	Khulna	1129	1129	0	Barisal	255	255	0					
	Rajshahi	811	811	0	Rangpur	642	642	0					
	Cumilla	828	828	0									
					Total	9036	9036	0					
13.	Fuel cost :	(a) Gas =	114225403	Taka	(c) Coal =	129539491	Taka						
		(b) Oil =	509739073	Taka	Total =	753503967	Taka						
14.	Maximum Temperature in Dhaka was :	:	26.0° C										
15.	Export through East-West interconnections :	:											
	At evening peak-hour	:	8126	MW, at	19:00 hrs								
	Maximum	:	86	MW, at	8:00 hrs								
	Energy	:	0	MW									

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation