

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023			Day : Tuesday					Date : 10.01.23						
Probable Maximum Demand : 10100 MW			Yesterday = 85.71 ft					Today = 85.66 ft					Rule Curve = 101.29 ft	
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.01.23 (Yesterday)		10.01.23 (Today)		09.01.23 (Yesterday)		10.01.23 (Today)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Machines shut down (MW)	Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW					
(A) Plants in operation:														
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260		Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0		190		Under maint.	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	200	200	200			165	ST under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3.35	108	108	71	74	70	73			34	Gas Shortage	
5	Tongi 80 MW GT PP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105		Gas Shortage	
6	Hari pur GT PP	Gas (PDB)	1 x 32	32	20	0	0	0	0		0		Contract Expired	
7	Hari pur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	273	265	330	330		95		Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0		450		Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling	
10	Hari pur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	341	333	400	400		79		Gas Shortage	
11	Siddhirganj 2 120 MW GT PP	Gas (EGCB)	2 x 105	210	210	0	0	0	0		210		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		217	118	Gas Shortage	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	157	156	150	160		179		Gas Shortage	
14	Madanganj-55 MW PP (Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	45	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8					
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	16	19	22					
17	Summit Power, (Madhadi+Ashulia)	Gas (SIPP, REB)	8x3.67+7x3.73	80	80	37	21	46	46					
18	Maona 33 MW PP (Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rupganj 33 MW PP (Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	28	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	50	49	50	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	16	16	16					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	65	32	98					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	17	17	17					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	77	0	100					
27	Bramhaniganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	35	55					
30	Maniganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	17	0	17					
32	Maniganj 162MW PP (MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162					
33	Maniganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17					
35	Siddhirganj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	8	8	8					
36	Meghnaghat 100 MW (IEL)	HFO (NENP)	12x8.9	100	100	10	9	9	9					
37	Madanganj 102 PP (Summit)	HFO (NENP)	6x17	102	102	64	64	90	90					
Dhaka Zone Total			6004	5847	1597	1929	1822	2213	1549	848				
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30		200		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180			Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180		Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0						
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	21	25	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	20	20	20					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150		Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	158	158	161	161					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	52	300	51	300					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25					
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	25	32	25	34					
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22			Gas Shortage	
52	Malanha, Cig.EP2 (United)	Gas	5x8.73+3x9.34			2	6	4	7					
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0					
54	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17					
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	51	34	51					
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25					
57	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	22	22	22	22					
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	34	34	34					
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0				on test	
Chattogram Zone Total			2442	2382	505	847	566	853	402	330				
58	Ashuganj TPP Unit- 5	Gas (APSL)	1 x 150	150	134	0	0	0	0		134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSL)	14x3.968	53	45	5	5	5	5		40		Gas Shortage	
60	Ashuganj 225 MW CCPP	Gas (APSL)	1x142+1*75	221	221	224	224	220	220					
61	Ashuganj 450 MW CCPP(South)	Gas (APSL)	1x360	360	360	0	0	0	0			360	Under maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (APSL)	1x361	360	360	295	300	360	360					
63	Ashuganj 420 MW CCPP(East)	Gas (APSL)	1x284+1x116	400	400	268	269	290	300					
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5		50		Gas Shortage	
65	Ashuganj 195MW PP (APSL-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8		187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	43	51					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	5	53	6	55		97		Gas Shortage	
68	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	32	29	31	31					
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163		Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	0	0					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	17	21	21					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	15	21	25	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	21	21					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+8x15+1x19.08	200	200	100	179	100	200					
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	0	0					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	13	9	9					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.56+2x25.428	115	115	88	75	94	94					
**	Impoort (Tripura)	India		160	160	100	112	135	153					
Cumilla Zone Total			3309	3285	1259	1434	1408	1601	508	523				
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	106	70	100		96		Gas Shortage	

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	09.01.23 (Yesterday)		10.01.23 (Today)		09.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
							Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
							Day	Evening	Day	Evening				
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0			70	GT-1 Under maint.	
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	31	31	31	31			59	GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	53	45	45					
91	Kushaira 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			163	Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	5	5	5					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	62	62	62					
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	3x2x2.90	86	86	40	84	40	86					
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	192	201	225	225					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	19	19	19					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	0	0					
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	325	300	330	330					
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0			400	Under maint.	
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work	
104	Sylhet 50MW PP (EPL)	Gas (NENP)	2x27	50	50	0	0	0	0					
105	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12x3.4+5*2	50	50	47	43	44	44					
Sylhet Zone Total				2522	2477	1153	1216	1211	1257	0	1122			
106	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	15	0	0	0	0					
107	Bheramara 410 MW CCPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	0	0	0	0			410	Under maint.	
108	Fandipur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	20	27	0	40					
109	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	63	0	76					
110	Khulna 225 MW CCPP	HSD (NWP/CGCL)	1 x 150+1x75	230	230	0	0	0	0					
111	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	89	90	90	90					
112	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17					
113	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	0	0	0					
114	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	76	0	100	0					
115	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	32	99	32	100					
116	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	153	40	40					
	Rampal 1320 MW	Coal (BIFPCL)				0	153	540	540					
	Khulna 330 MW CCPP	Gas/HSD (BFPDB)				0	0	0	0					
**	Bheramara (H/DC) India			1000	1000	481	491	496	496					
Khulna Zone Total				2388	2384	715	956	1275	1309	0	410			
117	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	100	0	100			10	Line Overload	
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	24	19	25					
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	162	131	130	180					
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	622	622	622	622					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	63	0	0			87	Line Overload	
	Barisal Electric 307 MW	Coal (IPP)				278	149	150	300					
122	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	105	108	105	105					
Barisal Zone Total				1958	1958	1205	1197	1026	1332	0	97			
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100	Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	32					
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	50					
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	17	0	25					
127	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	43	0	90					
128	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	0	40					
129	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	8	8	8					
130	Santhar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	34	0	36					
131	Sirajganj 225MW CCPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	0	0	0	0			210	Gas Shortage	
132	Sirajganj 225MW CCPP Unit-2	Gas (NWP/CGCL)	1x150 + 1x75	220	220	161	134	160	190					
133	Sirajganj 225MW CCPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	0	0	0	0			220	Under maint.	
134	Sirajganj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	420	400	400	400					
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	18	22	22					
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10					
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8					
138	Baqura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	35	35	35					
139	Baqura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	30	35	35	35					
140	Sirajganj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	5	0	6	0					
	Adani Power Jharkhand Ltd	Coal				0	0	0	0					
Rajshahi Zone Total				2129	2129	692	816	684	981	381	220			
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	160	160	160	160	160			114	Coal Shortage	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	30	35	34	34					
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
146	Majpara, Talsila 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0					
147	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	115	115	115	115					
148	Malmonhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	30	0	30	0					
	Treeta Solar Limited	Solar (IPP)				164	0	0	0					
Rangpur Zone Total				830	750	504	310	347	309	199	85			
Sub-total: Plants in operation				22204	21826	7776.0	8939	8571	10174	3135	3635			
(B) Plants under long term maintenance/ contract expired														
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
150	Katpotti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0					
151	Bosilia 108MW PPI(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
153	Ammura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired				404	0	0	0	0	0	0	0	0	0	
Gross Total				22608	21826	7776	8939	8571	10174	3135	3635			
(C) Actual data of 09.01.23 (Yesterday) Monday :														
01.	Max. Demand at eve. peak (Generation end)	: 9972 MW, at = 20:00 hrs		12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 9445 MW, at = 20:00 hrs			Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 8939 MW, at = 20:00 hrs			Dhaka	3352	2951	401	Mymensingh	790	689	101		
04.	Minimum Generation (Generation end)	: 6187 MW, at = 4:00 hrs			Chattogram	1018	928	90	Sylhet	359	297	62		
05.	Day-peak Generation (Generation end)	: 7776 MW, at = 12:00 hrs			Khulna	1206	1099	107	Barisal	269	269	0		
06.	Evening-peak Generation (Generation end)	: 8939 MW, at = 20:00 hrs			Rajshahi	977	918	59	Rangpur	637	537	100		
07.	Evening Peak Load-shed (Sub-station end)	: 952 MW, at = 20:00 hrs			Cumilla	836	804	32	Total	9445	8493	952		
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6338 MW, at = 5:00 hrs							(c) Coal =	155273853	Taka			
09.	Generation shortfall at evening peak due to :			13.	Fuel cost :				Total = 723381699 Taka					
	a) Gas/LF limitation	: 2736 MW			(e) Gas = 108895762 Taka									
	d) Coal supply Limitation	: 199 MW			(b) Oil = 459212084 Taka									
	b) Low water level in Kaptai lake	: 200 MW												
	c) Plants under shut down/ maintenance	: 3635 MW		14.	Maximum Temperature in Dhaka was : 28.5° C									
10.	Total Energy (Generation + India Import)	: 181.49 MKWh		15.	Export through East-West interconnections :									
	By Gas = 104.541 MKWh	By Oil = 32.820 MKWh			At evening peak-hour :		: 7776 MW, at 20:00 hrs							
	By Coal = 27.387 MKWh	By Hydro = 0.731 MKWh			Maximum :		: -130 MW, at 8:00 hrs							
	By Solar = 2.085 MKWh				Energy :		: 0 MKWh							
11.	Total Gas Supplied	: 793.63 MMCFD												
(D) Forecast of 10.01.23 (Today) Tuesday :														
01.	Maximum Demand	: 10100 MW (Generation end)		04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 10174 MW (Generation end)		05.	Total Generation : 205.06 MKWh									
03.	Reserve / Shortage	: 74 MW (Generation end)		06.	Probable Max. Temperature in Dhaka : 27° C									

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation