

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023			Day : Thursday					Date : 12.01.23					
Probable Maximum Demand :			10300 MW		Probable Maximum Generation :					10300 MW		Rule Curve = 100.91 ft.	
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 85.60 ft.		Today = 85.52 ft.								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.01.23 (Yesterday)		12.01.23 (Today)		11.01.23 (Yesterday)		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gen. shortfall for :	Status of Machines under shut-down/ Maintenance			
				Day		Evening		Day		Evening			
(A) Plants in operation:													
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1 x 254+1x 126	365	365	200	200	200	200		165	ST under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x3,35	108	108	70	70	70	70		34	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Hariপুর GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired	
7	Hariपुर 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	259	250	250	250		110	Gas Shortage	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450		Gas Shortage	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Hariপুর 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	307	304	300	315		108	Gas Shortage	
11	Siddhirganj 2' 120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage	
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage	
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	157	158	160	160		177	Gas Shortage	
14	Madanganj 55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	25	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	8	8	8	8				
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22				
17	Summit Power,(Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	48	48	46	48				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
20	Gezipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	51	49	50	50				
21	Gezipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	88	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	16	16	16				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	54	17	54				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	65	32	300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	35	35	35				
26	Keraniganj 300 MW PP (AFR)	HSD (IPP)	256x1.4	300	300	14	0	50	0				
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	35	17	35				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	17	19				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	16	8	8	8				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	9	14	9	9				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	17	17	17				
Dhaka Zone Total			6004	5847	1574	1787	1574	2040	1781	658			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	20	20	20				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	20	20	20				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	51				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	155	160	160	160				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x6.04	300	300	52	284	51	284				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	51				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	16	32	25	32				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage	
*	Malancha, Cig,EP2 (United)	Gas	5x8.73+3x9.34			2	8	20	20				
52	Chattogram 108 MW PP (ECVP)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	51	17	51				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25				
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	22	22	22	22				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	51	34	51				
**	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test	
Chattogram Zone Total			2442	2382	473	852	564	864	402	330			
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	0	0	0	0	45		Gas Shortage	
60	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1'175	221	221	185	192	200	200				
61	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0		360	Under maint.	
62	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	290	300	300	300				
63	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	338	338	340	340				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0				
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'116	195	195	0	0	0	0	195		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6	144		Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	27	37	31	37				
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	0	0				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	10	10	10	10				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	21	21	21				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	21	21	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+8x11.515+15x1.098	200	200	130	110	30	0				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	0	0				
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	9	9	9				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	96	50	96				
**	Impqort (Tripura)	India		160	160	98	108	135	153				
Cumilla Zone Total			3309	3285	1243	1345	1250	1290	573	523			
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	51	102	55	100		100	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	22	22				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	47	28	47				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	48	48	48				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutakhati 50 MW Solar PP	Solar (IPP)	1x50	50	50	44	0	50	0				
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	12	12	12	12				
Mymensingh Zone Total			622	614	204	228	217	229	100	0			

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11.01.23 (Yesterday)		12.01.23 (Today)		11.01.23 (Yesterday)	Gen. shortfall for :	Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)	Evening	Probable Peak Generation (MW)	Evening			
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0	70	G1-1 Under maint.
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	43	43	43	47	G1-4 Under maint.
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	51	8	51	51		
91	Kushiana 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163	Under maint.
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	3	5	11	11		
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	62	62		
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	78	86	81	86		
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	202	200	200	200		
97	Sylhet 20 MW GTPP	Gas (PDB)	1x20	20	20	18	19	19	19		
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10		
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	12	8	8	8		
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	295	300	300		
101	Bibiyana-II 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	0	266	100	270		
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400		
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work.
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.5+*2	50	50	48	5	44	44		
Sylhet Zone Total			2472	2427	1182	1406	1329	1504	0	710	
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0		
106	Bheramara 410 MW CCPP	Gas (NWP/CL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Under maint.
107	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	27	0	30		
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	73	0	75		
109	Khulna 225 MW CCPP	HSD (NWP/CL)	1 x 150+1x75	230	230	0	0	0	0		
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	10	26	90	90		
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	18	17	18		
112	Madhumati 100 MW PP	HFO (NWP/CL)	6x18.415	105	105	0	0	0	0		
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	73	0	100	0		
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	98	16	98		
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	40	0	40		
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIF/CL)	1x617	617	617	556	539	540	540		
116	Khulna 330 MW CCPP	Gas/HSD (B/PDB)				0	0	0	0		
**	Bheramara (H/DC)	India		1000	1000	911	910	928	928		
Khulna Zone Total			3005	3001	1566	1731	1691	1819	0	410	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	15	16	94	Line Overload
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	24	19	25		
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	135	133	135	135		
120	Payra 1320 MW TPP	Coal (BCP/CL)	2x622	1244	1244	480	622	622	622		
121	Potukhalhi 150MW PP (UPLL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	17	150	Line Overload
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	151	150	200		
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	221	220	220	220		
Barisal Zone Total			2265	2265	1005	1166	1161	1235	0	244	
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	34		
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0		
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	16	0	20		
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	92	0	92		
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	8	40	0	40		
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	42	34	42		
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	29	0	30		
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWP/CL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWP/CL)	1x150 +1x75	220	220	190	132	160	150		
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWP/CL)	1x141+1x79	220	220	0	0	0	0	220	Under maint.
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	417	359	400	400		
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	22	22	22		
137	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	8	10	11		
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	8	8	8		
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	35	35	35		
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	1	35	35	35		
141	Sirajgonj 6.55 MW Solar	Solar (NWP/CL)	1x6	6	6	4	0	6	0		
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0		
Rajshahi Zone Total			2129	2129	697	852	710	919	381	220	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250	24	Coal Shortage
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	35	34	35		
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0		
147	Majpara, Tatulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0		
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	110	115	115	115		
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	22	0	30	0		
	Teesa Solar Limited	Solar (IPP)				139	0	0	0		
Rangpur Zone Total			830	750	599	400	437	400	109	85	
Sub-total: Plants in operation			23078	22700	8503.0	9767	8933	10300	3346	3180	
(B) Plants under long term maintenance/ contract expired											
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0		
151	Kapcotibi 32 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0		
152	Bosilia 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0		
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0		
154	Ammura 30 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0		Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired			404	0	0	0	0	0	0	0	
Gross Total			23482	22700	8503	9767	8933	10300	3346	3180	

(C) Actual data of 11.01.23 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	9767 MW, at =	20:00 hrs									
02.	Max. Demand at eve. peak (Sub-station end)	9374 MW, at =	20:00 hrs									
03.	Highest Generation (Generation end)	9767 MW, at =	20:00 hrs									
04.	Minimum Generation (Generation end)	6489 MW, at =	5:00 hrs									
05.	Day-peak Generation (Generation end)	8503 MW, at =	12:00 hrs									
06.	Evening-peak Generation (Generation end)	9767 MW, at =	20:00 hrs									
07.	Evening Peak Load-shed (Sub-station end)	0 MW, at =	20:00 hrs									
08.	Minimum Generation Forecast up to 8:00 hrs.	6318 MW, at =	5:00 hrs									
09.	Generation shortfall at evening peak due to :											
	a) Gas/LF limitation	3037 MW										
	d) Coal supply Limitation	109 MW										
	b) Low water level in Kaptai lake	200 MW										
	c) Plants under shut down/ maintenance	3180 MW										
10.	Total Energy (Generation + India Import)	196.71 MKWh										
	By Gas =	107.183 MKWh	By Oil =	29.028 MKWh								
	By Coal =	35.726 MKWh	By Hydro =	0.722 MKWh								
	By Solar =	1.887 MKWh										
11.	Total Gas Supplied	839.22 MMCFD										
				12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
				Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW	
				Dhaka	3338	3338	0	Mymensingh	844	844	0	
				Chattogram	912	912	0	Sylhet	353	353	0	
				Khulna	1160	1160	0	Barishal	268	268	0	
				Rajshahi	1003	1003	0	Rangpur	652	652	0	
				Cumilla	843	843	0					
								Total	9374	9374	0	
								13. Fuel cost : (a) Gas = 109875204 Taka (c) Coal = 156404407 Taka				
								(b) Oil = 404943731 Taka Total = 671223342 Taka				
								14. Maximum Temperature in Dhaka was : 26° C				
				15. Export through East-West interconnections :								
				At evening peak-hour				8503 MW, at	20:00 hrs			
				Maximum				240 MW, at	7:00 hrs			
				Energy				0.099 MKWh				
				16. Forecast of 12.01.23 (Today) Thursday :								
01.	Maximum Demand	10300 MW (Generation end)										
02.	Maximum Generation	10300 MW (Generation end)										
03.	Reserve / Shortage	0 MW (Generation end)										
04.	Maximum Load-shed	0 MW At evening peak (Sub-station end)										
05.	Total Generation	207.44 MKWh										
06.	Probable Max. Temperature in Dhaka	25.4° C										

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00 (Md. Helalur Rahman) Deputy Secretary, Generation