

Bangladesh Power Development Board  
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation  
Tel : 9564667, 9551095

Month January, 2023		Day : Sunday			Date : 22.01.23										
Probable Maximum Demand :		10000 MW			Probable Maximum Generation : 9675 MW										
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 84.71 ft			Today = 84.61 ft										
					Rule Curve = 99.00 ft.										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.01.23 (Yesterday)		22.01.23 (Today)		21.01.23 (Yesterday)	Gen. shortfall for : Gas/Coal/Water Limitation	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)								Gen. shortfall for : MW
				Day		Evening		Day		Evening					
<b>(A) Plants in operation:</b>															
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work.			
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	160	180	170	170						
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190		Gas Shortage			
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		under maint.			
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	74	74	72	72	34		Gas Shortage			
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage			
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			Contract Expired			
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	319	207	270	270						
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0		450	Under Maint.			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling			
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	388	361	360	360						
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage			
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	217	118	Gas Shortage			
13	Meghnaghat CAPP(Summit)	GAS (IPP)	2x110+1x110	335	335	150	150	150	150	185		Gas Shortage			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15						
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.524	102	102	8	8	8	8						
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22						
17	Summit Power, Madhabdi-Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	51	49	49						
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33						
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	30	30	30						
20	Gezipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	8	16						
21	Gezipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	88	34	88						
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	64	16	64						
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35						
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	113	32	64						
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	62	90	36	36						
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0						
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0						
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0						
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	17	17						
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55						
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	0	17						
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	17	17						
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	26	0	30	0						
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17						
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	8	8	8						
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	9	9	8	8						
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	34	34	34						
<b>Dhaka Zone Total</b>			<b>6004</b>	<b>5847</b>	<b>1539</b>	<b>1694</b>	<b>1471</b>	<b>1655</b>	<b>941</b>	<b>1308</b>					
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200		Low water			
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.			
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0						
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17						
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	20						
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	19	27	27						
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	68	34	68						
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.			
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	76	227	225	225		75	ST Under maint.			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	106	284	100	300						
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	25	25	25	25						
49	Dohazari-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	85	68	85						
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	32	16	32						
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22		Gas Shortage			
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			5	4	5	10						
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0						
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17						
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	51	87	51	51						
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	25	25	25	25						
56	Juldah 100 MW Unit-1 (Acorn)	HFO (ORPP)	8x13.45	100	100	22	22	22	22						
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	34	68	35	68						
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			20	0	0	0			on test			
<b>Chattogram Zone Total</b>			<b>2442</b>	<b>2382</b>	<b>509</b>	<b>1010</b>	<b>713</b>	<b>1002</b>	<b>402</b>	<b>405</b>					
58	Ashuganj TPP Unit-5	Gas (AFSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage			
59	Ashuganj 50 MW PP	Gas (AFSCL)	14x3.968	53	45	5	5	5	5						
60	Ashuganj 225 MW CAPP	Gas (AFSCL)	1x142+17x5	221	221	201	222	180	220						
61	Ashuganj 450 MW CAPP(South)	Gas (AFSCL)	1x360	360	360	0	0	0	0		360	Under maint.			
62	Ashuganj 450 MW CAPP(North)	Gas (AFSCL)	1x361	360	360	310	345	330	330						
63	Ashuganj 420 MW CAPP(East)	Gas (AFSCL)	1x284+1x116	400	400	277	327	320	320						
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5						
65	Ashuganj 195MW PP (AFSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8						
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51						
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6	144		Gas Shortage			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	23	36	35	35						
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under maint.			
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	17	17						
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	21	21	21						
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	23	16	17	17						
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8						
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15						
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+8x1.515+15x1.09	200	200	0	0	0	0						
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	0	0						
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	0	109	0	109						
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17						
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	52	94	54	94						
**	Impoort (Tripura)	India		160	160	104	114	135	152						
<b>Cumilla Zone Total</b>			<b>3309</b>	<b>3285</b>	<b>1123</b>	<b>1407</b>	<b>1224</b>	<b>1438</b>	<b>278</b>	<b>523</b>					
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	35	81	50	80	121		Gas Shortage			
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	17	19	19						
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	75	28	47						
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	49	87	48	48						
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0						
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	38	0	50	0						
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	6	6	6						
<b>Mymensingh Zone Total</b>			<b>622</b>	<b>614</b>	<b>152</b>	<b>266</b>	<b>203</b>	<b>200</b>	<b>121</b>	<b>0</b>					

Sl. No.	Name of Power Station		Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.01.23 (Yesterday)		22.01.23 (Today)		21.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance				
						Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date			
						Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)					
88	Fenchugonj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30		40	G1-Under maint.				
89	Fenchugonj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	G1-Under maint.				
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	1x52	51	51	53	53	50	50							
91	Kushiana 183 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	0	0	0	0	0			163	Under maint.			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8							
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	62	62							
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.			
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	86	50	81							
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	0	0	0	0							
97	Sylhet 20 MW GTPP	Gas (PDB)	1x20	20	20	19	19	19	19							
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.55	10	10	10	10	10	10							
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16							
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	310	290	300	300							
101	Bibiana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	393	415	400	400							
102	Bibiana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400							
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work			
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12x3.3+5x2	50	50	47	50	44	44							
<b>Sylhet Zone Total</b>						<b>2472</b>	<b>2427</b>	<b>1470</b>	<b>1481</b>	<b>1432</b>	<b>1463</b>	<b>0</b>	<b>680</b>			
105	Bheramara GTTP Unit- 3	HSD (PDB)	1x20	20	16	0	0	0	0							
106	Bheramara 410 MW CCPP	Gas (NWPGCL)	1x278+1x132	410	410	0	0	0	0			410	Gas Shortage			
107	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	45	0	45							
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	74	0	73							
109	Khulna 225 MW CCPP	HSD (NWPGCL)	1x150+1x75	230	230	0	0	0	0							
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0							
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	18	0	18							
112	Madhumati 100 MW PP	HFO (NWPGCL)	6x18.415	105	105	0	0	0	0							
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	77	0	100	0							
114	Khulna 115 MW PP (KPCCL-2)	HFO (NENP)	7x17	115	115	32	49	16	49							
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	8	0	8							
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0			617	Coal Shortage			
	Khulna 330 MW CCPP	Gas+HSD (BPDB)				200	0	0	0							
**	Bheramara (HVDC)	India		1000	1000	912	795	924	924							
<b>Khulna Zone Total</b>						<b>3005</b>	<b>3001</b>	<b>1221</b>	<b>989</b>	<b>1040</b>	<b>1122</b>	<b>1027</b>	<b>0</b>			
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	32	32	32	32							
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	25	19	25							
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	115	185	185	185							
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	710	830	850	850							
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	150	35	150							
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0			307	Coal Shortage			
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas+HSD (IPP)	2x75+1x70	220	220	180	220	220	220							
<b>Barishal Zone Total</b>						<b>2265</b>	<b>2265</b>	<b>1092</b>	<b>1442</b>	<b>1341</b>	<b>1462</b>	<b>307</b>	<b>0</b>			
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1x71	71	71	0	0	0	0			71	Gas Shortage			
	b) Baghabari 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Gas Shortage			
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	26	0	34							
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0							
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	28	0	28							
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	42	90	10	92							
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	16	40	0	40							
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	42	34	42							
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	0	35							
132	Sirajgonj 225MW CCPP Unit-1	Gas (NWPGCL)	1x150+1x75	210	210	0	0	0	0			210	Gas Shortage			
133	Sirajgonj 225MW CCPP Unit-2	Gas (NWPGCL)	1x150+1x75	220	220	143	165	0	0			55	Gas Shortage			
134	Sirajgonj 225MW CCPP Unit-3	Gas (NWPGCL)	1x141+1x79	220	220	0	0	0	0			220	Gas Shortage			
135	Sirajgonj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	349	392	400	400							
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	21	21							
137	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8							
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8							
139	Baqura 113 MW (Confidence) U-1	HFO (IPP)	6x18.55	113	113	35	55	35	55							
140	Baqura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	10	50	35	50							
141	Sirajgonj 6.55 MW Solar	Solar (NWPGCL)	1x6	6	6	4	0	6	0							
	Adani Power Jharbandha Ltd	Coal		0	0	0	0	0	0							
<b>Rajshahi Zone Total</b>						<b>2129</b>	<b>2129</b>	<b>634</b>	<b>960</b>	<b>557</b>	<b>813</b>	<b>656</b>	<b>0</b>			
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1x125	125	85	85	85	85	85			0	Coal Shortage			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1x125	125	85	0	0	0	0			85	Under Overhauling			
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1x274	274	274	249	250	250	250			24	Coal Shortage			
144	Rangpur 20 MW GTTP	HSD (PDB)	1x20	20	20	0	0	0	0							
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x2'3	113	113	34	69	35	70							
146	Saidpur 20 MW GTTP	HSD (PDB)	1x20	20	20	0	0	0	0							
147	Majpara Tutulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1x8	8	8	5	0	8	0							
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6x20	115	115	114	115	115	115							
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1x30	30	30	25	0	30	0							
	Teesta Solar Limited	Solar (IPP)				133	0	130	0							
<b>Rangpur Zone Total</b>						<b>830</b>	<b>750</b>	<b>645</b>	<b>519</b>	<b>653</b>	<b>520</b>	<b>24</b>	<b>85</b>			
<b>Sub-total: Plants in operation</b>						<b>23078</b>	<b>22700</b>	<b>8385.0</b>	<b>9768</b>	<b>8634</b>	<b>9675</b>	<b>3756</b>	<b>3001</b>			
<b>(B) Plants under long term maintenance/ contract expired</b>																
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0							
151	Kapzathi 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0							
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775-1x3.5	118	0	0	0	0	0							
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0							
154	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.90	50	0	0	0	0	0				Contract Expired on 11/01/2022			
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>						<b>404</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>			
<b>Gross Total</b>						<b>23482</b>	<b>22700</b>	<b>8385</b>	<b>9768</b>	<b>8634</b>	<b>9675</b>	<b>3756</b>	<b>3001</b>			
<b>(C) Actual data of 21.01.23 (Yesterday) Saturday :</b>																
01.	Max. Demand at eve. peak (Generation end) : 9801 MW, at = 20:00 hrs				12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :											
02.	Max. Demand at eve. peak (Sub-station end) : 9418 MW, at = 20:00 hrs				Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
03.	Highest Generation (Generation end) : 9768 MW, at = 20:00 hrs				Dhaka	332	323	0	Mymensingh	929	859	30				
04.	Minimum Generation (Generation end) : 6207 MW, at = 5:00 hrs				Chattogram	971	971	0	Sylhet	359	359	0				
05.	Day-peak Generation (Generation end) : 8385 MW, at = 12:00 hrs				Khulna	1125	1125	0	Barishal	276	276	0				
06.	Evening-peak Generation (Generation end) : 9768 MW, at = 20:00 hrs				Rajshahi	1007	1007	0	Rangpur	691	691	0				
07.	Evening Peak Load-shed (Sub-station end) : 30 MW, at = 20:00 hrs				Cumilla	828	828	0								
08.	Minimum Generation Forecast up to 8:00 hrs. : 6595 MW, at = 5:00 hrs				<b>Total</b>									<b>9418</b>	<b>9388</b>	<b>30</b>
09.	Generation shortfall at evening peak due to :				13.	Fuel cost : (a) Gas = 118107423 Taka (b) Oil = 397901112 Taka				(c) Coal = 213699419 Taka	Total = 729707954 Taka					
	a) Gas/LF limitation : 3532 MW				14.	Maximum Temperature in Dhaka was : 26.1° C										
	b) Coal supply Limitation : 24 MW				15.	Export through East-West interconnections :										
	c) Low water level in Kaptai lake : 200 MW					At evening peak-hour : 8385 MW, at 20:00 hrs										
	d) Plants under shut down/ maintenance : 3001 MW					Maximum : 540 MW, at 7:00 hrs										
	e) Total Energy (Generation + India Import) : 194.02 MKWh					Energy : 0 MKWh										
	By Gas = 111.938 MKWh															
	By Coal = 26.926 MKWh															
	By Solar = 1.993 MKWh															
	By Oil = 31.072 MKWh															
	By Hydro = 0.729 MKWh															
11.	Total Gas Supplied : 843.40 MMCFD															
<b>(D) Forecast of 22.01.23 (Today) Sunday :</b>																
01.	Maximum Demand : 10000 MW (Generation end)				04.	Maximum Load-shed : 300 MW At evening peak (Sub-station end)										
02.	Maximum Generation : 9675 MW (Generation end)															