

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month January, 2023			Day : Saturday				Date : 28.01.23				
Probable Maximum Demand :			10000 MW				Probable Maximum Generation : 10184 MW				
Water Level of Kaptai Lake at 06:00 AM			Yesterday = 84.03 ft		Today = 83.91 ft		Rule Curve = 97.80 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.01.23 (Yesterday)		28.01.23 (Today)		27.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work.
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	140	210	150	0		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	110	110	190	Gas Shortage
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	73	75	32	75	33	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		Contract Expired
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	208	260	340	200		
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Under Maint.
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	301	290	0	250		
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	100	0	210	Gas Shortage
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under Maint.
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	152	150	150	150	185	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	15	15		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	67	50	48	48		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	19	19	19		
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	44	50	51	51		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	0	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	30	30	30		
20	Gezipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	8	17		
21	Gezipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	52	34	52		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	32	16	48		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	35	17	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	67	80	32	100		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	36	17	34		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0		
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
29	Nababaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	17	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	0	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	56	72	53	53		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	17	17		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	30	54	50	50		
36	Meghnaghat 100 MW(IEEL)	HFO (NENP)	12x8.9	100	100	8	8	50	50		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	51	51	51		
Dhaka Zone Total			6004	5847	1453	1724	1487	1615	723	1525	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17		
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	0	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	33	26	30	30		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	18	51	34	85		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	154	151	150	150		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	104	282	105	284		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25		
49	Dohazani-Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	16	51	51		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	0	32	32		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			32	36	15	20		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	51	54	92		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	10	25	25		
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	22	22	22	22		
57	Chattogram 116 MW PP (Anlma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	87	51	115	115		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test
Chattogram Zone Total			2442	2382	696	785	738	995	402	330	
58	Ashuganj TPP Unit-5	Gas (AFSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (AFSCL)	14x3.968	53	45	38	38	35	35		
60	Ashuganj 225 MW CAPP	Gas (AFSCL)	1x142+17x5	221	221	202	182	180	180		
61	Ashuganj 450 MW CAPP(South)	Gas (AFSCL)	1x360	360	360	0	0	0	0	360	Under maint.
62	Ashuganj 450 MW CAPP(North)	Gas (AFSCL)	1x361	360	360	335	290	280	280		
63	Ashuganj 420 MW CAPP(East)	Gas (AFSCL)	1x284+1x116	400	400	347	367	300	300		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	10	5	5	45	Gas Shortage
65	Ashuganj 195MW PP (AFSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	8	0	0	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6	144	Gas Shortage
68	Tilas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	19	0	25	28		
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under maint.
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	34	34	34		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	21	21		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	7	8	8		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	16	30	21	21		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	20	20		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+6x1.515+1x1.091	200	200	0	0	50	0		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	17		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	57	9	113		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	35	94	35	94		
**	Impoort (Tripura)	India		160	160	122	112	135	152		
Cumilla Zone Total			3309	3285	1264	1370	1249	1390	510	523	
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	48	83	50	70	119	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	16	18	18		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	28	48	28	47		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	48	48	48	48		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0		
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6		
Mymensingh Zone Total			622	614	150	201	202	189	119	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	27.01.23 (Yesterday)		28.01.23 (Today)		27.01.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)			
88	Fenchugonj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30	40	GT-1 Under maint.		
89	Fenchugonj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43	47	GT-4 Under maint.		
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	31	14	14				
91	Kushiana 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0	163	Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	0	0	0				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	30	30	30				
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
95	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	30	84	10	84				
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	135	140	140	140				
97	Sylhet 20 MW GTPP	Gas (PDB)	1x20	20	20	18	18	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0				
100	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	300	300	300				
101	Bibiyana-II 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	398	366	366	366				
102	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work		
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	10	30	10	10				
Sylhet Zone Total					2472	2427	1410	1482	1372	1446	0	680	
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage		
107	Fairidpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	45	0	45				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	80				
109	Khulna 225 MW CCGP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	10	0	18				
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	15	105				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	74	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	16	0	16				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	0	8				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIF/CL)	1x617	617	617	0	0	0	0	617	Coal Shortage		
	Khulna 330 MW CCGP	Gas/HSD (BPDB)				120	120	0	0				
**	Bheramara (HVDC)	India		1000	1000	902	766	923	926				
Khulna Zone Total					3005	3001	1096	965	1038	1198	1027	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	16				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	24	19	22				
119	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	160	160	174	174				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	870	1062	1200	1244				
121	Potukhali 150MW PP (UPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	150				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage		
123	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	163	168	220	220				
Barishal Zone Total					2265	2265	1213	1431	1646	1626	307	0	
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	34				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	17				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	26	0	95				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	16	40				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	0	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	0	34				
132	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
133	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage		
134	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	223	204	170	190				
135	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	305	417	400	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	21	21				
137	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	5	8	8				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	70				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	45	50	50	50				
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0				
Rajshahi Zone Total					2129	2129	722	874	756	1009	601	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	79	81	81	81	4		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250	24	Coal Shortage		
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	78	42	70				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	35	115	35	115				
149	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	24	0	30	0				
	Teesta Solar Limited	Solar (IPP)				111	0	130	0				
Rangpur Zone Total					830	750	504	524	576	516	28	85	
Sub-total: Plants in operation					23078	22700	8508.0	9356	9064	10184	3717	3143	
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Kapoti 32 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	118	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.9	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0	0	0	
Gross Total					23482	22700	8508	9356	9064	10184	3717	3143	

(C) Actual data of 27.01.23 (Yesterday) Friday :												
01.	Max. Demand at eve. peak (Generation end)	: 9405 MW, at = 19:30 hrs										
02.	Max. Demand at eve. peak (Sub-station end)	: 9007 MW, at = 19:30 hrs										
03.	Highest Generation (Generation end)	: 9356 MW, at = 19:30 hrs										
04.	Minimum Generation (Generation end)	: 7006 MW, at = 5:00 hrs										
05.	Day-peak Generation (Generation end)	: 8508 MW, at = 12:00 hrs										
06.	Evening-peak Generation (Generation end)	: 9356 MW, at = 19:30 hrs										
07.	Evening Peak Load-shed (Sub-station end)	: 45 MW, at = 19:30 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6711 MW, at = 5:00 hrs										
09.	Generation shortfall at evening peak due to :											
	a) Gas/LF limitation	: 3489 MW										
	b) Coal supply Limitation	: 28 MW										
	c) Low water level in Kaptai lake	: 200 MW										
	d) Plants under shut down/ maintenance	: 3143 MW										
10.	Total Energy (Generation + India Import)	: 199.12 MCKWh										
	By Gas =	111.477 MCKWh	By Oil =	29.700 MCKWh								
	By Coal =	33.498 MCKWh	By Hydro =	0.721 MCKWh								
	By Solar =	1.518 MCKWh										
11.	Total Gas Supplied	: 837.81 MMCFD										
			12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
			Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
			Dhaka	3097	3097	0	Mymensingh	881	836	45		
			Chattogram	874	874	0	Sylhet	325	325	0		
			Khulna	1075	1075	0	Barishal	265	265	0		
			Rajshahi	971	971	0	Rangpur	682	682	0		
			Cumilla	837	837	0						
							Total	9007	8962	45		
			13.	Fuel cost :	(a) Gas = 114570944 Taka	(c) Coal = 273302122 Taka						
					(b) Oil = 356171373 Taka	Total = 744044440 Taka						
			14.	Maximum Temperature in Dhaka was :	28.6° C							
			15.	Export through East-West interconnections :								
				At evening peak-hour	: 8508 MW, at 19:30 hrs							
				Maximum	: 770 MW, at 17:00 hrs							
				Energy	: 0 MCKWh							
			(D) Forecast of 28.01.23 (Today) Saturday :									
01.	Maximum Demand	: 10000 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 10184 MW (Generation end)	05.	Total Generation	: 212.82 MCKWh							
03.	Reserve / Shortage	: 184 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	29.9° C							

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation