

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2023			Day : Thursday				Date : 02.02.23					
Probable Maximum Demand : 10500 MW			Yesterday = 83.59 ft			Today = 83.51 ft			Rule Curve = 96.86 ft.			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.02.23 (Yesterday)		02.02.23 (Today)		01.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation MW			
					Day	Evening	Day	Evening	Machines shut down (MW)			
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work.	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	120	180	180	180			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	76	75	75	75	32	Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	246	205	230	210	155	Gas Shortage	
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Under Maint.	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	353	370	370	370			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under Maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	152	150	150	150	185	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	25	15	25			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	50	48	48			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	19	19			
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	47	47	51	51			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x3.73	33	33	23	22	25	25			
20	Gezipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	8	16	8	16			
21	Gezipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	40	52	35	52			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	48	32	48			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	0	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	35	148	32	145			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	17	17	17	17			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	17	17	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	35	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	55	55	55			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	17	17	17			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	31	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
35	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	50	50	50			
36	Meghnaghat 100 MW (IEL)	HFO (NENP)	12x8.9	100	100	46	51	50	50			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	17	17	17			
Dhaka Zone Total					6004	5847	1513	1754	1608	1797	877	1525
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	32	32	33			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	51	34	85			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	148	151	155	155	74	ST Under maint.	
47	Anwara 300 MW PP (United)	Gas (IPP)	17x17.076+3x8.04	300	300	105	276	100	285			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	83	68	68			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	39	29	24	32			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage	
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	2	5	5			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	92	55	92			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	22	22	22	22			
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	97	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			18	0	0	0		on test	
Chattogram Zone Total					2442	2382	668	959	732	998	402	404
58	Ashuganj TPP Unit-5	Gas (AFSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (AFSCL)	14x3.968	53	45	41	41	42	42			
60	Ashuganj 225 MW CCPP	Gas (AFSCL)	1x142+17x5	221	221	95	131	100	110			
61	Ashuganj 450 MW CCPP(South)	Gas (AFSCL)	1x360	360	360	0	0	0	0	360	Under maint.	
62	Ashuganj 450 MW CCPP(North)	Gas (AFSCL)	1x361	360	360	285	285	280	300			
63	Ashuganj 420 MW CCPP(East)	Gas (AFSCL)	1x284+1x116	400	400	272	327	320	320			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	30	10	10	10	45	Gas Shortage	
65	Ashuganj 195MW PP (AFSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	15	30	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6	144	Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	20	22	25	25			
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	15	19	19			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	5	5	5			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	21	23	23			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	3	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	18	20	20			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	8x14+8x1.915+15x1.09	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	17			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	118	9	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	94	17	94			
**	Impoort (Tripura)	India		160	160	126	118	135	152			
Cumilla Zone Total					3309	3285	1016	1325	1138	1366	510	523
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	34	53	45	100	149	Gas Shortage	
82	Tangali 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	13	22	22			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	49	47	47			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	28	46	28	47			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0			
87	Tangali 22 MW PP (PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymensingh Zone Total					622	614	178	167	200	222	149	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	01.02.23 (Yesterday)		02.02.23 (Today)		01.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)			
88	Fenchugoni CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30	40	GT-1 & ST-1 Under maint.		
89	Fenchugoni CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43	47	GT-4 Under maint.		
90	Fenchugoni 51 MW PP (Barakattullah)	Gas (RPP)	1x29.50	51	51	0	0	10	10				
91	Kusharia 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	110	110	51	ST Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	64	65	65	65				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
95	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	3x22.90	86	86	10	84	10	84				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	210	210	218	218				
97	Sylhet 20 MW GTPP	Gas (PDB)	1x20	20	20	18	18	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.55	10	10	10	10	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0				
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	290	320	310				
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	407	407	400	400				
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work		
104	Fenchugoni 44MW (Energyprima)	Gas (NENP)	12'3.3+5'2	50	50	0	5	10	10				
Sylhet Zone Total			2472	2427	1632	1682	1653	1717	0	568			
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage		
107	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	80				
109	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	63	17	54				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	15	85	85	85				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	33	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	49	0	49				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	8	0	8				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0	617	Coal Shortage		
	Khulna 330 MW CAPP	Gas/HSD (BFDL)				120	120	120	120				
**	Bheramara (HVDC)	India	1000	1000	902	761	919	919					
Khulna Zone Total			3005	3001	1087	1086	1241	1360	1027	0			
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	16	16				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	20	24	19	25				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	182	169	180	180				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1162	1220	1200	1244				
121	Potuahalli 150MW PP (LPLL)	HFO (IPP)	8x18.415+1x9.78	150	150	54	150	55	150				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage		
123	Bhola 220MW CAPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	175	221	220	220				
Barisal Zone Total			2265	2265	1593	1816	1690	1635	307	0			
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	25	0	34				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	26	0	25				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	42	97	0	95				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	34	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	15	36	0	35				
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0	220	Gas Shortage		
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	220	220	200	200				
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	436	442	400	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	22	22	22				
137	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	113	35	95				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	50	50	50				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0				
Rajshahi Zone Total			2129	2129	873	1081	771	1014	601	0			
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	79	80	80	6	Coal Shortage		
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling		
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250	24	Coal Shortage		
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	39	52	35	70				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6'20	115	115	36	91	115	115				
149	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	27	0	30	0				
	Teesta Solar Limited	Solar (IPP)				142	0	130	0				
Rangpur Zone Total			830	750	579	472	648	515	30	85			
Sub-total: Plants in operation			23078	22700	9139.0	10342	9681	10824	3903	3105			
(B) Plants under long term maintenance/ contract expired													
150	Jamalgur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Kapoti 32 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775+1x3.5	118	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Ammura 50 MW PP(Sinha)	HFO (QRPP)	7x7.9	50	0	0	0	0	0		Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired			404	0	0	0	0	0	0				
Gross Total			23482	22700	9139	10342	9681	10824	3903	3105			
(C) Actual data of 01.02.23 (Yesterday) Wednesday :													
01.	Max. Demand at eve. peak (Generation end)	:	10581 MW,	at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end):							
02.	Max. Demand at eve. peak (Sub-station end)	:	10072 MW,	at =	19:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	10342 MW,	at =	19:00 hrs	Dhaka	3619	3563	56	Mymensingh	924	774	150
04.	Minimum Generation (Generation end)	:	7246 MW,	at =	5:00 hrs	Chattogram	1065	1065	0	Sylhet	358	344	14
05.	Day-peak Generation (Generation end)	:	9139 MW,	at =	12:00 hrs	Khulna	1150	1150	0	Barishal	275	275	0
06.	Evening-peak Generation (Generation end)	:	10342 MW,	at =	19:00 hrs	Rajshahi	1065	1065	0	Rangpur	761	761	0
07.	Evening Peak Load-shed (Sub-station end)	:	220 MW,	at =	19:00 hrs	Cumilla	855	855	0	Total			
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6972 MW,	at =	5:00 hrs	Total		10072	9852	220			
09.	Generation shortfall at evening peak due to :	:			13. Fuel cost :								
a)	Gas/LF limitation	:	3673	MW	a) Gas = 118519203		Taka			c) Coal = 308835938			Taka
b)	Coal supply Limitation	:	30	MW	b) Oil = 403386276		Taka			Total = 830741417			Taka
c)	Low water level in Kaptai lake	:	200	MW									
d)	Plants under shut down/ maintenance	:	3105	MW									
10.	Total Energy (Generation + India Import)	:	213.40	MkWh	14. Maximum Temperature in Dhaka was : 25.7° C								
		By Gas = 115.817	MkWh	By Oil = 34.007	MkWh	15. Export through East-West interconnections :							
		By Coal = 37.461	MkWh	By Hydro = 0.704	MkWh	At evening peak-hour : 9139 MW, at 19:00 hrs							
		By Solar = 1.779	MkWh			Maximum : 880 MW, at 7:00 hrs							
						Energy : 0 MkWh							
11.	Total Gas Supplied	:	884.40	MMCFD									
(D) Forecast of 02.02.23 (Today) Thursday :													
01.	Maximum Demand	:	10500	MW	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)								
02.	Maximum Generation	:	10824	MW	05. Total Generation : 216.66				MKWh				
03.	Reserve / Shortage	:	324	MW	06. Probable Max. Temperature in Dhaka : 26.9° C								
*Active Power ** Imported Power													
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00													
(Md. Helalur Rahman)													
Deputy Secretary, Generation													