

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2023		Day : Sunday				Date : 05.02.23					
Probable Maximum Demand :		10700 MW		Probable Maximum Generation :				10945 MW			
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 83.32 ft		Today = 83.13 ft		Rule Curve = 96.44 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.02.23 (Yesterday)		05.02.23 (Today)		04.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Water Limitation		
					Day	Evening	Day	Evening	MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	130	150	200	200		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	76	77	75	77	31	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	236	240	240	240	120	Gas Shortage
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	0	0	450	Under Maint.
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	360	304	300	300		
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under Maint.
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	150	150	150	150	185	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	15	15	15		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	50	48	50		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19		
17	Summit Power, (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	47	45	47	47		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	24	22	22	22		
20	Gezipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	16	8	16		
21	Gezipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	35	52	35	52		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	48	32	48		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	17		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	30	147	32	150		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	52	53	50	53		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	0	0		
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	17	17	17	17		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	10	55	0	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	48	56	55	56		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	17	17	17		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17		
35	Siddhirganj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	50	50	50		
36	Meghnaghat 100 MW (IEL)	HFO (NENP)	12x8.9	100	100	50	50	50	50		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	17	17	17	17		
Dhaka Zone Total											
			6004	5847	1595	1735	1559	1768	841	1525	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)		7	7	4	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	33	32	32	32		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	68	34	68		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	154	152	160	160	73	ST Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	104	300	100	300		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	68	0	68		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	30	30	30	30		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage
*	Malancha, Cig EPZ (United)	Gas	5x8.73+3x9.34			9	2	5	15		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
53	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	72	55	72		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25		
56	Juldah 100 MW Unit-1 (Acom)	HFO (ORPP)	8x13.45	100	100	22	22	22	22		
57	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	103	100	105		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			18	0	0	0		on test
Chattogram Zone Total											
			2442	2382	677	963	668	986	402	403	
58	Ashuganj TPP Unit-5	Gas (AFSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (AFSCL)	14x3.968	53	45	38	42	42	42		
60	Ashuganj 225 MW CCGP	Gas (AFSCL)	1x142+17x5	221	221	209	191	190	191		
61	Ashuganj 450 MW CCGP(South)	Gas (AFSCL)	1x360	360	360	0	0	0	0	360	Under maint.
62	Ashuganj 450 MW CCGP(North)	Gas (AFSCL)	1x361	360	360	320	290	300	300		
63	Ashuganj 420 MW CCGP(East)	Gas (AFSCL)	1x284+1x116	400	400	331	327	350	350		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	0	0		
65	Ashuganj 195MW PP (AFSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	43	43	43		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	6	6	6	6	144	Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0	52	Under overhauling
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	19	19	
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	14	20	20	20	20	
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	20	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+86x1.515+15x1.091	200	200	0	0	0	0		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	17	17	17		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	112	9	113		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	74	17	74		
**	Impoort (Tripura)	India		160	160	104	120	135	152		
Cumilla Zone Total											
			3309	3285	1207	1343	1243	1423	465	575	
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	44	50	50	100	152	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	21	22	22		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	48	47	48		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	28	46	28	46		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahkhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	39	0	50	0		
87	Tangail 22 MW PP (PPGL)	HFO (IPP)	4x6.7	22	22	5	6	6	6		
Mymensingh Zone Total											
			622	614	188	171	205	222	152	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	04.02.23 (Yesterday)		05.02.23 (Today)		04.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)			
88	Fenchugoni CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30	40	GT-1 & ST-1 Under maint.		
89	Fenchugoni CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43	47	GT-4 Under maint.		
90	Fenchugoni 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	11	11	11				
91	Kushiana 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	110	112	51	ST Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	60	65	65				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.		
95	Shahjibazar 66MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	87	87	50	86				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	218	217	218	218				
97	Sylhet 20 MW GTPP	Gas (PDB)	1x20	20	20	18	18	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	9	9	10	10				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	0	0	0				
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	320	290	300	300				
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	240	400	400	400				
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	290	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work		
104	Fenchugani 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	10	10	10	49				
Sylhet Zone Total					2472	2427	1457	1696	1674	1788	0	568	
105	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage		
107	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	44	0	45				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	51	0	70				
109	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	35	17	75				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	50	50	100				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	82	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	79	16	49				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	0	0				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0	617	Coal Shortage		
	Khulna 330 MW CAPP	Gas/HSD (BPDB)				120	120	120	120				
**	Bheramara (HVDC)	India		1000	1000	904	888	923	923				
Khulna Zone Total					3005	3001	1106	1267	1226	1382	1027	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	17	16	17				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	21	19	21				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	178	177	180	180				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1080	1090	1200	1244				
121	Potukhali 150MW PP (UPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	72	55	150				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage		
123	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	221	220	220	220				
Barisal Zone Total					2265	2265	1498	1597	1690	1632	307	0	
124	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	32	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	31	0	31				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	26	97	0	100				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	0				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	34	36	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	0	36				
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage		
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage		
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	220	193	180	193				
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	430	383	350	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	0	22	22				
137	Lillapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	10	10	10				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	95	35	95				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	50	50	50				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0				
Rajshahi Zone Total					2129	2129	800	969	697	1019	601	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	80	82	80	82	3		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250	24		Coal Shortage	
144	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	35	78	70	78				
146	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 119MW PP (Energypac)	HFO (IPP)	6*20	115	115	75	113	115	115				
149	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	26	0	30	0				
	Teesa Solar Limited	Solar (IPP)				133	0	130	0				
Rangpur Zone Total					830	750	604	523	663	525	27	85	
Sub-total: Plants in operation					23078	22700	9132.0	10264	9645	10945	3822	3156	
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Kapzoti 32 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosila 108MW PP(CLC)	HFO (IPP)	12x8.775-1x3.5	118	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amnura 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0	0	0	
Gross Total					23482	22700	9132	10264	9645	10945	3822	3156	

(C) Actual data of 04.02.23 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	: 10452 MW, at = 19:00 hrs											
02.	Max. Demand at eve. peak (Sub-station end)	: 9935 MW, at = 19:00 hrs											
03.	Highest Generation (Generation end)	: 10264 MW, at = 19:00 hrs											
04.	Minimum Generation (Generation end)	: 6484 MW, at = 5:00 hrs											
05.	Day-peak Generation (Generation end)	: 9132 MW, at = 12:00 hrs											
06.	Evening-peak Generation (Generation end)	: 10264 MW, at = 19:00 hrs											
07.	Evening Peak Load-shed (Sub-station end)	: 173 MW, at = 19:00 hrs											
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6823 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas/LF limitation	: 3595 MW											
b)	Coal supply Limitation	: 27 MW											
c)	Low water level in Kaptai lake	: 200 MW											
d)	Plants under shut down/ maintenance	: 3156 MW											
10.	Total Energy (Generation + India Import)	: 206.23 MKWh											
	By Gas = 115.037 MKWh	By Oil = 30.525 MKWh											
	By Coal = 35.011 MKWh	By Hydro = 0.738 MKWh											
	By Solar = 2.075 MKWh												
11.	Total Gas Supplied	: 877.84 MMCFD											
			12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :										
			Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
			Dhaka	3524	3524	0	Mymensingh	960	787	173			
			Chattogram	1018	1018	0	Sylhet	361	361	0			
			Khulna	1166	1166	0	Barishal	268	268	0			
			Rajshahi	1061	1061	0	Rangpur	713	713	0			
			Cumilla	865	865	0							
							Total	9935	9762	173			
			13.	Fuel cost :	(a) Gas = 118056276 Taka	(c) Coal = 286790597 Taka							
					(b) Oil = 360407742 Taka	Total = 765254615 Taka							
			14.	Maximum Temperature in Dhaka was :	26.5° C								
			15.	Export through East-West interconnections :									
				At evening peak-hour	: 9132 MW, at	19:00 hrs							