

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2023				Day : Saturday				Date : 11.02.23				
Probable Maximum Demand : 10300 MW				Probable Maximum Generation : 10449 MW				Rule Curve = 95.60 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 82.49 ft				Today = 82.43 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.02.23 (Yesterday)		11.02.23 (Today)		10.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work.	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	220	220	220	220			
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	0	0	190	Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	78	81	81	81	27	Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	248	261	210	210	99	Gas Shortage	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	225	225	225	Under Maint.	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	0	0	0	0	412	Under maint.	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage	
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0			
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	149	149	150	150	186	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.09+1x11.3	55	55	30	15	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	50	16	50			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	13	0	16	16			
17	Summit Power (Madhab+Ashulia)	Gas (SIPP, REB)	6x3.77+7x8.73	80	80	37	43	47	47			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	23	25	25	25			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	42	25	42			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	90	52	90			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	32	16	48			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	113	165	115	164			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	54	96	54	105			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0			
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	17	17	17			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	55	17	55			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	99	17	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	23	50	50	50			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	32	50	50	50			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	51	37	51	51			
Dhaka Zone Total				6004	5847	1521	1942	1549	2013	817	1377	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	8	17	8	17			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	68	17	85			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	151	151	130	151			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	106	296	100	300			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
49	Dohazari-Katash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	60	68	68	68			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	46	34	48			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	0	0	22	Gas Shortage	
	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	0			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	55	88	55	92			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	30			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	0	0	0	0	0	0		on test	
Chattogram Zone Total				2442	2382	679	981	682	1011	402	330	
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	44	45	42	42			
60	Ashuganj 225 MW CCGP	Gas (APSCl)	1x142+1*75	221	221	221	184	210	220			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0	360	Under maint.	
62	Ashuganj 450 MW CCGP(North)	Gas (APSCl)	1x361	360	360	300	355	330	300			
63	Ashuganj 420 MW CCGP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	50	300	400	Under maint.	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	50	50	50	50		Gas Shortage	
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*116	195	195	185	194	170	8		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	43	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	13	6	6	137	Gas Shortage	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	23	30	10	31			
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	13	16	25	25			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+20x1.015+10x1.068	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	114	17	114			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	9	9	9			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	94	17	94			
**	Impoport (Tripura)	India		160	160	114	114	135	152			
Cumilla Zone Total				3309	3285	1137	1367	1223	1503	271	923	
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	34	109	55	100	93	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	8	11	22	22			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	56	83	47	79			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	93	75	75	75			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	48	0	50	0	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymensingh Zone Total				622	614	247	284	257	282	93	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.02.23 (Yesterday)		11.02.23 (Today)		10.02.23 (Yesterday)	Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					Gen. shortfall for : Gas/Coal/Water Limitation MW
					Day	Evening	Day	Evening				
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30	40	GT-1 & ST-1 Under maint.	
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	42	30	30	48	GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	51	22	22			
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112	51	ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	62	65	65			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	87	86	84	86			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	216	210	220	220			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	18	19	19			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8			
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	290	300	300			
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	0	0	0	0	400	Under maint.	
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	370	380	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.4-5'2	50	50	50	49	49	49			
Sylhet Zone Total					2472	2427	1338	1346	1337	1359	0	969
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
106	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	19	42	0	45			
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	40	72	0	63			
109	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0			
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	56	57	55			
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0			
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	82	0	100	0			
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	32	0	32			
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	16	0	16			
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0	617	Coal Shortage	
**	Bheramara (H/DC)	Gas/HSD (B/PDB)		1000	1000	902	830	914	914			
Khulna Zone Total					3005	3001	1060	1048	1071	1245	1027	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	19	16	22			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	191	184	191	191			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1100	1244	1244			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	35	100	116	150			
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0	307	Coal Shortage	
123	Bhola 220MW CAPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	109	108	110	110			
Barishal Zone Total					2265	2265	1611	1527	1693	1733	307	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	34			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	4	0	31			
128	Chapainabaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	58	88	42	95			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	40	40	40			
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	50			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	30	0	36			
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	17	126	155	155	84	Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	132	120	130	100	100	Gas Shortage	
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	318	227	200	187	187	Gas Shortage	
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	21	21			
137	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	0			
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	35	35	50			
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	50	50	50			
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
Adani Power Jharkhanda Ltd							0	0	0	0		
Rajshahi Zone Total					2129	2129	747	828	732	903	762	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	33	85	42	85			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0			
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	95	0	115			
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	27	0	30	0			
Teesta Solar Limited							124	0	130	0		
Rangpur Zone Total					830	750	389	380	410	400	159	85
Sub-total: Plants in operation					23078	22700	8729.0	9703	8954	10449	3838	3684
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PPI(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
154	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0		Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0		
Gross Total					23482	22700	8729	9703	8954	10449	3838	3684

(C) Actual data of 10.02.23 (Yesterday) Friday :															
01.	Max. Demand at eve. peak (Generation end)	:	9722	MW,	at =	19:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	9197	MW,	at =	19:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	9703	MW,	at =	19:00	hrs	Dhaka	3073	3073	0	Mymensingh	890	872	18
04.	Minimum Generation (Generation end)	:	7128	MW,	at =	5:00	hrs	Chattogram	947	947	0	Sylhet	344	344	0
05.	Day-peak Generation (Generation end)	:	8729	MW,	at =	12:00	hrs	Khulna	1112	1112	0	Barishal	269	269	0
06.	Evening-peak Generation (Generation end)	:	9703	MW,	at =	19:00	hrs	Rajshahi	1016	1016	0	Rangpur	703	703	0
07.	Evening Peak Load-shed (Sub-station end)	:	18	MW,	at =	19:00	hrs	Cumilla	844	844	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6670	MW,	at =	5:00	hrs	Total				9197	9197	18	
09.	Generation shortfall at evening peak due to :	:						Fuel cost :		(a) Gas = 114057381 Taka	(c) Coal = 297193109 Taka				
	a) Gas/LF limitation	:	3479	MW				(b) Oil = 483986565 Taka		(c) Coal = 297193109 Taka					
	d) Coal supply Limitation	:	159	MW						(c) Coal = 297193109 Taka					
	b) Low water level in Kaptai lake	:	200	MW						(c) Coal = 297193109 Taka					
	c) Plants under shut down/ maintenance	:	3684	MW						(c) Coal = 297193109 Taka					
10.	Total Energy (Generation + India Import)	:	198.67	MKWh				14. Maximum Temperature in Dhaka was :		29.5° C					
	By Gas = 101.842 MKWh				By Oil = 36.499 MKWh			15. Export through East-West interconnections :							
	By Coal = 34.989 MKWh				By Hydro = 0.732 MKWh			At evening peak-hour		:	8729	MW,	at	19:00	hrs
	By Solar = 2.189 MKWh							Maximum		:	628	MW,	at	18:30	hrs
11.	Total Gas Supplied	:	796.09	MMCFD				Energy		:	0	MKWh			
(D) Forecast of 11.02.23 (Today) Saturday :															
01.	Maximum Demand	:	10300	MW	(Generation end)	04. Maximum Load-shed		:	0	MW	At evening peak (Sub-station end)				
02.	Maximum Generation	:	10449	MW	(Generation end)	05. Total Generation		:	210.89	MKWh					
03.	Reserve / Shortage	:	149	MW	(Generation end)	06. Probable Max. Temperature in Dhaka :		:	30.6° C						

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW