

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2023		Day : Saturday			Date : 18.02.23						
Probable Maximum Demand :		10500 MW			Probable Maximum Generation : 11199 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 82.03 ft			Today = 81.93 ft						
					Rule Curve = 94.62 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.02.23 (Yesterday)		18.02.23 (Today)		17.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coil/Miner Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work.
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	120	115	120	120	65	Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	264	280	300	280	80	Gas Shortage
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	225	225	300	300	225	Gas Shortage
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	0	0	300	300	412	Under maint.
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	142	142	0	0	193	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.09+1x11.3	55	55	40	40	40	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	50	16	50		
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	10	19	22		
17	Summit Power (Madhab+Ashulia)	Gas (SIPP, REB)	6x3.77+7x8.73	80	80	42	40	49	49		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	16	28	28		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	50	25	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	52	90		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	48	48	64		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	32	0	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	72	135	33	130		
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	72	35	72		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0		
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	17	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	54	17	55		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	26	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17		
35	Siddhirganj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	17	50	16	50		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	17	49	17	50		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	20	35	75	75		
Dhaka Zone Total			6004	5847	1393	1920	1784	2377	1321	1152	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		Under maint.
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25		
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	19	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	20	20	20		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	85	34	85		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	142	148	100	225	77	ST Under maint.
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	106	155	100	300		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25		
49	Dohazari-Katash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	34	32	17	85		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	24	40	60		
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12	10	Gas Shortage
52	* Malancha, Ctg. EPZ (United)	Gas	5x8.73+3x9.34	108	108	0	0	0	0		
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17		
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	72	74	72	72		
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25		
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	22	22	22		
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	68	107	107		
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test
Chattogram Zone Total			2442	2382	745	762	671	1110	390	407	
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	10	10	10	10	35	Gas Shortage
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1x75	221	221	209	184	210	200		
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0	360	Under maint.
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	310	290	300	300	70	Gas Shortage
63	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	340	280	350	300	120	Gas Shortage
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	5	5	5	5	50	Gas Shortage
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'116	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'8.34	51	51	43	43	43	43		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	100	13	100		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	7	29	7	36		
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	8	8	8		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	13	16	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	18	21	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	39x1.4+20x1.015+10x1.061	200	200	0	0	0	0		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	34	17	17		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	48	9	55		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	13	17	17		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	72	17	72		
**	Impoort (Tripura)	India	160	160	108	112	135	153	153		
Cumilla Zone Total			3309	3285	1195	1334	1259	1442	596	523	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	35	100	50	100	102	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	38	50	50		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	104	115	100	100		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahkhal 50 MW Solar PP	Solar (IPP)	1x50	50	41	0	50	0	0		
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6		
Mymensingh Zone Total			622	614	254	278	277	275	102	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	17.02.23 (Yesterday)		18.02.23 (Today)		17.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date		
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)				
88	Fenchuganj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	40	0	0		30	GT-1 & GT-1 Under maint.		
89	Fenchuganj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	42	43	43		48	GT-4 Under maint.		
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	27	31	31					
91	Kushira 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		51	ST Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	63	61	61					
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	89	89	86	86					
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	210	208	210	210					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	19	19					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	8	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage		
100	Bibiana-III 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	265	310	300					
101	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	381	367	400	400					
102	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	400	360	400	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	10	21	50	50					
Sylhet Zone Total					2472	2427	1676	1618	1748	1738	17	559		
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
106	Bheramara 410 MW CCGP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	0	0	0	0	410		Gas Shortage		
107	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45					
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	0					
109	Khulna 225 MW CCGP	HSD (NWP/CGCL)	1 x 150+1x75	230	230	0	0	0	0					
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0					
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	36	17	55					
112	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	0	0	0					
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	69	0	100	0					
114	Khulna 115 MW PP (KPL-2)	HFO (NENP)	7x17	115	115	0	32	0	32					
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	16	0	16					
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	400	400	400	400	217		Coal Shortage		
**	Bheramara (H/DC)	Gas/HSD (BPDB)		1000	1000	905	717	916	916					
Khulna Zone Total					3005	3001	1391	1201	1433	1564	627	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	16					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	9	22	16	21					
119	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x88	194	194	184	170	190	192					
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	760	740	750	750					
121	Putuakhal 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0					
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	181	150	180	180					
123	Bhola 220MW CCGP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	111	220	220	220		0	Under maintenance		
Barishal Zone Total					2265	2265	1245	1302	1356	1379	0	0		
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	71			Gas Shortage		
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	33	0	34					
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	9	29	0	30					
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	50	50	96					
129	Katakhali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	39	40	32	40					
130	Katakhali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0					
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	30	0	30					
132	Sirajganj 225MW CCGP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	134	135	160	160	75		Gas Shortage		
133	Sirajganj 225MW CCGP Unit-2	Gas (NWP/CGCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
134	Sirajganj 225MW CCGP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage		
135	Sirajganj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	260	325	280	320	89		Gas Shortage		
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22					
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8					
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	95	35	95					
140	Bagura 113 MW (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	70					
141	Sirajganj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	4	0	6	0					
141	Adani Power Jharkhanda Ltd	Coal				0	0							
Rajshahi Zone Total					2129	2129	627	847	631	916	775	0		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	85			Coal Shortage		
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal Shortage		
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	41	71	42	85					
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0					
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	113	0	113					
149	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	28	0	30	0					
149	Teesta Solar Limited	Solar (IPP)				126	0	130	0					
Rangpur Zone Total					830	750	401	384	410	398	159	85		
Sub-total: Plants in operation					23078	22700	8927	9646	9569	11199	3987	2726		
(B) Plants under long term maintenance/ contract expired														
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0					
152	Bosilia 108MW PPI(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
154	Ankur 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0	0	0		
Gross Total					23482	22700	8927	9646	9569	11199	3987	2726		

(C) Actual data of 17.02.23 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	: 9670 MW, at = 19:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 9348 MW, at = 19:00 hrs		Demand			Supply			Load Shed			
03.	Highest Generation (Generation end)	: 9646 MW, at = 19:00 hrs											
04.	Minimum Generation (Generation end)	: 7182 MW, at = 5:00 hrs		Dhaka	3131	3131	0	Mymensingh	925	903	22		
05.	Day-peak Generation (Generation end)	: 8927 MW, at = 12:00 hrs		Chattogram	1004	1004	0	Sylhet	333	333	0		
06.	Evening-peak Generation (Generation end)	: 9646 MW, at = 19:00 hrs		Khulna	1113	1113	0	Barishal	260	260	0		
07.	Evening Peak Load-shed (Sub-station end)	: 22 MW, at = 19:00 hrs		Rajshahi	1037	1037	0	Rangpur	724	724	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	: 6729 MW, at = 5:00 hrs		Cumilla	821	821	0						
09.	Generation shortfall at evening peak due to :							Total	9348	9326	22		
	a) Gas/LF limitation	: 3628 MW		13.	Fuel cost :			(a) Gas = 115057670 Taka	(c) Coal = 213072292 Taka		Taka		
	d) Coal supply Limitation	: 159 MW						(b) Oil = 371034326 Taka	(d) Total = 699164288 Taka		Taka		
	b) Low water level in Kaptai lake	: 200 MW		14.	Maximum Temperature in Dhaka was : 29.4° C								
	c) Plants under shut down/ maintenance	: 2726 MW		15.	Export through East-West interconnections :								
10.	Total Energy (Generation + India Import)	: 203.08 MKWh			At evening peak-hour			: 8927 MW, at 19:00 hrs					
	By Gas = 111.019 MKWh				Maximum			: 30 MW, at 7:00 hrs					
	By Coal = 39.220 MKWh				Energy			: 0 MKWh					
	By Solar = 1.997 MKWh												
11.	Total Gas Supplied	: 876.03 MMCFD											
(D) Forecast of 18.02.23 (Today) Saturday :													
01.	Maximum Demand	: 10500 MW (Generation end)	04.	Maximum Load-shed	: 0 MW	At evening peak (Sub-station end)							
02.	Maximum Generation	: 11199 MW (Generation end)	05.	Total Generation	: 221.06 MKWh								
03.	Reserve / Shortage	: 699 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	30° C								

#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation