

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2023				Day : Sunday				Date : 19.02.23				
Probable Maximum Demand : 10800 MW				Probable Maximum Generation : 11440 MW				Rule Curve = 94.48 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 81.93 ft				Today = 81.72 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.02.23 (Yesterday)		19.02.23 (Today)		18.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	120	120	120	120	60	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	321	308	300	300	52	Gas Shortage	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300	150	Gas Shortage	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	286	0	250	250			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	111	0	0	99	Gas Shortage	
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Gas Shortage	
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.09+1x11.3	55	55	40	55	40	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	50	16	50			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	19	22			
17	Summit Power (Madhab+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	30	30	49	49			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	30	29	30	30			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	41	25	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	88	50	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	64	48	64			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	32	164	115	165			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	36	72	35	72			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0			
27	Bramhaniganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	0	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	53	17	55			
32	Manikganj 162MW PR(MPGL)	HFO (IPP)	9x18	162	162	0	162	17	162			
33	Manikganj 35MW Solar PP (Inspectra Soler Ltd.)	Solar (IPP)	1x35	35	35	24	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	0	17			
35	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	17	40	8	40			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	18	50	17	50			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	80	70	85	85			
Dhaka Zone Total				6004	5847	1724	2184	1784	2382	1244	740	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	20	20	20			
44	Sikalbaha 105 MW PP (Baraka Sikalabaha)	HFO (IPP)	6x18.415	105	105	5	85	34	85			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	137	226	220	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	105	243	100	245			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
49	Dohazari-Katash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	84	68	85			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	40	66	40	65			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12	10	Gas Shortage	
	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34	108	108	0	0	0	0			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	72	73	54	73			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	35	25	25	25			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	30	22	22	22			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	51	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test	
Chattogram Zone Total				2442	2382	700	1004	824	1061	390	330	
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	45	10	10	10	35	Gas Shortage	
60	Ashuganj 225 MW CCGP	Gas (APSCl)	1x142+1x75	221	221	165	184	200	190			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0	360	Under maint.	
62	Ashuganj 450 MW CCGP(North)	Gas (APSCl)	1x361	360	360	300	275	320	300	85	Gas Shortage	
63	Ashuganj 420 MW CCGP(East)	Gas (APSCl)	1x284+1x116	400	400	325	312	330	300	88	Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	25	5	5	5	50	Gas Shortage	
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'116	195	195	8	8	8	8	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	35	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	13	100	13	100			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	7	29	29	36			
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	34	34			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	22	22	22	22			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	0	5	5			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	23	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	8	8	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	12	21	21			
	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.015+10x1.068	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	34	17	100			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	87	9	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	22	72	39	72			
**	Impoport (Tripura)	India	160	160	98	126	135	153	153			
Cumilla Zone Total				3309	3285	1199	1411	1298	1570	579	523	
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	44	82	35	100	120	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	75	98	88	50			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	56	56	18	100			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	39	0	50	0	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymensingh Zone Total				622	614	241	261	218	275	120	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	18.02.23 (Yesterday)		19.02.23 (Today)		18.02.23 (Yesterday)	Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					Gen. shortfall for : Gas/Coal/Water Limitation MW
					Day	Evening	Day	Evening				
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0	70	GT-1 & ST-1 Under maint.	
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	31	31	31	31	59	GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	22	51	40	40			
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8	51		
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	62	62	61	61			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	40	86	70	86			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	170	171	170	170			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	6	8	10	10			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17	Gas Shortage	
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	285	300	300			
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	400	367	400	400			
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
104	Fenchuganj 44MW (Energyprime)	Gas (NENP)	12'3.3-5'2	50	50	40	49	50	50			
Sylhet Zone Total					2472	2427	1632	1656	1679	1695	17	610
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
106	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	0	0	0	0	410	Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	45			
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	60			
109	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0			
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	35			
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	0	0			
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	52	0	100	0			
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	49	16	83			
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	24	0	16			
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	385	387	380	380	230	Coal Shortage	
	Khulna 330 MW CAPP	Gas/HSD (B/PDB)				0	0	0	0			
**	Bheramara (H/DC) India		1000	1000	898	794	919	919				
Khulna Zone Total					3005	3001	1368	1286	1432	1538	640	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	16			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	22	16	16			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x88	194	194	184	185	183	183			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	760	850	900	900			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	169	168	150	150			
123	Bhola 220MW CAPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	223	220	220			
Barishal Zone Total					2265	2265	1352	1448	1469	1485	0	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	33	0	34			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	27	0	30			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	50	96	50	96			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	4	40	32	40			
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	0			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	21	30	0	30			
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	137	149	150	150	61	Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220	Gas Shortage	
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	358	400	400	56	Gas Shortage	
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	20	21	22	22			
137	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	11	11	11			
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	95	35	95			
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	70			
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0			
	Adani Power Jharkhanda Ltd	Coal				0	0	0	0			
Rajshahi Zone Total					2129	2129	727	938	741	986	728	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	250	250	74	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	37	85	35	85			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	0	113	35	113			
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	25	0	30	0			
	Teesta Solar Limited	Solar (IPP)				115	0	130	0			
Rangpur Zone Total					830	750	383	398	488	448	159	85
Sub-total: Plants in operation					23078	22700	9326	10586	9933	11440	3877	2288
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0			
152	Bosilia 108MW PPI(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
154	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0		Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0	0	0
Gross Total					23482	22700	9326	10586	9933	11440	3877	2288

(C) Actual data of 18.02.23 (Yesterday) Saturday :															
01.	Max. Demand at eve. peak (Generation end)	:	10586	MW,	at =	19:30	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10121	MW,	at =	19:30	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	10586	MW,	at =	19:30	hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	6729	MW,	at =	5:00	hrs	Dhaka	3655	3655	0	Mymensingh	937	937	0
05.	Day-peak Generation (Generation end)	:	9326	MW,	at =	12:00	hrs	Chattogram	1058	1058	0	Sylhet	373	373	0
06.	Evening-peak Generation (Generation end)	:	10586	MW,	at =	19:30	hrs	Khulna	1167	1167	0	Barishal	278	278	0
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW,	at =	19:30	hrs	Rajshahi	1088	1088	0	Rangpur	717	717	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7280	MW,	at =	5:00	hrs	Cumilla	850	850	0				
09.	Generation shortfall at evening peak due to :	:										Total	10121	10121	0
	a) Gas/LF limitation	:	3518	MW				13.	Fuel cost :	(a) Gas = 122284780	Taka	(c) Coal = 203274610	Taka		
	d) Coal supply Limitation	:	159	MW						(b) Oil = 431250682	Taka	Total = 756810072	Taka		
	b) Low water level in Kaptai lake	:	200	MW											
	c) Plants under shut down/ maintenance	:	2288	MW											
10.	Total Energy (Generation + India Import)	:	212.12	MKWh				14.	Maximum Temperature in Dhaka was :	30.1° C					
	By Gas = 117.220	MKWh						15.	Export through East-West interconnections :						
	By Coal = 37.823	MKWh							At evening peak-hour	:	9326	MW,	at	19:30	hrs
	By Solar = 1.808	MKWh							Maximum	:	320	MW,	at	7:00	hrs
									Energy	:	0	MKWh			
11.	Total Gas Supplied	:	889.34	MMCFD											
(D) Forecast of 19.02.23 (Today) Sunday :															
01.	Maximum Demand	:	10800	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)				