

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month February, 2023				Day : Thursday				Date : 23.02.23				
Probable Maximum Demand : 11500 MW				Probable Maximum Generation : 12233 MW				Rule Curve = 93.90 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 81.00 ft				Today = 80.76 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.02.23 (Yesterday)		23.02.23 (Today)		22.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130	50	Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CAPP(HPL)	Gas (IPP)	1x235+1x125	360	360	0	41	340	330	319	Gas Shortage	
8	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	300	300	300			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	412	408	411	400	400			
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	198	199	150	200	11	Gas Shortage	
12	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		Under maint	
13	Meghnaghat CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	147	147	150	150	188	Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.09+1x11.3	55	55	26	55	40	55			
15	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	16	40	100	50			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22			
17	Summit Power (Madhab+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	50	50	50			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	50	25	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	88	52	88			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	98	48	115			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	115	245	145	245			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	78	72	108			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x12.4	300	300	0	0	0	0			
27	Bramhaniganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	55	0	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	54	17	55			
32	Manikganj 162MW PR(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	27	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	8	8	8	8			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	9	0	9	9			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	64	64	48	64			
Dhaka Zone Total				6004	5847	1973	2650	2416	2999	781	740	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	60	60	200	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	75	75	180	Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	85	34	85			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0	75	ST Under maint	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	106	243	100	245			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	25	25	25	25			
49	Dohazari-Kalataish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	85	85	51	85			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	24	69	48	65			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	0	15	10	10	7	Gas Shortage	
	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34	108	108	0	0	0	0			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	25	25	25	25			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	22	22	22			
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	150	150	0	0	0	0		on test	
Chattogram Zone Total				2442	2382	588	821	697	919	387	405	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	44	44	44	44			
60	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1x75	221	221	212	198	200	200			
61	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Gas Shortage	
62	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	340	305	330	310	55	Gas Shortage	
63	Ashuganj 420 MW CAPP(East)	Gas (APSCL)	1x284+1x116	400	400	360	360	350	360	40	Gas Shortage	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	15	5	15	15	50	Gas Shortage	
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+11'6	195	195	8	8	80	80	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'8.34	51	51	51	51	51	51			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	68	150	67	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	37	36	28	36			
69	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	41	34	34	34			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	17	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	7	7			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+66x1.615+10x1.668	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	80	17	98			
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	105	9	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	17	115	18	115			
**	Import (Tripura)	India	160	160	128	132	135	153	153			
Cumilla Zone Total				3309	3285	1426	1728	1477	1866	826	163	
81	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	132	109	100	100	93	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	59	49	65			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	96	93	66	56			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	34	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6			
Mymensingh Zone Total				622	614	298	286	292	246	93	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.02.23 (Yesterday)		23.02.23 (Today)		22.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)			
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	42	42		27	GT-1 & GT-1 Under maint.	
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	20	31	31	31		59	GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	48	51	51	51				
91	Kushira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112			ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	5	8	8		51		
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	62	62	62				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	89	89	89	89				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	0	140	150	150		91	Under maint.	
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	8	8				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage	
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	315	300	300				
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	410	398	400	400				
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0		383	Under maint.	
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprime)	Gas (NENP)	12'3.3-5'2	50	50	50	49	50	50				
Sylhet Zone Total					2472	2427	1175	1329	1330	1330	17	1041	
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	370	410	350	410	0		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	40				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	80				
109	Khulna 225 MW CAPP	HSD (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	37	17	35				
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	32	0	32				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	82	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	49	0	66				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	16	0	16				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	402	400	400	400	217		Coal Shortage	
**	Bheramara (H/DC)	Gas/HSD (B/PDB)		1000	1000	895	778	916	916				
Khulna Zone Total					3005	3001	1766	1722	1783	1995	217	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	20	17	22				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	174	183	180	180				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	760	922	900	950				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	170	199	180	180				
123	Bhola 220MW CAPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	108	108	220	220				
Barishal Zone Total					2265	2265	1230	1432	1497	1552	0	0	
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	70	70	70	1		Gas Shortage	
124	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	33	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	16	16	30				
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	43	93	50	95				
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	32	40				
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	34	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	20	36	26	36				
132	Sirajganj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	216	218	170	220				
133	Sirajganj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
134	Sirajganj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	176	180	220		Gas Shortage	
135	Sirajganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	0	0	414		Gas Shortage	
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	21	21	19	19				
137	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	8	0	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	75	35	75				
140	Bagura 113 MW (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	70				
141	Sirajganj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
Adani Power Jharkhanda Ltd							0	0	0	0			
Rajshahi Zone Total					2129	2129	472	717	696	928	955	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
142	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	34	92	38	85				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	36	113	35	113				
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	18	0	30	0				
	Teesta Solar Limited	Solar (IPP)				95	0	130	0				
Rangpur Zone Total					830	750	388	405	441	398	159	85	
Sub-total: Plants in operation					23078	22700	9316	11090	10629	12233	3435	2434	
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0				
152	Bosilia 108MW PPI(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0	0	0	
Gross Total					23482	22700	9316	11090	10629	12233	3435	2434	

(C) Actual data of 22.02.23 (Yesterday) Wednesday :															
01.	Max. Demand at eve. peak (Generation end)	:	11200	MW,	at =	19:30	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	10841	MW,	at =	19:30	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	11090	MW,	at =	19:30	hrs		MW	MW	MW		MW	MW	MW
04.	Minimum Generation (Generation end)	:	7163	MW,	at =	5:00	hrs	Dhaka	4101	4101	0	Mymensingh	968	958	10
05.	Day-peak Generation (Generation end)	:	9316	MW,	at =	12:00	hrs	Chattogram	1123	1123	0	Sylhet	355	355	0
06.	Evening-peak Generation (Generation end)	:	11090	MW,	at =	19:30	hrs	Khulna	1230	1230	0	Barishal	298	298	0
07.	Evening Peak Load-shed (Sub-station end)	:	101	MW,	at =	19:30	hrs	Rajshahi	1104	1049	55	Rangpur	713	677	36
08.	Minimum Generation Forecast up to 8:00 hrs.	:	7887	MW,	at =	5:00	hrs	Cumilla	948	948	0				
09.	Generation shortfall at evening peak due to :	:						Total		10841	10740	101			
a)	Gas/LF limitation	:	3076	MW			13. Fuel cost :		(a) Gas = 126622958	Taka	(c) Coal = 214491153	Taka			
d)	Coal supply Limitation	:	159	MW					(b) Oli = 513497395	Taka	(d) Total = 856611505	Taka			
b)	Low water level in Kaptai lake	:	200	MW											
c)	Plants under shut down/ maintenance	:	2434	MW											
10.	Total Energy (Generation + India Import)	:	220.99	MW											
	By Gas = 117.360	By Oil = 38.464	By Coal = 39.916	By Hydro = 0.719	By Solar = 1.785										
11.	Total Gas Supplied	:	966.07	MMCFD											
(D) Forecast of 23.02.23 (Today) Thursday :															
01.	Maximum Demand	:	11500	MW	(Generation end)			04. Maximum Load-shed		:	0	MW	At evening peak (Sub-station end)		
02.	Maximum Generation	:	12233	MW	(Generation end)			05. Total Generation		:	229.16	MW			
03.	Reserve / Shortage	:	733	MW	(Generation end)			06. Probable Max. Temperature in Dhaka :		:	32.9°	C			

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation