

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023				Day : Wednesday				Date : 01.03.23			
Probable Maximum Demand : 11800 MW				Probable Maximum Generation : 13269 MW				Rule Curve = 93.00 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 79.63 ft				Today = 79.51 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.02.23 (Yesterday)		01.03.23 (Today)		28.02.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	327	352	350	350		
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	404	365	400	400		
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210	Gas Shortage
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under Maint.
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	280	266	270	270	69	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.09+1x11.3	55	55	55	55	55	55		
15	Gaganraj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	40	58	40	58		
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22		
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	43	48	50	50		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	15	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	28	30	30		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	49	25	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	90	52	90		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	98	48	98		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	147	245	262	285		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	90	97	100	149		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0		
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	17	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	16	17	17		
32	Manikganj 162MW PR(MPGL)	HFO (IPP)	9x18	162	162	17	35	17	100		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	40	55	33	60		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	42	58	31	60		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	88	65	85	85		
Dhaka Zone Total				6004	5847	2607	2937	2761	3184	492	1075
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	4	0	5	0	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	20		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	18	20	21	21		
44	Sikalbaha 105 MW PP (Baraka Sikalabaha)	HFO (IPP)	6x18.415	105	105	34	34	17	51		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	222	227	220	220		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	122	248	100	245		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	100	50	100		
49	Dohazari-Katash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	70	17	85		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	62	70	50	70		
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15	7	Gas Shortage
	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34	108	108	0	0	0	0		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	17		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	50	100	50	100		
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	44	83	44	85		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	150	150	0	0	0	0		on test
Chattogram Zone Total				2442	2382	866	1200	842	1225	387	330
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	30	42	47	47		
60	Ashuganj 225 MW CCGP	Gas (APSCl)	1x142+1*75	221	221	192	183	190	190		
61	Ashuganj 450 MW CCGP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0	360	Gas Shortage
62	Ashuganj 450 MW CCGP(North)	Gas (APSCl)	1x361	360	360	320	310	300	300		
63	Ashuganj 420 MW CCGP(East)	Gas (APSCl)	1x284+1x116	400	400	351	345	380	400		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	5	5	50	Gas Shortage
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*16	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	43	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	48	128	40	150	22	Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	29	20	28	33		
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	97	34	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	19	19		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	0	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	3	0	8		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	18	20	20		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+6x1.015+10x1.068	200	200	0	0	0	0		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	17	80	17	100		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	82	9	113		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	72	18	72		
**	Impoport (Tripura)	India	160	160	104	138	135	153	153		
Cumilla Zone Total				3309	3285	1272	1618	1360	1928	753	163
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	32	63	50	65	139	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	19	19		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	47	78	12	80		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	111	88	114		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	48	0	50	0	0		
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6		
Mymensingh Zone Total				622	614	221	277	227	284	139	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28.02.23 (Yesterday)		01.03.23 (Today)		28.02.23 (Yesterday)	Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW
					Day	Evening	Day	Evening	Description/ Remarks			
88	Fenchuganj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	42	42	42	42	28	GT-1 & ST-1 Under maint.	
89	Fenchuganj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	42	47	GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	53	30	51			
91	Kushiera 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	62	60	62			
94	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	89	86	86			
96	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	212	214	225	225			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	8	8			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8			
100	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	315	270	300	300			
101	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	376	368	366	366			
102	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.4-5'2	50	50	40	47	46	50			
Sylhet Zone Total					2472	2427	1642	1630	1641	1667	0	559
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
106	Bheramara 410 MW CCGP	Gas (NWPGL)	1 x 278+1 x 132	410	410	330	410	370	380			
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	47			
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	40			
109	Khulna 225 MW CCGP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0			
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0			
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	12	35	55			
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	50			
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	85	0	100	0			
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	11	16	83	99			
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	8	0	24			
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	368	372	400	400			
**	Bheramara (H/DC)	Gas/HSD (B/PDB)		1000	1000	883	817	904	904			
Khulna Zone Total					3005	3001	1677	1635	1892	1999	0	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	16			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	17	20	14	14			
119	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x68	194	194	179	184	175	184			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	770	700	820	950			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	100			
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	151	150	150	150			
123	Bhola 220MW CCGP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	223	220	220			
Barishal Zone Total					2265	2265	1339	1277	1396	1634	0	0
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	23	0	32			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	16	30			
128	Chapainabaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	60	86	40	95			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	32	40	32	35			
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	28	28	26	36			
132	Sirajgonj 225MW CCGP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage	
133	Sirajgonj 225MW CCGP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage	
134	Sirajgonj 225MW CCGP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	120	124	170	170	96	Gas Shortage	
135	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	0	0	265	265			
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	19	21	22	22			
137	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8			
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	75	35	75			
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	70			
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0			
Adani Power Jharkhanda Ltd							0	0	0	0		
Rajshahi Zone Total					2129	2129	387	520	708	891	697	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250	24	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	42	85	49	92			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tabula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	5	111	35	115			
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	27	0	30	0			
	Teesta Solar Limited	Solar (IPP)				116	0	130	0			
Rangpur Zone Total					830	750	446	446	502	457	109	85
Sub-total: Plants in operation					23078	22700	10457.0	11540	11329	13269	2577	2212
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PPI(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
154	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0		Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0		
Gross Total					23482	22700	10457	11540	11329	13269	2577	2212

(C) Actual data of 28.02.23 (Yesterday) Tuesday :											
01.	Max. Demand at eve. peak (Generation end)	: 11562 MW, at = 19:00 hrs									
02.	Max. Demand at eve. peak (Sub-station end)	: 11176 MW, at = 19:00 hrs									
03.	Highest Generation (Generation end)	: 11540 MW, at = 19:00 hrs									
04.	Minimum Generation (Generation end)	: 8381 MW, at = 4:00 hrs									
05.	Day-peak Generation (Generation end)	: 10457 MW, at = 12:00 hrs									
06.	Evening-peak Generation (Generation end)	: 11540 MW, at = 19:00 hrs									
07.	Evening Peak Load-shed (Sub-station end)	: 20 MW, at = 19:00 hrs									
08.	Minimum Generation Forecast up to 8:00 hrs.	: 8092 MW, at = 5:00 hrs									
09.	Generation shortfall at evening peak due to :										
	a) Gas/LF limitation	: 2268 MW									
	d) Coal supply Limitation	: 109 MW									
	b) Low water level in Kaptai lake	: 200 MW									
	c) Plants under shut down/ maintenance	: 2212 MW									
10.	Total Energy (Generation + India Import)	: 240.41 MKWh									
	By Gas = 135.302 MKWh	By Oil = 42.247 MKWh									
	By Coal = 36.566 MKWh	By Hydro = 0.718 MKWh									
	By Solar = 2.274 MKWh										
11.	Total Gas Supplied	: 998.51 MMCFD									
			(D) Forecast of 01.03.23 (Today) Wednesday :								
01.	Maximum Demand	: 11800 MW (Generation end)									
02.	Maximum Generation	: 13269 MW (Generation end)									
03.	Reserve / Shortage	: 1469 MW (Generation end)									
04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)									
05.	Total Generation	: 245.64 MKWh									
06.	Probable Max. Temperature in Dhaka :	: 32.2° C									
			(E) Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :								
	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW			
	Dhaka	4168	4168	0	Mymensingh	936	916	20			
	Chattogram	1102	1102	0	Sylhet	372	372	0			
	Khulna	1303	1303	0	Barishal	303	303	0			
	Rajshahi	1237	1237	0	Rangpur	754	754	0			
	Cumilla	1001	1001	0							
	Total					11176	11156	20			
13.	Fuel cost :	(a) Gas = 142242657 Taka	(c) Coal = 21900336 Taka								
		(b) Oil = 559744288 Taka	(d) Total = 913887282 Taka								
14.	Maximum Temperature in Dhaka was : 32.6° C										
15.	Export through East-West interconnections :										
	At evening peak-hour	: 10457 MW, at 19:00 hrs									
	Maximum	: -146 MW, at 20:00 hrs									
	Energy	: 0 MKWh									

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00 (Md. Helalur Rahman) Deputy Secretary, Generation