

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023				Day : Friday				Date : 03.03.23			
Probable Maximum Demand : 11000 MW				Probable Maximum Generation : 12700 MW				Rule Curve = 92.68 ft.			
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 79.39 ft				Today = 79.27 ft			
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.03.23 (Yesterday)		03.03.23 (Today)		02.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work.
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	347	344	300	344		
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	350	450	450		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	402	367	370	370		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	34	90	90	176	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under Maint.
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	0	0	335	Gas Shortage
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.09+1x11.3	55	55	55	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	58	40	58		
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	22	22	22		
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	31	31	48	51		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	26	30	30		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	50	25	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	88	52	88		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	32	98	32	98		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	278	278	280	280		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	149	149	149	149		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0		
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	17	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	17	18	19	46		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	129	17	144		
33	Manikganj 35MW Solar PP (Inspectra Soler Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	40	47	33	50		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	41	61	31	60		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	90	75	30	75		
Dhaka Zone Total				6004	5847	2502	2776	2497	3015	724	1075
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30	200	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	17	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	20		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	18	18	18		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	34	34		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	220	200	220	220		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	121	257	120	260		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	88	100	88	100		
49	Dohazari-Kalataish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	85	17	85		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	38	58	50	60		
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15	7	Gas Shortage
	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	0		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	36		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	62	54	54		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100		
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	33	33	33		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	96	107	107		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test
Chattogram Zone Total				2442	2382	932	1166	945	1177	387	330
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	46	46	45	46		
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1x75	221	221	190	218	190	220		
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Gas Shortage
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	330	290	300	300		
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	350	250	320	320		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	40	5	5	5	50	Gas Shortage
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+11'6	195	195	8	8	8	8	187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'8.34	51	51	51	51	51	51		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	40	140	40	150	10	Gas Shortage
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	30	28	28	30		
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	92	34	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	19	19	19		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	21	21	21		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+60x1.015+10x1.068	200	200	0	0	0	0		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	17	80	17	80		
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	104	9	113		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	37	72	18	72		
**	Impoport (Tripura)	India		160	160	138	138	135	153		
Cumilla Zone Total				3309	3285	1417	1629	1299	1855	741	163
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	44	55	70	100	147	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	19	19	19		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	49	78	47	80		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	68	116	68	115		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahkhal 50 MW Solar PP	Solar (IPP)	1x50	50	45	0	50	0	0		
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6		
Mymensingh Zone Total				622	614	228	274	262	320	147	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	02.03.23 (Yesterday)		03.03.23 (Today)		02.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)			
88	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	43	43	43	43		27	GT-1 & ST-1 Under maint.	
89	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	43	43	43	43		47	GT-4 Under maint.	
90	Fenchugonj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	42	42	30	50				
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	112	0	112				
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	5	8	8	8		52		
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	32	32	32				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330		Under maint.
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	89	86	86				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	214	210	215	215				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	8	8				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8				
100	Bibiiana-III 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	325	290	300	300				
101	Bibiiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	402	367	366	367				
102	Bibiiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	370	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100		Under project work
104	Fenchugonj 44MW (Energyprima)	Gas (NENP)	12'3.4-5'2	50	50	46	50	30	50				
Sylhet Zone Total				2472	2427	1668	1690	1588	1741		0	558	
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	150	260	150	260				
107	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	38	0	38				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	32	0	75				
109	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	55	56	56	56				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	89	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	80	99	83	99				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	8	8	8	40				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0				
**	Bheramara (H/DC) India	Gas/HSD (B/PDB)		1000	1000	888	770	906	906				
Khulna Zone Total				3005	3001	1270	1295	1303	1524		0	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	15	19	14	20				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x88	194	194	176	178	185	185				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	870	1090	700	1050				
121	Potukhalhi 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	121	30	100				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	151	179	150	200				
123	Bhola 220MW CAPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	165	220	220				
Barishal Zone Total				2265	2265	1432	1752	1299	1775		0	0	
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71		Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100		Gas Shortage
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	30	0	30				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	20	20	18	20				
128	Chapainwabant 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	64	86	64	86				
129	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	30	40	32	40				
130	Katakhalhi 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	42	42	42	42				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	35	26	35				
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210		Gas Shortage
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150+1x75	220	220	0	0	0	0		220		Gas Shortage
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	220	145	150	150				
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	151	171	170	200				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	21	22	22				
137	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	75	95	75	95				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	50	70	50	90				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
Adani Power Jharkhanda Ltd		Coal				0	0						
Rajshahi Zone Total				2129	2129	691	774	674	829		601	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85		Coal Shortage
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85		Under Overhauling
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	250	250	250	250		24		Coal Shortage
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	71	99	70	99				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	5	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	37	113	35	115				
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	25	0	30	0				
	Teesta Solar Limited	Solar (IPP)				111	0	130	0				
Rangpur Zone Total				830	750	499	462	523	464		109	85	
Sub-total: Plants in operation				23078	22700	10639.0	11818	10390	12700		2709	2211	
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
152	Bosilia 108MW PPL(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amfara 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired				404	0	0	0	0	0				
Gross Total				23482	22700	10639	11818	10390	12700		2709	2211	

(C) Actual data of 02.03.23 (Yesterday) Thursday :				12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :			
01. Max. Demand at eve. peak (Generation end)		: 11865 MW, at = 19:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW
02. Max. Demand at eve. peak (Sub-station end)		: 11515 MW, at = 19:00 hrs		Dhaka	4293	4293	0
03. Highest Generation (Generation end)		: 11818 MW, at = 19:00 hrs		Chattogram	1092	1092	0
04. Minimum Generation (Generation end)		: 8170 MW, at = 5:00 hrs		Khulna	1378	1378	0
05. Day-peak Generation (Generation end)		: 10639 MW, at = 12:00 hrs		Rajshahi	1240	1240	0
06. Evening-peak Generation (Generation end)		: 11818 MW, at = 19:00 hrs		Cumilla	1032	1032	0
07. Evening Peak Load-shed (Sub-station end)		: 43 MW, at = 19:00 hrs					
08. Minimum Generation Forecast up to 8:00 hrs.		: 8203 MW, at = 5:00 hrs					
09. Generation shortfall at evening peak due to :							
a) Gas/LF limitation		: 2400 MW					
d) Coal supply Limitation		: 109 MW					
b) Low water level in Kaptai lake		: 200 MW					
c) Plants under shut down/ maintenance		: 211 MW					
10. Total Energy (Generation + India Import)		: 244.46 MCKWh					
By Gas = 133.394 MCKWh		By Oil = 46.642 MCKWh					
By Coal = 37.690 MCKWh		By Hydro = 0.730 MCKWh					
By Solar = 2.190 MCKWh							
11. Total Gas Supplied		: 1042.19 MMCFD					
13. Fuel cost : (a) Gas = 140764874 Taka (c) Coal = 253343812 Taka (b) Oil = 610962997 Taka (d) Total = 1005071682 Taka							
14. Maximum Temperature in Dhaka was : 34.1° C							
15. Export through East-West interconnections :							
At evening peak-hour		: 10639 MW, at 19:00 hrs					
Maximum		: 170 MW, at 21:00 hrs					
Energy		: 0 MCKWh					
04. Maximum Load-shed		: 0 MW At evening peak (Sub-station end)					
05. Total Generation		: 227.54 MCKWh					
06. Probable Max. Temperature in Dhaka :		: 34.2° C					

* Coactive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation