

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 3-Mar-23

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCPP-Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1210	180	130	312987	
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4347000	
4	Ghorasal 365 MW CCPP Unit-7	PDB	1243*1122	365	0	0	Under maint.
5	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
6	Ghorasal 108MW PP (Regent)	IPP	343.35	108	0	0	Gas shortage
7	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
8	Haripur 412 MW CCPP	EGCB	1273*1139	412	372	8925190	Frequency Control
9	Haripur 360MW CCPP(HPL)	IPP	1235*1125	360	309	7188000	Frequency Control
10	Meghnaghat 450 MW CCPP(MPL)	IPP	2150*1150	450	380	9396250	Frequency Control
11	Meghnaghat 100 MW (IEL)	NENP	12*9	100	28	419520	Low demand
12	Meghnaghat CCPP(Summit)	IPP	2110*1110	335	27	632960	ST syn at 19:29
13	Madanagar 102 MW (Summit)	NENP	6*17	102	12	8763	Low demand
14	Madanagar-55 MW PPS(Summit)	IPP	3*17.08*111.3	55	32	483625	Low demand
15	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	19	415152	
17	210 MW Siddhirgonj TPP	PDB	1210	115	0	0	Under maint.
18	Siddhirgonj 2120 MW GTTP	EGCB	2165	210	37	1545000	Gas shortage
19	Siddhirgonj 100 PP(Dutch) Bangla	NENP	12*8.9	100	24	372480	Low demand
20	Siddhirgonj 335 MW CCPP	EGCB	1217*118	335	0	0	Gas shortage
21	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	58	780048	Fuel shortage
22	Kaipoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	35	166240	Fuel shortage
24	Kodda 150MW PP	BPDB-RRCL	9*17.06	149	98	800160	Fuel shortage
25	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	55	307772	
26	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	389268	
27	Bosila 108MW PP(CLC)	IPP	12*8.775*113.5	0	0	0	
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67*4*8.73	80	45	1068000	Engine problem
29	Madhabdi 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	632600	
30	Ruaganj 33 MW PP(Summit)	SIPP, REB	4*8.73	33	30	767600	Engine problem
31	Gazipur 52 MW PP	RPCL	6*8.9	52	25	142080	Low demand
32	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	95	1538072	Low demand
34	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Fuel shortage
35	Bramhantha 100 MW PP (Aggreko)	IPP	11*9.959	100	0	0	Fuel shortage
36	Auraha 100MW PP (Aggreko)	IPP	0.85*23*0.95*91	100	0	0	Fuel shortage
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	40	1104048	Low demand
38	Gazipur 100 MW PP	RPCL	6*17.5	105	88	990518	Fuel shortage
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	60	926400	Fuel shortage
40	Manikganj 162MW PP(MPGL)	IPP	9*18	162	99	888480	Low demand
41	Spectro Solar Plant Ltd.	IPP	35	35	0	201262	
42	Kanchan Flatbatal Power Generation Ltd.	IPP	18.4*3	55	17	159120	Fuel shortage
Dhaka area Total				5847	2383	48005295	
43	Chattoagram TPP-1	PDB	1210	180	0	0	
44	Chattoagram TPP-2	PDB	1210	180	0	0	Gas shortage
45	Raozan 25 MW PP	RPCL	3*8.9	25	0	193478	Low demand
46	Tafal 20MW PP (Solartech)	IPP	20	20	0	141150	
47	Palenga 50MW PP (Baraka)	IPP	6*8.98	50	19	448320	Fuel shortage
48	Kapila Hydro Unit-1,2,3,4, 5	IPP	2*40*3*50	230	30	722880	Low water level
49	Sikalbaha 225MW	PDB	1150*1175	225	228	5360835	
50	Sikalbaha Peaking GT	PDB	1150	150	0	0	Under maint.
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	34	663127	Fuel shortage
52	Hathazari 100 MW peaking PP	PDB	11*8.9	98	9	226632	Low demand
53	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	68	496411	Low demand
54	Juldah 100 MW Unit-1 (Accom)	NENP	8*13.45	100	70	639600	Fuel shortage
55	Juldah 100 MW PP Unit-3 (Accom)	IPP	8*13.5	100	100	1032000	
56	Barabkunda 22 MW PP (Regent)	SIPP, PDB	6*2.90	22	15	361440	Gas shortage
57	Manaraha, Ch. EPZ (United)	IPP	5*8.73*9.34	0	0	28600	
58	Chattoagram 108 MW PP (ECPV)	IPP	16*7	108	0	0	Fuel shortage
59	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	27840	
60	Anwara 300 MW PP (United)	IPP	17*17*24	300	253	2268218	Fuel shortage
61	Jodiach Power	IPP	3*18.55*113.6	54	36	669484	Fuel shortage
62	Kanapath Power Ltd.	IPP	18.415*6+8.5	110	54	1359921	Fuel shortage
63	Juldah unit-2 (Accom)	IPP	8*13.5	100	70	710400	Low demand
64	Anlima Energy Ltd.	IPP	6*21.2	116	102	2139000	Engine problem
65	Minshaha 150 MW	BPDB-RRCL	18.5*9	0	0	0	On test.
Chattoagram area Total				2382	1079	17593136	
66	Ashuganj TPP Unit-3	APSCCL	1150	0	0	0	Contract Expired
67	Ashuganj TPP Unit-4	APSCCL	1150	0	0	0	Contract Expired
68	Ashuganj TPP Unit-5	APSCCL	1150	134	0	0	Gas shortage
69	Ashuganj 225 MW CCPP	APSCCL	1142*1175	221	162	4684000	FGMO
70	Ashuganj 450 MW CCPP(North)	APSCCL	1360	360	295	7588200	FGMO
71	Ashuganj 450 MW CCPP(South)	APSCCL	1360	360	0	0	Under maint.
72	Ashuganj 420 MW CCPP(East)	APSCCL	284*11*116*1	400	270	7642100	Frequency Control
73	Ashuganj 50 MW PP	APSCCL	143.068	45	43	1038240	
74	Ashuganj 45 MW PP (Precision)	QRPP	15*14	50	50	803620	
75	Ashuganj 195MW PP (APSCCL-United)	IPP	20*9.73*11.6	195	8	217454	Gas shortage
76	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	1110230	
77	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	127	1144145	Low demand
78	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	188976	Low demand
79	Chandpur 150 MW CCPP	PDB	1210*1157	163	0	0	Under maint.
80	Chandpur 200MW (Desh energy)	IPP	12*12.4	200	129	1271520	Low demand
81	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	453780	Engine problem
82	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	9	239760	Engine problem
83	Impoport (Tripura)	Imported power	0	160	126	2777280	
84	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	620900	
85	Jangalia 52 MW PP (Lakshmi)	IPP	6*8.92	52	16	81422	Fuel shortage
86	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67*2*6.97	25	15	295380	Engine problem
87	Daudkandi 200 MW PP (B. Trac)	IPP	15*4.1	200	0	0	Fuel shortage
88	Feni Lanka Power	IPP	7*18.415*19.78	114	25	459420	Low demand
89	Chowmuhani 113 MW	IPP	12*9.78*2*3.1	113	87	1055040	Low demand
90	Bharob 54.5 MW	IPP	3*18.2	54	17	423360	Engine problem
91	Chandpur 115 (Doreen)	IPP	4*18.5*2*22.5	115	72	792960	Fuel shortage
Cumilla Area Total				3285	1574	33067687	
92	RPCL 210MW CCPP	IPP	415*170	202	107	1873920	Gas shortage
93	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	430740	Engine problem
94	Jamalpur 95 MW PP (Powerpac)	IPP	12*8.924	0	0	0	Under maint.
95	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	12100	
96	Mymensingh 200 MW PP (United)	IPP	9*78*21	106	200	1524000	Fuel shortage
97	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	78	963600	Fuel shortage
98	Suliakhali 50 MW Solar PP	IPP	50	50	0	302500	
99	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	6	145920	Engine problem
Mymensingh Area Total				614	316	5252780	
100	Fenchuganj CCPP Phase-1	PDB	2*32*133	70	0	0	Machine problem
101	Fenchuganj CCPP Phase-2	PDB	2*35*135	90	0	27000	Machine problem
102	Kushara 163 MW CCPP (KP)	IPP	1109*1154	163	80	2265709	Sync. at 18:45 & ST.U.M.
103	Shahbazar 330 MW CCPP	PDB	3*110	330	0	0	Under maint.
104	Fenchuganj 51 MW PP (Barakattullah)	RPP	19*2.90	51	0	415800	Engine problem
105	Fenchuganj 44MW (Energyprima)	NENP	12*3.3*5*2	50	0	399672	
106	Haldiganj 11MW PP (Confidence-E)	SIPP, REB	4*2.90	11	8	192384	Engine problem
107	Shahbazar GTTP Unit-1 & 2	PDB	2*35	86	20	571200	GT-9 Under maint.
108	Shahbazar 86MW PP (Shahbazar)	RPP	32*2.90	86	89	1491840	
109	Shahbazar 100 MW GTTP	PDB	1100	100	0	0	Under maint.
110	Sylhet 225 MW CCPP	PDB	1142*1189	231	211	5261580	
111	Sylhet 20 MW GTTP	PDB	120	20	0	22200	
112	Sylhet 50MW PP (EP)	NENP	2*7.2	0	0	0	Gas shortage
113	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	8	114528	Gas shortage
114	Bitiana-II 341 MW CCPP (Summit)	IPP	1222*1119	341	270	684500	FGMO
115	Bitiana-III 400 MW CCPP	PDB	285*1134*1	400	366	8817000	FGMO
116	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	6	107820	Engine problem
117	Bitiana South 400 MW	PDB	400 MW	383	400	9117000	
Sylhet Area Total				2427	1458	35853033	
118	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
119	Bheramara (HVDC)	Imported power	2*500	1000	888	21080727	
120	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	99	532800	Fuel shortage
121	Fardpur 50 MW Peaking PP	PDB	6*8.89	54	0	0	Line O/L
122	Khulna 225 MW CCPP	NWPGCL	1150*1175	230	0	0	Fuel conservation
123	Casapara 100 MW Peaking PP	PDB	16*8.98	109	0	0	Line O/L
124	Bheramara 410 MW CCPP	NWPGCL	1278*1132	410	180	5368896	Gas shortage
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	40	65250	
126	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Fuel shortage
127	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	49	739680	Fuel shortage
128	Madhumati 100 MW PP	NWPGCL	6*18	105	0	0	Line O/L
129	Mongia Orion 100 MW Solar PP	IPP	100	100	0	557280	
130	Khulna 330 MW CCPP (DIL)	BPDB	1220*1110	0	0	0	On test.
131	Rampal 1320 MW (BIFPCL)	NTPCB&PDB	660*2	617	372	8749091	
Khulna Area Total				3001	1628	37093724	
132	Barisal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Line O/L
133	Bhola 33 MW PP (Venture)	NENP	13*4.50	40	19	378700	Engine problem
134	Bhola 225 MW CCPP	PDB	2*63*1168	172	194	4277407	
135	Bhola 95 MW PP (Aggreko)	QRPP	96*11.0	0			