

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023					Day : Saturday				Date : 04.03.23				
Probable Maximum Demand : 11800 MW					Probable Maximum Generation : 13134 MW								
Water Level of Kaptai Lake at 06:00 AM					Yesterday = 79.27 ft				Today = 79.15 ft				
					Rule Curve = 92.25 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.03.23 (Yesterday)		04.03.23 (Today)		03.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	130	130	130	130				
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	0	0	108	Gas Shortage		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage		
6	Haripur GTTP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	309	309	300	300				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	350	380	400	400				
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	12x73+1x139	412	412	322	372	380	380				
11	Siddhirganj 2 nd 120 MW GTTP	Gas (EGCB)	2 x 105	210	210	37	37	110	110	173		Gas Shortage	
12	Siddhirganj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0		335	Under Maint.	
13	Meghnaghat CCPP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	27	150	150	308		Gas Shortage	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.09+1x11.3	55	55	15	32	55	55				
15	Gagnagarj 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	58	58	40	58				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	19	22	22				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	43	45	48	51				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	30	30	30				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	25	25	50				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	52	88	52	88				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	98	32	98				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	146	95	285	285				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	40	50	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Bramhaniganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	17	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	55	17	55				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	45	60	55	72				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	99	17	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	28	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	17	17	17				
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	40	24	40	50				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	49	28	60	60				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	12	67	67				
Dhaka Zone Total					6004	5847	1976	2383	2642	3142	694	1075	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	30	30	30	30		200	Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage	
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	0	17	25				
42	Teknaf 20MW PP (SolarTech)	Solar (IPP)	1x20	20	20	0	20	0	20				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	18	18				
44	Sikalbaha 105 MW PP (Baraka Sikalabaha)	HFO (IPP)	6x18.415	105	105	34	34	34	34				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	221	228	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	116	253	120	260				
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	30	100	88	100				
49	Dohazari-Katish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	32	68	51	68				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	28	0	40	55				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	15	15	15	15	7		Gas Shortage	
*	Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			0	0	0	0				
52	Chattogram 108 MW PP (ICEPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	36	17	36				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54				
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	22	70	100	100				
56	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	44	70	33	33				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	102	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test	
Chattogram Zone Total					2442	2382	810	1079	974	1160	387	330	
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0	134		Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	44	43	44	44				
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1x75	221	221	215	182	190	220				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0	360		Gas Shortage	
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	290	295	360	360				
63	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	401	270	320	320				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	40	50	20	40	5		Gas Shortage	
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'116	195	195	8	8	8	8	187		Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	51	51	51	51				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	33	127	40	150	23		Gas Shortage	
68	Titans 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	2	0	28	30				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	104	129	200	200				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	16	0	16				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	6	15	21	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	86x1.4+6x1.615+1x1.661	200	200	0	0	0	0				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	34	25	17	80				
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	58	87	9	113				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	2	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	24	72	18	72				
**	Impoport (Tripura)	India		160	160	118	126	135	153				
Cumilla Zone Total					3309	3285	1491	1574	1539	1956	709	163	
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	49	107	70	100	95		Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	19	19	19				
83	Jamalpur 115 MW PP (Unitec)	HFO (IPP)	12x9.87	115	115	47	78	40	75				
84	Mymensingh 200 MW PP (Unitec)	HFO (IPP)	21x9.780	200	200	88	106	68	115				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0				
86	Sutikhali 50 MW Solar PP	Solar (IPP)	1x50	50	45	0	50	0	0				
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	6	6	6	6				
Mymensingh Zone Total					622	614	234	316	255	315	95	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	03.03.23 (Yesterday)		04.03.23 (Today)		03.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance				
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date			
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)					
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	0	0	0	0	70	GT-1 & ST-1 Under maint.				
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	0	0	30	30	90	GT-4 Under maint.				
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	0	0	30	30						
91	Kushnara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	80	112	112						
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8						
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	20	32	32						
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0	330	Under maint.				
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	89	89	86	86						
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	210	211	215	215						
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	19	19						
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	0	6	8	8						
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	8	8						
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	270	300	300						
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	368	366	366	367						
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400						
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0	100	Under project work				
104	Fenchuganj 44MW (Energyprime)	Gas (NENP)	12'3.4-5'2	50	50	0	0	30	50						
Sylhet Zone Total					2472	2427	1485	1458	1644	1685	0	644			
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0						
106	Bheramara 410 MW CAPP	Gas (NWP/CL)	1 x 278+1 x 132	410	410	180	180	300	300						
107	Fandpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	38						
108	Gopalgarj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	75						
109	Khulna 225 MW CAPP	HSD (NWP/CL)	1 x 150+1x75	230	230	0	0	0	0						
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0						
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	50	49	56	56						
112	Madhumati 100 MW PP	HFO (NWP/CL)	6x18.415	105	105	0	0	0	50						
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	93	0	100	0						
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	37	99	83	99						
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	0	8	40						
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIF/CL)	1x617	617	617	370	372	400	400						
	Khulna 330 MW CAPP	Gas/HSD (B/PDB)		0	0	0	0	0	0						
**	Bheramara (H/DC) India			1000	1000	885	888	907	907						
Khulna Zone Total					3005	3001	1615	1628	1854	1965	0	0			
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0						
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	16	19	14	20						
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	159	172	160	160						
120	Payra 1320 MW TPP	Coal (BC/CL)	2x622	1244	1244	680	700	700	770						
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	30	100						
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	149	150	150	200						
123	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	217	220	220						
Barisal Zone Total					2265	2265	1224	1258	1274	1470	0	0			
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage				
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Gas Shortage				
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	34	0	30						
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0						
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	0	18	20						
128	Chapainabaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	64	62	62	62						
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	0	32	40						
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	8	0	42	42						
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	14	28	26	35						
132	Siraiganj 225MW CAPP Unit-1	Gas (NWP/CL)	1x150+1x75	210	210	0	0	0	0	210	Gas Shortage				
133	Siraiganj 225MW CAPP Unit-2	Gas (NWP/CL)	1x150 + 1x75	220	220	0	0	0	0	220	Gas Shortage				
134	Siraiganj 225MW CAPP Unit-3	Gas (NWP/CL)	1x141+1x79	220	220	130	130	150	150	90	Gas Shortage				
135	Siraiganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	155	131	400	400	283	Gas Shortage				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	21	22	22						
137	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11						
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	8	8						
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	50	113	77	113						
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	70	90	70	94						
141	Siraiganj 6.55 MW Solar	Solar (NWP/CL)	1x6	6	6	4	0	6	0						
	Adani Power Jharkhand Ltd	Coal		0	0	0	0	0	0						
Rajshahi Zone Total					2129	2129	552	628	924	1027	974	0			
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Coal Shortage				
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85	Under Overhauling				
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74	Coal Shortage				
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	68	99	70	99						
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0						
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0						
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	36	70	35	115						
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	25	0	30	0						
	Teesta Solar Limited	Solar (IPP)				10.4	0	130	0						
Rangpur Zone Total					830	750	437	369	473	414	159	85			
Sub-total: Plants in operation					23078	22700	9824.0	10693	11579	13134	3018	2297			
(B) Plants under long term maintenance/ contract expired															
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0						
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0						
152	Bosilia 108MW PPI(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0						
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0						
154	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022			
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0	0	0			
Gross Total					23482	22700	9824	10693	11579	13134	3018	2297			
(C) Actual data of 03.03.23 (Yesterday) Friday :															
01.	Max. Demand at eve. peak (Generation end)	:		10693 MW, at =	19:00 hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:		10603 MW, at =	19:00 hrs	Zone		Demand MW	Supply MW	Load Shed MW	Zone		Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:		10693 MW, at =	19:00 hrs	Dhaka	3674	3674	0	Mymensingh	965	965	0		
04.	Minimum Generation (Generation end)	:		8203 MW, at =	5:00 hrs	Chattogram	1102	1102	0	Sylhet	385	385	0		
05.	Day-peak Generation (Generation end)	:		9824 MW, at =	12:00 hrs	Khulna	1280	1280	0	Barishal	288	288	0		
06.	Evening-peak Generation (Generation end)	:		10693 MW, at =	19:00 hrs	Rajshahi	1195	1195	0	Rangpur	735	735	0		
07.	Evening Peak Load-shed (Sub-station end)	:		0 MW, at =	19:00 hrs	Cumilla	981	981	0	Total	10603	10603	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:		7915 MW, at =	5:00 hrs	13. Fuel cost :		(a) Gas = 136330098 Taka	(c) Coal = 198949599 Taka	(b) Oil = 461854122 Taka					
09.	Generation shortfall at evening peak due to :	:				14. Maximum Temperature in Dhaka was :		34.2° C							
a)	Gas/LF limitation	:		2659 MW		15. Export through East-West interconnections :		At evening peak-hour : 9824 MW, at 19:00 hrs							
d)	Coal supply Limitation	:		159 MW		Maximum		: 130 MW, at 21:00 hrs							
b)	Low water level in Kaptai lake	:		200 MW		Energy		: 0 MKWh							
c)	Plants under shut down/ maintenance	:		2297 MW		11. Total Gas Supplied : 995.35 MMCFD									
10.	Total Energy (Generation + India Import)	:		229.28 MKWh											
	By Gas = 130.561 MKWh	By Oil =		35.461 MKWh											
	By Coal = 36.533 MKWh	By Hydro =		0.723 MKWh											
	By Solar = 2.148 MKWh														
(D) Forecast of 04.03.23 (Today) Saturday :															
01.	Maximum Demand	:		11800 MW (Generation end)	04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)										
02.	Maximum Generation	:		13134 MW (Generation end)	05. Total Generation : 253.02 MKWh										
03.	Reserve / Shortage	:		1334 MW (Generation end)	06. Probable Max. Temperature in Dhaka : 33.8° C										

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation