

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023				Day : Thursday				Date : 09.03.23				
Probable Maximum Demand : 12600 MW				Probable Maximum Generation : 13729 MW				Rule Curve = 91.72 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 78.67 ft				Today = 78.55 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.03.23 (Yesterday)		09.03.23 (Today)		08.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Water Limitation			Machines shut down (MW)
					Day	Evening	Day	Evening	MW			
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work.	
2	a) Ghorasal Repowered CCGP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	130	130	130	130			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Under maint.	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	52	22	22	22	86	Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	348	342	330	330			
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	400	450	0	Under Maint.	
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling	
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	400	363	400	400			
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	150	115	100	100	95	Gas Shortage	
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	0	335	Under Maint.	
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	0	0	270	270	335	was under Maint.	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.09+1x11.3	55	55	0	30	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	50	24	65			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	16	0	19	19			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	51	50	53	53			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	25	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	32	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	25	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	70	52	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	0	32	115			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	122	280	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	35	142	90	142			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0			
27	Bramhaniganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	17	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	17	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	35	55	55			
32	Manikganj 162MW PR(MPGL)	HFO (IPP)	9x18	162	162	17	162	17	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	12	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	17	17			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	38	40	65			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	22	50	68			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	42	85	85			
Dhaka Zone Total												
			6004	5847	1959	2572	2856	3449	286	1410		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level	
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	140	140	140	140	40	Gas Shortage	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0		Under maint.	
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	17	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	19	19	19	19			
44	Sikalbaha 105 MW PP (Baraka Sikalabaha)	HFO (IPP)	6x18.415	105	105	17	34	34	34			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.	
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	221	224	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	0	15	120	260			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	70	63	80	80			
49	Dohazari-Katash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	82			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	40	40	65			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	12	12	10	Gas Shortage	
52	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34	108	108	1	0	2	2			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	54	17	54			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	53	54	54			
56	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	12	50	80	80			
57	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	22	44	44	44			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	89	107	107	107			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	150	150	0	0	0	0		on test	
Chattogram Zone Total												
			2442	2382	667	956	1092	1308	255	330		
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage	
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	46	46	44	44			
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	216	184	200	210			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360	Gas Shortage	
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	305	290	300	330			
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	320	350	330	350			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	20	54	54	54			
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8	187	Gas Shortage	
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	1	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	142	40	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	29	28	30			
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling	
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	122	100	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	20	21	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	8			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	12	15	15			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+6x1.015+1x1.061	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	17	80			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	113	9	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	18	72	18	72			
**	Impoort (Tripura)	India	160	160	120	140	135	153	153			
Cumilla Zone Total												
			3309	3285	1199	1711	1422	1941	681	163		
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	156	201	130	130	1	Gas Shortage	
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	63	84	40	94			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	55	144	100	150			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	49	0	50	0	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	6	6	6			
Mymensingh Zone Total												
			622	614	341	451	344	396	1	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	08.03.23 (Yesterday)		09.03.23 (Today)		08.03.23 (Yesterday)	09.03.23 (Today)	Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks
					Day	Evening	Day	Evening	Gen. shortfall for :				
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	44	44			GT-1 & ST-1 Under maint.	
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42			GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	25	14	25	25				
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	80	80	112			ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	63	65	64	64				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	40	86	86				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	208	210	210	210				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	8	8	8				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8				
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	275	300	300				
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	367	367	366	366				
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	35	102	260	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprime)	Gas (NENP)	12'3.3-5'2	50	50	43	15	20	20				
Sylhet Zone Total					2472	2427	1366	1296	1539	1711	0	558	
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	320	305	300	300	105		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	38				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	75				
109	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	56	56				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	71	0	100	0				
114	Khulna 115 MW PP (KPL-2)	HFO (NENP)	7x17	115	115	0	66	66	99				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	0	8	40				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	370	368	370	400				
**	Bheramara (H/DC)	Gas/HSD (B/PDB)		1000	1000	880	879	887	899				
Khulna Zone Total					3005	3001	1641	1635	1797	2007	105	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	14	20	20	20				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	147	151	185	185				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	590	640	750	800				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	142	142	150	150				
123	Bhola 220MW CAPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	222	167	220	220				
Barishal Zone Total					2265	2265	1115	1120	1325	1375	0	0	
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	18	33				
128	Chapainabaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	50	50	85				
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	40	32	40				
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	50				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	26	35				
132	Sirajganj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0		210	Gas Shortage	
133	Sirajganj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	130	150	150	175		70	Gas Shortage	
134	Sirajganj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0		220	Gas Shortage	
135	Sirajganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	394	419	380	380				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	16	20	21	21				
137	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	16	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	50	77	113				
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	94	94	50	94				
141	Sirajganj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	5	0	6	0				
Adani Power Jharkhanda Ltd							0	0	0	0			
Rajshahi Zone Total					2129	2129	685	909	871	1077	671	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	201	220	250	73		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	71	99	50	100				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	35	70	35	115				
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	30	0	30	0				
Teesta Solar Limited							106	0	130	0			
Rangpur Zone Total					830	750	448	370	473	465	158	85	
Sub-total: Plants in operation					23078	22700	9421.0	11020	11719	13729	2157	2546	

(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PPL(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
154	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0		
Gross Total					23482	22700	9421	11020	11719	13729	2157	2546

(C) Actual data of 08.03.23 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	:	11040	MW,	at =	19:00	hrs					
02.	Max. Demand at eve. peak (Sub-station end)	:	10472	MW,	at =	19:00	hrs					
03.	Highest Generation (Generation end)	:	11020	MW,	at =	19:00	hrs					
04.	Minimum Generation (Generation end)	:	7839	MW,	at =	6:00	hrs					
05.	Day-peak Generation (Generation end)	:	9421	MW,	at =	12:00	hrs					
06.	Evening-peak Generation (Generation end)	:	11020	MW,	at =	19:00	hrs					
07.	Evening Peak Load-shed (Sub-station end)	:	18	MW,	at =	19:00	hrs					
08.	Minimum Generation Forecast up to 8:00 hrs.	:	8274	MW,	at =	5:00	hrs					
09.	Generation shortfall at evening peak due to :	:										
	a) Gas/LF limitation	:	1794	MW								
	d) Coal supply Limitation	:	158	MW								
	b) Low water level in Kaptai lake	:	205	MW								
	c) Plants under shut down/ maintenance	:	2546	MW								
10.	Total Energy (Generation + India Import)	:	225.64	MKWh								
	By Gas = 139.106	MKWh	By Oil =	25.303	MKWh							
	By Coal = 35.017	MKWh	By Hydro =	0.602	MKWh							
	By Solar = 2.165	MKWh										
11.	Total Gas Supplied	:	1110.89	MMCFD								

(D) Forecast of 09.03.23 (Today) Thursday :												
01.	Maximum Demand	:	12600	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)	
02.	Maximum Generation	:	13729	MW	(Generation end)	05.	Total Generation	:	257.99	MKWh		
03.	Reserve / Shortage	:	1129	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	34.4°	C		

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00 (Md. Helalur Rahman) Deputy Secretary, Generation