

Date : 10-Mar-23

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks	
								Unit No. X Capacity
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1260	260	0	0	Under maint.	
2	Ghorasal Repowered CCGP Unit-4	PDB	1210	180	130	3074000	Gas shortage	
3	Ghorasal TPP Unit-5	PDB	1210	190	180	4284000		
4	Ghorasal 365 MW CCGP Unit-7	PDB	1243*1122	365	0	0	Under maint.	
5	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0		
6	Ghorasal 108MW PP (Regent)	IPP	343.35	108	52	969727	Gas shortage	
7	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.	
8	Haripur 412 MW CCGP	EGCB	1273*1139	412	328	9336830	Gas shortage	
9	Haripur 360MW CCGP(HPL)	IPP	1235*1125	360	306	7634000	Gas shortage	
10	Meghnaghat 450 MW CCGP(MPL)	IPP	2150*1150	450	450	9197000		
11	Meghnaghat 100 MW(IEI)	NENP	12'9.9	100	7	52800	low demand.	
12	Meghnaghat CCGP(Summit)	IPP	2110*1110	335	260	10864029	Gas shortage	
13	Madanaghat 102 PP(Summit)	NENP	6117	102	17	99974	low demand.	
14	Madanaghat-55 MW PPS(Summit)	IPP	317.08*111.3	55	15	147439	low demand.	
15	Keraniganj 100 MW PP (Powerpac)	QRPP	813.45	0	0	0	Contract Expired	
16	Narsingdi 22 MW PP (Doreen)	SIPP, REB	82.90	22	22	463140		
17	210 MW Siddhirgonj TFP	PDB	1210	115	0	0	Under maint.	
18	Siddhirgonj 2120 MW GTTP	EGCB	2165	210	100	3044000	Gas shortage	
19	Siddhirgonj 100 PP(Dutch) Bangla	NENP	129.9	100	8	67200	low demand.	
20	Siddhirgonj 335 MW CCGP	EGCB	1217+118	335	0	35545	Gas shortage	
21	Gagnagar 102 MW PP (Digital Power)	IPP	128.924	102	40	121536	low demand.	
22	Kalipoti 52 MW PP (Siraha)	IPP	77.9	0	0	0	Fuel shortage	
23	Kamalaghat 54 MW PP(Banco Energy)	IPP	318	54	35	156600	Fuel shortage	
24	Kodda 150 MW PP	BPDB-RRCL	917.06	149	64	692160	low demand.	
25	Manikganj 55 MW PP (Northern)	IPP	319.3	55	17	146996	Engine problem	
26	Nabaganj 55 MW PP (Southern power)	IPP	319.3	55	55	398040		
27	Boisla 108MW PP(CLC)	IPP	128.775+113.5	0	0	0		
28	Summit Power (Madhabdi+Ashulia)	SIPP, REB	33.67+48.73	80	49	1083600	Engine problem	
29	Madona 33 MW PP(Summit)	SIPP, REB	48.73	33	33	775100		
30	Ruaganj 33 MW PP(Summit)	SIPP, REB	48.73	33	25	691000	Engine problem	
31	Gazipur 52 MW PP	RPCL	69.9	52	40	261120	Low demand.	
32	Tongi 80 MW GTTP	PDB	1'105	105	0	0	Under maint.	
33	Kodda 300 MW PP Unit-2 (Summit)	IPP	1817.076	300	90	416508	Low demand.	
34	Keraniganj 300 MW PP (APR)	IPP	2567.4	300	0	0	Fuel shortage	
35	Bramhanaga 100 MW PP (Aggreko)	IPP	1149.959	100	0	0	Fuel shortage	
36	Aurahat 100MW PP (Aggreko)	IPP	0.8523+0.9591	100	0	0	Fuel shortage	
37	Kodda 149 MW PP Unit-1 (Summit)	IPP	818.45+8.97	149	85	1936800	low demand.	
38	Gazipur 100 MW PP	RPCL	617.5	105	80	723840	low demand.	
39	Meghnaghat 104 MW PP (OPCL)	IPP	18.56	104	13	120960	low demand.	
40	Manikganj 162MW PP(MPGL)	IPP	918	162	72	444960	low demand.	
41	Spectro Solar Plant Ltd.	IPP	35	0	35	0	127439	
42	Kanchan Flutbachtal Power Generation Ltd.	IPP	18.43	55	17	228990	Fuel shortage	
Dhaka area Total				5847	2600	57888603		
43	Chattoagram TPP-1	PDB	1210	180	140	3300000	Gas shortage	
44	Chattoagram TPP-2	PDB	1210	180	0	0	Gas shortage	
45	Raozan 25 MW PP	RPCL	39.9	25	17	112876		
46	Tanai 20MW PP (Solaritech)	IPP	20	20	0	133380	Gas shortage	
47	Palenga 50MW PP (Baraka)	IPP	69.98	50	19	473760	Fuel shortage	
48	Kaptai Hydro Unit-1,2,3,4, 5	PDB	240*350	230	25	602760	Low water level	
49	Sikalbaha 225MW	PDB	1150*175	225	228	5296646		
50	Sikalbaha Peaking GT	PDB	1150	150	0	0	Under maint.	
51	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	617.5	105	34	853927	Fuel shortage	
52	Hathazari 100 MW peaking PP	PDB	119.9	102	0	0	Reserve.	
53	Dohazari -Kalaish 100 MW Peaking	PDB	617	102	51	120125	Low demand.	
54	Juldah 100 MW Unit-1 (Accom)	NENP	813.45	100	70	783360	Fuel shortage	
55	Juldah 100 MW PP Unit-3 (Accom)	IPP	813.5	100	100	1332480		
56	Barabkundia 22 MW PP (Regent)	SIPP, PDB	62.90	22	9	255840	Gas shortage	
57	Madarochi Cst. EPZ (United)	IPP	58.73*9.34	0	0	0	11520	
58	Chattoagram 108 MW PP (ECPV)	IPP	167	108	0	0	Fuel shortage	
59	Kaptai 7 MW Solar PP	PDB	7.4 MW	7	0	21121		
60	Anwara 300 MW PP (United)	IPP	1717+24	300	165	343745	High voltage	
61	Jodiach Power	IPP	318.55+113.6	54	48	683202	Engine problem	
62	Kamaphuli Power Ltd.	IPP	18.4156+8.5	110	43	989414	Fuel shortage	
63	Juldah unit (Accom)	IPP	813.5	100	86	505620	Low demand.	
64	Anlima Energy Ltd.	IPP	621.2	116	90	1846691	Engine problem	
65	Minshahi 150 MW	BPDB-RRCL	18.59	0	0	0	On test.	
Chattoagram area Total				2382	1123	17646767		
66	Ashuganj TPP Unit-3	APSCCL	1150	0	0	0	Contract Expired	
67	Ashuganj TPP Unit-4	APSCCL	1150	0	0	0	Contract Expired	
68	Ashuganj TPP Unit-5	APSCCL	1150	134	0	0	Gas shortage	
69	Ashuganj 225 MW CCGP	APSCCL	1142+175	221	190	4489000	Gas shortage	
70	Ashuganj 450 MW CCGP(North)	APSCCL	1360	360	280	7264500	Gas shortage	
71	Ashuganj 450 MW CCGP(South)	APSCCL	1360	360	0	0	Under maint.	
72	Ashuganj 420 MW CCGP(East)	APSCCL	2841+1161	400	320	7480300	Gas shortage	
73	Ashuganj 50 MW PP	APSCCL	143.068	45	48	1141272		
74	Ashuganj 45 MW PP (Precision)	QRPP	1514	55	53	1283040		
75	Ashuganj 195MW PP (APSCCL-United)	IPP	209.73+116	195	8	217454	Gas shortage	
76	Ashuganj 51 MW PP (Midland)	IPP	69.34	51	43	1028565	Engine problem	
77	Ashuganj 150MW PP (Midland)	IPP	237.015	150	52	277672	Engine problem	
78	Titas 50 MW Peaking PP	PDB	68.92	52	0	0	Engine problem	
79	Chandpur 150 MW CCGP	PDB	1106+157	163	0	0	Under maint.	
80	Chandpur 200MW (Desh energy)	IPP	1212.4	200	104	1659840	Engine problem	
81	Feni 22MW PP (Doreen)	SIPP, PDB	82.90	22	20	482888		
82	Feni 11 MW PP (Doreen)	SIPP, REB	42.90	11	10	238680		
83	Imported (Tripura)	Imported power	0	160	134	2853120		
84	Jangalia 33MW PP (Summit)	SIPP, PDB	48.73	33	33	813100		
85	Jangalia 55 MW PP (Lakshmi)	IPP	69.92	52	14	53823		
86	Cumilla 25 MW PP (Summit)	SIPP, REB	33.67+26.97	25	15	369550	Fuel shortage	
87	Daudkandi 200 MW PP (B.Trac)	IPP	1541.4	200	0	0	Engine problem	
88	Feni Lanka Power	IPP	718.415+19.78	114	17	120840	High voltage	
89	Chowmuhani 113 MW	IPP	129.78+23.1	113	34	461160	High voltage	
90	Bharoh 54.5 MW	IPP	318.2	54	17	305940	Engine problem	
91	Chandpur 115 (Doreen)	IPP	418.5+22.5	115	72	866720	Fuel shortage	
Cumilla Area Total				3285	1464	31426074		
92	RPCL 210MW CCGP	IPP	4156+170	202	86	1911360	Gas shortage	
93	Tangal 22 MW PP (Doreen)	SIPP, PDB	82.90	22	17	368208	Engine problem	
94	Jamalpur 95 MW PP (Powerpac)	IPP	128.924	0	0	0	Under maint.	
95	Sarishabari 3 MW Solar Plant	IPP	13	0	0	12700		
96	Mymensingh 200 MW PP (United)	IPP	978921	152	200	2443200	Fuel shortage	
97	Jamalpur 115 MW PP (United)	IPP	97812	115	94	1309200	Fuel shortage	
98	Suliakhali 50 MW Solar PP	IPP	50	50	0	246070		
99	Tangal Pali Power Gen 22 MW	IPP	46.7	22	6	26400	Engine problem	
Mymensingh Area Total				614	355	6317138		
100	Fenchuganj CCGP Phase-1	PDB	232+133	70	44	1020000	Machine problem	
101	Fenchuganj CCGP Phase-2	PDB	235+135	42	42	663040	Machine problem	
102	Kushihara 163 MW CCGP (KP)	IPP	1109+154	163	112	2152800	ST U/M	
103	Shahjibazar 330 MW CCGP	PDB	3110	330	0	0	Under maint.	
104	Fenchuganj 51 MW PP (Barakatullah)	RPP	192.90	51	53	790800		
105	Fenchuganj 44MW (Energyprima)	NENP	123.3+52	50	50	887760		
106	Haldiganj 14MW PP (Confidence-E)	SIPP, REB	42.90	11	9	162294	Engine problem	
107	Shahjibazar GTTP Unit-3 & 9	PDB	235	86	85	1377120		
108	Shahjibazar 86MW PP (Shahjibazar)	RPP	322.90	86	84	1400640		
109	Shahjibazar 100 MW GTTP	PDB	1100	100	0	0	Under maint.	
110	Sylhet 225 MW CCGP	PDB	1142+189	231	207	5180270	Machine problem	
111	Sylhet 20 MW GTTP	PDB	120	20	18	430000		
112	Sylhet 50MW PP (EP)	NENP	272	0	0	0	Gas shortage	
113	Shahjahanulla 25 MW PP	SIPP, REB	39.34	25	8	180912	Gas shortage	
114	Bitiyana-II 341 MW CCGP (Summit)	IPP	1222+1119	341	285	6940000	FGMO	
115	Bitiyana-III 400 MW CCGP	IPP	2851+1341	400	367	8886000	FGMO	
116	Sylhet 10MW PP (Desh)	RPP	61.95	10	8	187020	Engine problem	
117	Bitiyana South 400 MW	PDB	400 MW	383	384	9316400		
Sylhet Area Total				2427	1735	39914946		
118	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage	
119	Bheramara (HVDC)	Imported power	2500	1000	753	20429818		
120	Khulna 115 PP MW (KPCL-2)	NENP	717	115	10	115200	Low demand.	
121	Fariapur 50 MW Peaking PP	PDB	69.89	54	0	0	Reserve.	
122	Khulna 225 MW CCGP	NWPGCL	1150+175	230	0	0	Fuel conservation	
123	Casapora 100 MW Peaking PP	PDB	169.98	100	0	0	Reserve.	
124	Bheramara 410 MW CCGP	NWPGCL	1278+1132	410	0	3695000	Gas shortage	
125	Noapara 40 MW PP (Khanjahan Ali)	NENP	59.5	40	0	0	Fuel shortage	
126	Noapara 100 MW PP (Bangla Trac)	IPP	701.4	100	0	0	Reserve.	
127	Rupsha 105 MW PP (Orion rupsha)	IPP	618.445	105	17	68640	Low demand.	
128	Madhumati 100 MW PP	NWPGCL	618	105	0	0	Transformer OIL	
129	Mongia Orion 100 MW Solar PP	IPP	100	100	0	445880		
130	Khulna 330 MW CCGP (OIL)	BPDB	1220+1110	0	0	0	On test.	
131	Rampal 1320 MW (BIFPCL)	NTPCB&PDB	6602	617	369	8865455		
Khulna Area Total				3001	1149	33534293		
132	Barisal 110 MW PP (Summit)	IPP	717.076	110	0	0	Line O/L	
133	Bhola 33 MW PP (Venture)	NENP	134.50	20	20	367900	Engine problem	
134	Bhola 225 MW CCGP	PDB	2831+168	194	158	4125572		
135	Bhola 95 MW PP (Aggreko)	QRPP	961.10	0	0	0	Contract Expired	
136	Payra 1320 MW	BCPCL	2622	1244	800			