

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023				Day : Saturday				Date : 11.03.23				
Probable Maximum Demand : 12000 MW				Probable Maximum Generation : 13546 MW				Rule Curve = 91.40 ft.				
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 78.31 ft				Today = 78.16 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.03.23 (Yesterday)		11.03.23 (Today)		10.03.23 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)	Probable Peak Generation (MW)	Actual Peak Generation (MW)	Probable Peak Generation (MW)	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)		
					Day	Evening	Day	Evening	Gen. shortfall for :		Description/ Remarks	Probable start-up date
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work.
2	a) Ghorasal Repowered CCGP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	130	130	130	130			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0		365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	51	52	52	52		56	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0		105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	337	306	300	330			
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450			
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	400	338	350	400			
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	181	100	80	80		110	Gas Shortage
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	0	150		335	Under Maint.
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	152	260	250	290			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	15	55	55			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	32	40	16	65			
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	19	22			
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	42	49	53	53			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	25	33	33			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	16	40	25	50			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	80	52	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	82	64	98	115			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	2	90	280	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	118	85	90	142			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0			
27	Bramhaniganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	55	17	55			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	5	17	17	55			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	6	13	55	72			
32	Manikganj 162MW PR(MPGL)	HFO (IPP)	9x18	162	162	8	72	17	162			
33	Manikganj 35MW Solar PP (Inspectra Soler Ltd.)	Solar (IPP)	1x35	35	35	9	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	12	17	17	17			
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	6	8	40	92			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	7	50	68			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	17	85	85			
Dhaka Zone Total				6004	5847	2312	2600	2874	3676	271	1075	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25		205	Low water level
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	140	140	140	140		40	Gas Shortage
40	Kaptai 7 MW Solar PP	Solar (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	17	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	19	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	20	19	20	20			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	34	34	34	34			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	220	226	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	15	165	120	260			
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	25	100	80	100			
49	Dohazari-Katish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	51	82			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	40	65			
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	9	10	10		13	Gas Shortage
52	* Malancha, Ctg, EPZ (United)	Gas	5x8.73+3x9.34	108	108	0	0	0	0			
53	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	0	0			
54	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	48	17	54			
55	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	43	54	54			
56	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	0	86	80	86			
57	Juldah 100 MW Unit-1 (Acorn)	HFO (QRPP)	8x13.45	100	100	11	70	44	44			
58	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	17	90	107	107			
59	Mirsharai 150 MW	HFO (BRPgen)	9x18.5	150	150	0	0	0	0			on test
Chattogram Zone Total				2442	2382	576	1123	1089	1331	258	330	
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0		134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	50	45	44	48	44	44			
60	Ashuganj 225 MW CCGP	Gas (APSCl)	1x142+1*75	221	221	188	190	200	200			
61	Ashuganj 450 MW CCGP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0		360	Gas Shortage
62	Ashuganj 450 MW CCGP(North)	Gas (APSCl)	1x361	360	360	325	280	300	300			
63	Ashuganj 420 MW CCGP(East)	Gas (APSCl)	1x284+1x116	400	400	337	320	320	320			
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	52	53	20	20			
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8		187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	43	43	43	43			
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	52	40	150			
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	50	50	0	0	28	30			
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	104	100	200			
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	21	20	21	21			
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	10	10	10			
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33			
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	14	0	14			
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	15	15	15			
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+6x1.015+1x1.061	200	200	0	0	0	0			
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	17	17	80			
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	34	9	113			
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17			
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	34	72	18	72			
**	Impoport (Tripura)	India		160	160	126	134	135	153			
Cumilla Zone Total				3309	3285	1277	1464	1378	1843	681	163	
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	69	86	94	94			Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	16	16	16			
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	85	94	95	94			
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	85	152	150	150			
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	0	0	50	0			
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	6	6	6			
Mymensingh Zone Total				622	614	307	355	413	360	116	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	10.03.23 (Yesterday)		11.03.23 (Today)		10.03.23 (Yesterday) Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening					
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	44	44	44	44		26	GT-1 & ST-1 Under maint.	
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	30	42		48	GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	46	53	53	53				
91	Kushnara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	80	112			ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	65	65	65				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	84	86	86				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	206	207	210	210				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	8	8				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	8	8	8	17		Gas Shortage	
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	300	285	300	300				
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	385	367	366	366				
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	384	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
104	Fenchuganj 44MW (Energyprime)	Gas (NENP)	12*3.4-5*2	50	50	44	50	50	50				
Sylhet Zone Total					2472	2427	1766	1735	1726	1770	17	558	
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	160	0	0	0	410		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	0	38				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	75				
109	Khulna 225 MW CAPP	HSD (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	56	56				
112	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	0	0	0				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	67	0	100	0				
114	Khulna 115 MW PP (KPL-2)	HFO (NENP)	7x17	115	115	16	10	66	99				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	8	8				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	368	369	370	370				
**	Bheramara (H/DC) India	Gas/HSD (B/PDB)		1000	1000	873	753	888	888				
Khulna Zone Total					3005	3001	1484	1149	1488	1634	410	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	0	0				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	14	20	20	20				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x88	194	194	171	158	185	185				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	630	800	750	800				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	143	160	150	150				
123	Bhola 220MW CAPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	101	220	220				
Barishal Zone Total					2265	2265	1178	1239	1325	1375	0	0	
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	24	0	32				
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	18	33				
128	Chapainabaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	15	50	85				
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	16	32	40				
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	50				
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	26	35				
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	0	0	0	0	210		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	140	158	200	200	62		Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	383	353	400	400				
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	20	22	22				
137	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	8	8				
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	70	77	113				
140	Bagura 113 MW (Confidence) U-2	HFO (IPP)	6x18.55	113	113	17	92	50	113				
141	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	3	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				0	154	0	0				
Rajshahi Zone Total					2129	2129	606	945	942	1142	663	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	200	200	200	74		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	85	100	50	100				
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
147	Majpara, Tabulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	35	115				
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	30	0				
	Teesta Solar Limited	Solar (IPP)				117	0	130	0				
Rangpur Zone Total					830	750	442	335	453	415	159	85	
Sub-total: Plants in operation					23078	22700	9948.0	10945	11688	13546	2575	2211	
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0				
152	Bosilia 108MW PPL(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0			Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0	0	0	
Gross Total					23482	22700	9948	10945	11688	13546	2575	2211	
(C) Actual data of 10.03.23 (Yesterday) Friday :													
01.	Max. Demand at eve. peak (Generation end)	: 10978 MW, at = 19:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 10801 MW, at = 19:00 hrs		Zone Demand Supply Load Shed Zone Demand Supply Load Shed									
03.	Highest Generation (Generation end)	: 10945 MW, at = 19:00 hrs		Dhaka 3788 3788 0 Mymensingh 1033 1003 30									
04.	Minimum Generation (Generation end)	: 8757 MW, at = 5:00 hrs		Chattogram 1096 1096 0 Sylhet 395 395 0									
05.	Day-peak Generation (Generation end)	: 9948 MW, at = 12:00 hrs		Khulna 1261 1261 0 Barishal 280 280 0									
06.	Evening-peak Generation (Generation end)	: 10945 MW, at = 19:00 hrs		Rajshahi 1179 1179 0 Rangpur 776 776 0									
07.	Evening Peak Load-shed (Sub-station end)	: 30 MW, at = 19:00 hrs		Cumilla 993 993 0									
08.	Minimum Generation Forecast up to 8:00 hrs.	: 8379 MW, at = 5:00 hrs		Total 10801 10771 30									
09.	Generation shortfall at evening peak due to :	Total 10801 10771 30											
	a) Gas/LF limitation	: 2211 MW		13. Fuel cost : (a) Gas = 166270244 Taka (c) Coal = 194067152 Taka									
	d) Coal supply Limitation	: 159 MW		(b) Oil = 320646749 Taka Total = 680984145 Taka									
	b) Low water level in Kaptai lake	: 205 MW		14. Maximum Temperature in Dhaka was : 31.6° C									
	c) Plants under shut down/ maintenance	: 2211 MW		15. Export through East-West interconnections :									
10.	Total Energy (Generation + India Import)	: 242.59 MKWh		At evening peak-hour : 9948 MW, at 19:00 hrs									
	By Gas = 152.121 MKWh	By Oil = 24.822 MKWh		Maximum : 22 MW, at 18:30 hrs									
	By Coal = 39.618 MKWh	By Hydro = 6.603 MKWh		Energy : 0 MKWh									
	By Solar = 2.145 MKWh												
11.	Total Gas Supplied	: 1117.30 MMCFD											
(D) Forecast of 11.03.23 (Today) Saturday :													
01.	Maximum Demand	: 12000 MW (Generation end)		04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
02.	Maximum Generation	: 13546 MW (Generation end)		05. Total Generation : 265.98 MKWh									
03.	Reserve / Shortage	: 1546 MW (Generation end)		06. Probable Max. Temperature in Dhaka : 34.7° C									

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation