

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCPP-Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1210	180	100	242638	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1243+1122	365	0	0	Under maint.
4	Ghorasal 78.5 MW PP(MAX)	QRPP	240	0	0	0	
5	Ghorasal 108MW PP (Regent)	IPP	34.3.35	108	12	210136	Gas shortage
6	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
7	Haripur 412 MW CCPP	EGCB	1273+1139	412	393	871040	Gas shortage
8	Haripur 360MW CCPP(HPL)	IPP	1235+1125	360	346	733200	Gas shortage
9	Meghnaghat 450 MW CCPP(MPL)	IPP	2150+1150	450	360	8947500	Gas shortage
10	Meghnaghat 100 MW(IEI)	NENP	12*9	100	17	15360	Low demand
11	Meghnaghat CCPP(Summit)	IPP	2110+1110	335	273	6002342	FGMO
12	Madaniganj 102 PP(Summit)	NENP	6*17	102	20	53022	Low demand
13	Madaniganj-55 MW PPS(Summit)	IPP	3*17.08+111.3	55	55	94355	
14	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	287136	
16	210 MW Siddhirganj TPP	PDB	1210	115	0	0	Under maint.
17	Siddhirganj 210 MW GTTP	EGCB	2105	210	0	970000	Gas shortage
18	Siddhirganj 100 PP(Dutch) Bangla	NENP	12*8	100	8	26880	Low demand
19	Siddhirganj 335 MW CCPP	EGCB	1217+118	335	234	4439002	ST U/M.
20	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	24	31680	Low demand
21	Katipoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
22	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	54	433800	
23	Kodda 150 MW PP	BPOB-RPCL	9*17.06	149	16	656640	Low demand
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	195660	Low demand
25	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	35	128955	Low demand
26	Bosila 108MW PP(CLC)	IPP	12*8.775+1*3.5	0	0	0	
27	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	47	1143300	Engine problem
28	Madhabdi 33 MW PP(Summit)	SIPP, REB	4*8.73	33	0	371600	Engine problem
29	Ruaganj 300 MW PP(Summit)	SIPP, REB	4*18.73	28	28	656100	Engine problem
30	Gazipur 52 MW PP	RPCL	6*8.9	52	42	297120	Engine problem
31	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	15	57709	Low demand
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Fuel shortage
34	Bramhanaga 100 MW PP (Aggreko)	IPP	11*19.959	100	0	0	Fuel shortage
35	Auraha 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Fuel shortage
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	149	837360	
37	Gazipur 100 MW PP	RPCL	6*17.5	105	52	173760	Low demand
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	68	274560	Low demand
39	Manikganj 162MW PP(MPGL)	IPP	9*18	162	35	109440	Low demand
40	Spectro Solar Plant Ltd.	IPP	35	35	0	142856	
41	Kanchan Furtbachal Power Generation Ltd.	IPP	18.4*3	55	35	281880	Fuel shortage
Dhaka area Total				5847	2655	50615311	
41	Chattoagram TPP-1	PDB	1210	180	140	330000	Gas shortage
42	Chattoagram TPP-2	PDB	1210	25	0	0	Gas shortage
43	Raozan 25 MW PP	RPCL	3*8.9	180	0	0	Reserve.
44	Takani 20MW PP (Solartech)	IPP	20	20	0	81135	
45	Palanga 50MW PP (Baraka)	IPP	8*6.98	50	19	452640	Fuel shortage
46	Kapila Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	0	0	Under shut down
47	Sikalbaha 225MW	PDB	1150+175	225	227	5264910	
48	Sikalbaha Peaking GT	PDB	1150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	68	980217	Fuel shortage
50	Hathazari Cto. EPZ Unit-2	PDB	11*9.9	98	0	0	Reserve problem
51	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	17	57851	Low demand
52	Juldah 100 MW Unit-1 (Accorn)	NENP	8*13.45	100	54	390960	Low demand
53	Juldah 100 MW Unit-3 (Accorn)	IPP	8*13.5	100	90	1296000	Engine problem
54	Barabkunda 22 MW PP (Regent)	SIPP, PDB	8*2.90	22	5	116544	Gas shortage
55	Manandha Cto. EPZ Unit-1	IPP	5*8.73+9.34	0	0	0	102240
56	Chattoagram 108 MW PP (ECPV)	PDB	16*7	108	0	0	Fuel shortage
57	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	6121	
58	Anwara 300 MW PP (United)	IPP	17*17+24	300	65	348764	Low demand
59	Jodiach Power	IPP	3*18.55+1*3.6	54	36	399163	Fuel shortage
60	Kanaphuli Power Ltd.	IPP	18.45*6+8.5	110	72	1110686	Fuel shortage
61	Juldah unit-1 (Accorn)	IPP	8*13.5	90	90	463680	Engine problem
62	Anlima Energy Ltd.	IPP	6*21.2	116	107	2450127	Engine problem
63	Minsharai 150 MW	BPOB-RPCL	18.5*9	0	0	0	On test.
Chattoagram area Total				2382	990	16821038	
61	Ashuganj TPP Unit-3	APSCL	1150	0	0	0	Contract Expired
62	Ashuganj TPP Unit-4	APSCL	1150	0	0	0	Contract Expired
63	Ashuganj TPP Unit-5	APSCL	1150	134	0	0	Gas shortage
64	Ashuganj 225 MW CCPP	APSCL	1142+175	221	182	4492000	FGMO
65	Ashuganj 450 MW CCPP(North)	APSCL	1360	360	310	7480000	FGMO
66	Ashuganj 450 MW CCPP(South)	APSCL	1360	360	0	0	Under maint.
67	Ashuganj 420 MW CCPP(East)	APSCL	284*1+116*1	400	358	7874600	FGMO
68	Ashuganj 50 MW PP	APSCL	143.968	45	51	860184	
69	Ashuganj 50 MW PP (Precision)	QRPP	15*4	55	35	641760	Gas shortage
70	Ashuganj 195MW PP (APSCL-United)	IPP	20*9.73+11*6	195	8	217454	Gas shortage
71	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	51	893506	
72	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	10	92000	Low demand
73	Titas 50 MW Peaking PP	PDB	6*8.92	50	0	0	Reserve.
74	Chandpur 150 MW CCPP	PDB	11*106+157	163	0	0	Under maint.
75	Chandpur 200MW (Desh energy)	IPP	12*12.4	200	100	843360	Fuel shortage
76	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	0	0	
77	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	11	166680	
78	Impoport (Tripura)	Imported power	0	160	104	2188800	
79	Jangjala 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	818000	
80	Jangjala 50 MW PP (Lakshmi)	IPP	6*9.92	52	8	48547	
81	Cumilla 25 MW PP (Summit)	SIPP, REB	33.67+2*6.97	25	21	401010	Fuel shortage
82	Daudkandi 200 MW PP (B.Trac)	IPP	15*4.1	200	0	0	Fuel shortage
83	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	17100	Fuel shortage
84	Chowmuhanj 113 MW	IPP	12*9.78+2*3.1	113	105	407400	Engine problem
85	Bharoid 54.5 MW	IPP	3*18.2	54	0	0	Engine problem
86	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	84	1333840	Engine problem
Cumilla Area Total				3285	1481	28766241	
87	RPCL 210MW CCPP	IPP	41*56+170	202	89	1448640	Gas shortage
88	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	276516	Engine problem
89	Jamalpur 95 MW PP(Powerpac)	IPP	12*8.924	0	0	0	Under maint.
90	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	7850	
91	Mymensingh 200 MW PP (United)	IPP	9*78*21	16	200	612000	High voltage
92	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	77	1084800	High voltage
93	Suliakhali 50 MW Solar PP	IPP	50	50	0	185250	
94	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	6	100320	Engine problem
Mymensingh Area Total				614	207	3715376	
91	Fenchuganj CCPP Phase-1	PDB	2*32+133	70	43	1019000	Machine problem
92	Fenchuganj CCPP Phase-2	PDB	2*35+135	90	42	659880	Machine problem
93	Kushkhara 163 MW CCPP (KP)	IPP	1109+1154	163	112	2273236	ST U/M.
94	Shahjibazar 330 MW CCPP	PDB	3*110	330	0	0	Under maint.
95	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	53	690600	
96	Fenchuganj 44MW (Energyprima)	NENP	12*3.3+5.2	50	47	661392	
97	Haldiganj 1 MW PP Confidence-E	SIPP, REB	4*2.90	11	3	79528	Engine problem
98	Shahjibazar GTTP Unit-1 & 9	PDB	2*35	86	85	122928	
99	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	89	1017600	
100	Shahjibazar 100 MW GTTP	PDB	1100	100	0	0	Under maint.
101	Sylhet 225 MW CCPP	PDB	1142+189	231	0	1308560	Under maint.
102	Sylhet 20 MW GTTP	PDB	120	20	0	0	Engine problem
103	Sylhet 50MW PP (EPZ)	NENP	27*2	0	0	0	Gas shortage
104	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	8	178608	Gas shortage
105	Bitiyana-II 341 MW CCPP (Summit)	IPP	1222+1119	341	260	6789500	FGMO
106	Bitiyana-III 400 MW CCPP	PDB	285*1+134*1	400	382	8621000	FGMO
107	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	8	144900	Engine problem
108	Bitiyana South 400 MW	PDB	400 MW	383	395	9001200	
Sylhet Area Total				2427	1507	33965832	
107	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
108	Bheramara (HVDC)	Imported power	2500	1000	782	20317090	
109	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	0	0	Reserve.
110	Fariapur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Reserve.
111	Khulna 225 MW CCPP	NWPGCL	1150+175	230	0	0	Fuel conservation
112	Cazipara 100 MW Peaking PP	PDB	10*9.98	100	0	0	Reserve.
113	Bheramara 410 MW CCPP	NWPGCL	1278+1132	410	300	7929792	Gas shortage
114	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	0	0	Reserve.
115	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Reserve.
116	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	0	0	Reserve.
117	Madhumati 180 MW PP	NWPGCL	6*18	105	0	0	Transformer OIL
118	Mongia Orion 100 MW Solar PP	IPP	100	100	0	425520	
119	Khulna 330 MW CCPP (DIL)	BPDB	1220+1110	0	0	0	On test.
120	Rampal 1320 MW (BIFPCL)	NTPCB&BPDB	660*2	617	0	0	Machine problem
121	Khulna 225 MW CCPP (GAS)	NWPGCL	0	0	0	0	
Khulna Area Total				3001	1082	28672402	
117	Baisaal 110 MW PP (Summit)	IPP	7*17.076	110	0	0	Line O/L
118	Bhola 33 MW PP (Wattare)	NENP	1*34.50	23	40	390400	Engine problem
119	Bhola 225 MW CCPP	PDB	2*63+168	194	160	3861428	
120	Bhola 95 MW PP (Aggreko)	QRPP	96*1.10	0	0	0	Contract Expired
121	Payra 1320 MW	BCPCL	2*622	1244	620	14947800	Line O/L
122	Bhola Nutan Biddut BD LTD	IPP	220	220	0	0	Under maint.
123	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Line O/L
124	Baisaal 307 MW	BCPCL	307*1	307	153	3433600	
Barisal Area Total				2265	856	22462228	
124	Baghabari 71 MW GTTP	PDB	1*71	71	0	0	Gas shortage
125	Baghabari 100 MW GTTP	PDB	1100	100	0	0	Gas shortage
126	Baghabari 50 MW Peaking PP	IPP	6*8.9	52	0	0	Reserve.
127	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Reserve.
128	Annura 50 MW PP(Sinha)	QRPP	7*7.9	50	0	0	Contract Expired
129	Katakhal 50 MW PP (Northern)	QRPP	6*8.9	50	0	0	Reserve.
130	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	0	0	Reserve.
131	Sirajgonj Unit-1 225MW	NWPGCL	1150+175	210	214	3782436	
132	Sirajgonj Unit-2 225MW	NWPGCL	1150+175	220	0	0	
133	Sirajgonj Unit-3 225MW	NWPGCL	1141	220	0	0	Gas shortage
134	Sirajgonj 400 MW CCPP Unit-4	NWPGCL	1262+1132	414	370	7025454	Gas shortage
135	Santahar 50 MW Peaking PP	PDB	6*8.7	50	0	375230	Reserve.
136	Bogra 22 MW PP (GBB)	RPP	6*4	22	21	284160	
137	Bogra 20 MW PP (Energyprima)	NENP	5*3.3+5.2	0	0	0	
138	Ulipara 11 MW PP (Summit)	SIPP, REB	4*2.90	11	11	167148	