

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
				Unit No. X Capacity	MW	MW	
1	Ghorasal Repowered CCPP Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCPP Unit-4	PDB	1210	180	64	1216800	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1243+1122	365	0	0	Under maint.
4	Ghorasal 78.5 MW PP (MAX)	QRPP	240	0	0	0	
5	Ghorasal 108MW PP (Regent)	IPP	343.35	108	76	1476181	Gas shortage
6	Haripur GTPP	SBU, PDB	232	20	0	0	Under maint.
7	Haripur 412 MW CCPP	EGCB	1273+1139	412	360	9236480	Gas shortage
8	Haripur 360MW CCPP(HPL)	IPP	1235+1125	360	303	7342000	Gas shortage
9	Meghnaghat 450 MW CCPP(MPL)	IPP	2150+1150	450	350	8755750	Gas shortage
10	Meghnaghat 100 MW (IEL)	NENP	12'9	100	90	630720	Engine problem
11	Meghnaghat CCPP(Summit)	IPP	2110+1110	335	263	6555084	FGMO
12	Madaniganj 102 PP(Summit)	NENP	6'17	102	73	977187	Engine problem
13	Madaniganj-55 MW PPS(Summit)	IPP	3'17.08+111.3	55	55	234807	
14	Keraniganj 100 MW PP (Powerpac)	QRPP	8'13.45	0	0	0	Contract Expired
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8'2.90	22	22	306468	
16	210 MW Siddhirganj TPP	PDB	1'210	115	0	0	Under maint.
17	Siddhirganj 2'120 MW GTPP	EGCB	2'105	210	0	0	Gas shortage
18	Siddhirganj 100 PP(Dutch) Bangla	NENP	12'8	100	85	786080	Engine problem
19	Siddhirganj 335 MW CCPP	EGCB	1'217+118	335	140	4064729	ST U/M.
20	Gagnagar 102 MW PP (Digital Power)	IPP	12'8.924	102	102	1013904	
21	Kaipoti 52 MW PP (Sinha)	IPP	7'7.9	0	0	0	Fuel shortage
22	Kamalaghat 54 MW PP(Banco Energy)	IPP	3'18	55	35	747360	Engine problem
23	Kodda 150 MW PP	BPDB-RPCL	9'17.06	149	64	1216800	Low demand
24	Manikganj 55 MW PP (Northern)	IPP	3'19.3	55	35	472229	Fuel shortage
25	Nabaganj 55 MW PP (Southern power)	IPP	3'19.3	55	0	654942	Engine problem
26	Bosila 108MW PP(CLC)	IPP	12'8.775+113.5	0	0	0	
27	Summit Power (Madhabdi+Ashulia)	SIPP REB	3'3.67+4'8.73	80	40	1059780	Engine problem
28	Madhabdi 33 MW PP(Summit)	SIPP, REB	4'8.73	33	33	769580	
29	Ruaganj 300 MW PP(Summit)	SIPP, REB	4'8.73	316	16	682200	Engine problem
30	Gazipur 52 MW PP	RPCL	6'8.9	52	32	554880	Low demand
31	Tongi 80 MW GTPP	PDB	1' 105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18'17.076	300	295	2634545	
33	Keraniganj 300 MW PP (APR)	IPP	2567.4	300	0	0	Fuel shortage
34	Bramharanji 100 MW PP (Aggreko)	IPP	114'9.959	100	0	0	Fuel shortage
35	Auraihat 100MW PP (Aggreko)	IPP	0.85'23+0.95'91	100	0	0	Fuel shortage
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8'18.45+8.97	149	117	2069420	High voltage
37	Gazipur 100 MW PP	RPCL	6'17.5	105	102	1342080	
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5'6	104	72	966720	Fuel shortage
39	Manikganj 162MW PP(MPGL)	IPP	9'18	162	162	1368000	
40	Spectro Solar Plant Ltd.	IPP	35	35	0	1942680	
41	Kanchan Furthachal Power Generation Ltd.	IPP	18.4'3	55	34	513000	Engine problem
Dhaka area Total				5847	3136	61332615	
41	Chattogram TPP-1	PDB	1'210	180	0	0	Gas shortage
42	Chattogram TPP-2	PDB	1'210	180	0	0	Gas shortage
43	Raozan 25 MW PP	RPCL	3'9.9	25	8	179623	Low demand
44	Tanai 28MW PP (Salatleh)	IPP	20	20	0	335810	
45	Palanga 50MW PP (Baraka)	IPP	8'6.98	50	6	176160	Fuel shortage
46	Kapila Hydro Unit-1,2,3,4, 5	PDB	2'40+3'50	230	25	613280	Low Water level
47	Sikalbaha 225MW	PDB	1'150+1'75	225	214	4878146	
48	Sikalbaha Peaking GT	PDB	1'150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6'17.5	105	17	352945	Fuel shortage
50	Haziganj 100 MW Peaking PP	PDB	11'9.9	106	9	336528	
51	Dohazari -Kalaish 100 MW Peaking	PDB	6'17	102	84	740034	Low demand
52	Juddah 100 MW Unit-1 (Accom)	NENP	8'13.45	100	66	1118760	Fuel shortage
53	Juddah 100 MW PP Unit-3 (Accom)	IPP	8'13.5	100	100	2257920	
54	Barakkunda 22 MW PP (Regent)	SIPP, PDB	6'2.90	22	5	123312	Gas shortage
55	Malancha Ch. EPZ (United)	IPP	5'8.73+9.34	0	31	580320	
56	Chattogram 108 MW PP (ECPV)	IPP	16'7	108	6	72000	Fuel shortage
57	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	29762	
58	Anwara 300 MW PP (United)	IPP	17'17+24	300	300	3600545	
59	Jodiach Power	IPP	3'18.55+11'3.6	54	54	443649	
60	Karnaphuli Power Ltd.	IPP	18.415'6+8.5	110	54	969341	
61	Juddah unit-2 (Accom)	IPP	8'13.5	100	100	1442880	Low demand
62	Anlima Energy Ltd.	IPP	6'21.2	116	107	2135236	Engine problem
63	Minshaha 150 MW	BPDB-RPCL	18.5'9	0	0	0	On test.
Chattogram area Total				2382	1177	20186251	
61	Ashuganj TPP Unit- 3	APSCS	1'150	0	0	0	Contract Expired
62	Ashuganj TPP Unit- 4	APSCS	1'150	0	0	0	Contract Expired
63	Ashuganj TPP Unit- 5	APSCS	1'150	0	0	0	Contract Expired
64	Ashuganj 225 MW CCPP	APSCS	1'142+1'75	221	208	4561000	FGMO
65	Ashuganj 450 MW CCPP(North)	APSCS	1'360	360	290	7622000	FGMO
66	Ashuganj 450 MW CCPP(South)	APSCS	1'360	360	0	0	Gas shortage & ST Under ma
67	Ashuganj 420 MW CCPP(East)	APSCS	284'1+116'1	400	250	6545100	Gas shortage
68	Ashuganj 50 MW PP	APSCS	14'3.068	45	42	771480	
69	Ashuganj 45 MW PP (Precision)	QRPP	15'17.4	55	5	146880	Gas shortage
70	Ashuganj 195MW PP (APSCS-United)	IPP	20'9.73+11'6	195	8	217454	Gas shortage
71	Ashuganj 51 MW PP (Midland)	IPP	6'9.34	51	43	851791	Engine problem
72	Ashuganj 150MW PP (Midland)	IPP	23'7.015	150	132	1625890	Engine problem
73	Titas 50 MW Peaking PP	PDB	6'8.92	52	0	165296	Reserve.
74	Chandpur 150 MW CCPP	PDB	1'106+1'57	163	0	0	Under maint.
75	Chandpur 200 MW (Desh energy)	IPP	1'212+4	200	136	2749000	Low demand
76	Feni 22MW PP (Doreen)	SIPP, PDB	8'2.90	22	18	267156	Engine problem
77	Feni 11 MW PP (Doreen)	SIPP, REB	4'2.90	11	8	178200	
78	Impoport (Tripura)	Imported power	0	160	136	2859840	
79	Jangalia 33MW PP (Summit)	SIPP, PDB	4'8.73	33	33	296700	
80	Jangalia 300 MW PP (Lakshmi)	IPP	6'9.92	52	52	182744	
81	Cumilla 25 MW PP (Summit)	SIPP, REB	3'3.67+2'6.97	25	21	415760	Engine problem
82	Daudkandi 200 MW PP (B. Trac)	IPP	15'4.1	200	0	0	Fuel shortage
83	Feni Lanka Power	IPP	7'18.415+1'9.78	114	17	446880	Low demand
84	Chowmuhani 113 MW	IPP	12'9.78+2'3.1	113	9	226800	Fuel shortage
85	Bharat 54.5 MW	IPP	3'18.2	54	17	305280	Engine problem
86	Chandpur 115 (Doreen)	IPP	4'18.5+2'22.5	115	115	694560	
Cumilla Area Total				3285	1540	31428808	
87	RPCL 210MW CCPP	IPP	4'35+1'70	202	50	1370880	Gas shortage
88	Tangail 22 MW PP (Doreen)	SIPP, PDB	8'2.90	22	19	442512	Engine problem
89	Jamalpur 95 MW PP (Powerpac)	IPP	12'8.924	0	0	0	Under maint.
90	Sarishabari 3 MW Solar Plant	IPP	1'3	3	0	9100	
91	Mymensingh 200 MW PP (United)	IPP	9'78'21	183	200	2131200	
92	Jamalpur 115 MW PP (United)	IPP	9'78'12	115	109	1563600	
93	Sutiakhali 50 MW Solar PP	IPP	50	50	0	223950	
94	Tangail Pali Power Gen 22 MW	IPP	4'6.7	22	18	326160	Engine problem
Mymensingh Area Total				614	379	6067402	
91	Fenchuganj CCPP Phase-1	PDB	2'32+1'33	70	41	970000	Machine problem
92	Fenchuganj CCPP Phase-2	PDB	2'35+1'35	90	42	653160	Machine problem
93	Kushaura 183 MW CCPP (KP)	IPP	1109+1'54	163	80	2164090	ST U/M.
94	Shahjibazar 330 MW CCPP	PDB	3'110	330	0	0	Under maint.
95	Fenchuganj 51 MW PP (Barakatullah)	RPP	19'2.90	51	53	1030800	
96	Fenchuganj 44MW (Energyprima)	NENP	12'3.3+5.2	50	50	1031832	
97	Haldiganj 1 MW PP Colddene-E	SIPP, REB	4'2.90	11	9	178572	Engine problem
98	Shahjibazar GTTP Unit- 8 & 9	PDB	2'35	86	83	1318152	
99	Shahjibazar 86MW PP (Shahjibazar)	RPP	32'2.90	86	89	1779840	
100	Shahjibazar 100 MW GTTP	PDB	1'100	100	0	0	Under maint.
101	Sylhet 225 MW CCPP	PDB	1'142+1'89	231	130	3081370	ST U/M.
102	Sylhet 20 MW GTTP	PDB	1'20	20	18	428000	
103	Sylhet 50MW PP (EPL)	NENP	2'72	0	0	0	Contract Expired
104	Shahjahanulla 25 MW PP	SIPP, REB	3'9.34	25	16	378096	Engine problem
105	Bitiana-II 341 MW CCPP (Summit)	IPP	1'222+1'119	341	270	6567000	FGMO
106	Bitiyana-III 400 MW CCPP	PDB	285'1+134'1	400	321	8569000	FGMO
107	Sylhet 10MW PP (Desh)	RPP	6'1.95	10	10	242460	
108	Bitiyana South 400 MW	PDB	400 MW	383	350	9011400	Frequency control
Sylhet Area Total				2427	1547	37705272	
107	Bheramara GTTP Unit- 3	PDB	1'20	16	0	0	Fuel shortage
108	Bheramara (HVDC)	Imported power	2'500	1000	902	22075636	
109	Khulina 115 PP MW (KPCL-2)	NENP	7'17	115	80	818880	Engine problem
110	Fardpur 50 MW Peaking PP	PDB	8'6.89	54	0	0	Reserve.
111	Khulina 225 MW CCPP	NWPGCL	1'150+1'75	230	0	0	Fuel conservation
112	Cazipora 100 MW Peaking PP	PDB	1'6'9.98	109	109	1563600	Reserve.
113	Bheramara 410 MW CCPP	NWPGCL	1'278+1'132	410	120	3566880	Gas shortage
114	Noapara 40 MW PP (Khanjahan Ali)	NENP	5'8.5	40	0	14250	Reserve.
115	Noapara 100 MW PP (Bangla Trac)	IPP	70'1.4	100	0	0	Reserve.
116	Rupsha 105 MW PP (Orion rupsha)	IPP	6'18.445	105	56	412320	Fuel shortage
117	Madhumati 180 MW PP	NWPGCL	6'18	105	15	58304	Transformer OIL
118	Mongia Orion 100 MW Solar PP	IPP	100	100	0	516240	
119	Khulina 330 MW CCPP (DIL)	BPDB	1'220+1'110	0	27	394764	On test.
120	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	660'2	617	0	0	On test.
121	Kulina 225 MW CCPP (GAS)	NWPGCL	0	0	0	0	
Khulina Area Total				3001	1200	27855274	
117	Baisaal 110 MW PP (Summit)	IPP	7'17.076	110	16	18336	Line OIL
118	Bhola 33 MW PP (Venture)	NENP	1'34.50	26	40	476000	Engine problem
119	Bhola 225 MW CCPP	PDB	2'63+1'68	194	166	4071701	Machine problem
120	Bhola 95 MW PP (Aggreko)	QRPP	96'1.10	0	0	0	Contract Expired
121	Payra 1320 MW	BCPCL	2'622	1244	1070	25747000	Line OIL
122	Bhola Nutan Biddut BD LTD	IPP	220	220	0	0	Under maint.
123	United Payra Power Ltd.	IPP	8'18.5+1'9.5	150	0	22900	Line OIL
124	Baisaal 307 MW	BCPCL	307'1	307	230	4472700	On test.
Barisal Area Total				2265	1508	34808337	
124	Baghabari 71 MW GTTP	PDB	1'71	71	0	0	Gas shortage
125	Baghabari 100 MW GTTP	PDB	1'100	100	0	0	Gas shortage
126	Baghabari 50 MW Peaking PP	PDB	6'8.9	52	0	52461	Reserve.
127	Bera 70 MW Peaking PP	PDB	9'8.29	71	0	0	Reserve.
128	Annuar 50 MW PP (Sinha)	QRPP	7'7.9	0	0	0	Contract Expired
129	Katakhal 50 MW PP (Northern)	QRPP	6'8.9	50	0	0	Reserve.
130	Katakhal 50 MW Peaking PP	PDB	6'8.7	50	0	0	Reserve.
131	Sirajgonj Unit-1 225MW	NWPGCL	1'150+1'75	210	164	4087773	Gas shortage
132	Sirajgonj Unit-2 225MW	NWPGCL	1'150+1'75	220	0	0	
133	Sirajgonj Unit-3 225MW	NWPGCL	0	0	0	0	Gas shortage
134	Sirajgonj 400 MW CCPP Unit-4	NWPGCL	1'262+1'132	414	173	5509127	Gas shortage
135	Santahar 50 MW Peaking PP	PDB	6'8.7	50	36	379001	Engine problem
136	Bogra 22 MW PP (GGB)	RPP	6'4	22			