

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month March, 2023				Day : Friday				Date : 31.03.23					
Probable Maximum Demand : 11000 MW				Probable Maximum Generation : 14162 MW				Rule Curve = 88.17 ft.					
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 76.14 ft				Today = 76.02 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.03.23 (Yesterday)		31.03.23 (Today)		30.03.23 (Yesterday) Probable Peak Generation (MW)	31.03.23 (Today) Probable Peak Generation (MW)	Gas/Coal/Oil/Water Limitation MW	Gen. shortfall for : Machines shut down (MW)	Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)	Evening	Actual Peak Generation (MW)	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0				Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	75	75	75	81			32	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	323	303	300	300				
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	400	350	400	400				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	395	360	400	400				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0			210	Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	150	140	200	200				
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	273	263	300	285				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	102	102	102	102				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	19	22				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	40	40	51	53				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	26	16	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	25	32	25	51				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	51	102	70	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	64	64	64	150				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	35	35	35	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	145	295	280	300				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	55	117	17	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	55	0	17	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	72	72	72				
32	Manikganj 162MW PR(MPGL)	HFO (IPP)	9x18	162	162	72	162	162	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	34	17	34				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	50	85	92	92				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	62	90	75	90				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	85	73	90	90				
Dhaka Zone Total				6004	5847	2896	3136	3229	3564	347	740		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	50	25	25	25			205	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	8	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	6	20	20				
44	Sikalbaha 105 MW PP (Baraka Sikalabaha)	HFO (IPP)	6x18.415	105	105	5	17	17	17				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	219	214	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	190	300	300	300				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	76	100	88	100				
49	Dohazari-Katash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	84	0	85				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	34	0	0	48				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	5	5	5			17	Gas Shortage
*	Malancha, Ctg, EPZ (United)	Gas	5x8.73+3x9.34	108	108	5	31	10	25				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	5	6	5	12				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	12	54	17	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	0	54	51	54				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	100	100	100	100				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	44	66	55	75				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0				on test
Chattogram Zone Total				2442	2382	894	1177	1075	1277	402	330		
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	134				Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	15	42	47	50				
60	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	173	208	210	210				
61	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	360				Gas Shortage
62	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	290	290	330	330				
63	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	300	250	325	325				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	5	5	51	51				
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	8	8	8			187	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	43	43	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	135	132	25	150				
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	14	0	0	35				
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0			163	Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	155	136	160	180				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	18	19	20				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	8	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	0	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	0	52				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	21	18	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+6x1.015+1x1.068	200	200	0	0	0	0				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	34	17	114	114				
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	9	9	9				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	115	94	115				
**	Impoport (Tripura)	India	160	160	128	136	135	153	153				
Cumilla Zone Total				3309	3285	1367	1540	1649	1927	681	163		
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	42	50	51	50			152	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	89	109	95	110				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	95	183	150	180				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3								

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	30.03.23 (Yesterday)		31.03.23 (Today)		30.03.23 (Yesterday)	31.03.23 (Today)	Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)							
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date		
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	41	41	41		29	GT-1 & ST-1 Under maint.		
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		48	GT-4 Under maint.		
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	31	53	51	51					
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	80	112	112				ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8					
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	63	65	65					
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	60	89	86	86					
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	130	130	140	140					
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	19	19					
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10					
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage		
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	270	280	280					
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	368	321	400	400					
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	350	400	400					
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work		
104	Fenchuganj 44MW (Energyprime)	Gas (NENP)	12*3.4+5*2	50	50	50	50	50	50					
Sylhet Zone Total					2472	2427	1514	1541	1720	1720	9	561		
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0					
106	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	125	120	240	240	290		Gas Shortage		
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	40	50					
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	40	65					
109	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0					
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0					
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	56	53	53					
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	15	0	100					
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	97	0	100	0					
114	Khulna 115 MW PP (KPL-2)	HFO (NENP)	7x17	115	115	16	80	66	83					
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	8	40					
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0					
**	Bheramara (H/DC) India	Gas/HSD (B/PDB)		1000	1000	903	902	921	921					
Khulna Zone Total					3005	3001	1160	1200	1468	1552	290	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	48	48					
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	26	22	22					
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	171	166	170	170					
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	900	1070	900	1070					
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0					
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	178	230	250	250					
123	Bhola 220MW CAPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.		
Barishal Zone Total					2265	2265	1268	1508	1390	1560	0	220		
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage		
125	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage		
126	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32					
127	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0					
128	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	18	40					
129	Chapainabaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	100					
130	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	32	40					
131	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	42					
132	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	36	36	26	36					
133	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	166	164	160	150	46		Gas Shortage		
134	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage		
135	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0	220		Gas Shortage		
136	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	223	173	300	300	241		Gas Shortage		
137	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	20	22	22					
138	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11					
139	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	34					
140	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	95	95	113					
141	Bagura 113 MW (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	50	113					
142	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	2	0	6	0					
Adani Power Jharkhanda Ltd							759	761	760	760				
Rajshahi Zone Total					2129	2129	1239	1330	1572	1793	898	0		
143	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Coal Shortage		
144	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling		
145	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104		Coal Shortage		
146	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
147	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	28	92	35	113					
148	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0					
149	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0					
150	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	114	55	50	115					
151	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	30	0					
152	Teesta Solar Limited	Solar (IPP)				181	0	130	0					
Rangpur Zone Total					830	750	533	317	423	398	189	85		
Sub-total: Plants in operation					23078	22700	11163.0	12128	12905	14162	2968	2099		
(B) Plants under long term maintenance/ contract expired														
153	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0					
154	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0					
155	Bosilia 108MW PPI(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0					
156	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0					
157	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				Contract Expired on 11/01/2022	
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0	0	0	0	Contract Expired on 11/01/2022
Gross Total					23482	22700	11163	12128	12905	14162	2968	2099		

(C) Actual data of 30.03.23 (Yesterday) Thursday :														
01.	Max. Demand at eve. peak (Generation end)	:	12155	MW, at =	19:30 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	11714	MW, at =	19:30 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed	
03.	Highest Generation (Generation end)	:	12128	MW, at =	19:30 hrs		MW	MW	MW		MW	MW	MW	
04.	Minimum Generation (Generation end)	:	8357	MW, at =	6:00 hrs	Dhaka	4171	4171	0	Mymensingh	936	911	25	
05.	Day-peak Generation (Generation end)	:	11163	MW, at =	12:00 hrs	Chattogram	1234	1234	0	Sylhet	420	420	0	
06.	Evening-peak Generation (Generation end)	:	12128	MW, at =	19:30 hrs	Khulna	1541	1541	0	Barishal	337	337	0	
07.	Evening Peak Load-shed (Sub-station end)	:	25	MW, at =	19:30 hrs	Rajshahi	1239	1239	0	Rangpur	780	780	0	
08.	Minimum Generation Forecast up to 8:00 hrs.	:	6307	MW, at =	5:00 hrs	Cumilla	1057	1057	0					
09.	Generation shortfall at evening peak due to :	:				Total						11714	11689	25
a)	Gas/LF limitation	:	2574	MW		Fuel cost :						(a) Gas = 138731529	(c) Coal = 253990044	Taka
d)	Coal supply Limitation	:	189	MW		(b) Oil = 608862437						Taka	Total = 1001584011	Taka
b)	Low water level in Kaptai lake	:	205	MW		14. Maximum Temperature in Dhaka was :						32.5° C		
c)	Plants under shut down/ maintenance	:	2099	MW		15. Export through East-West interconnections :								
10.	Total Energy (Generation + India Import)	:	257.13	MKWh		At evening peak-hour						11163	MW, at	19:30 hrs
	By Gas = 129.706	By Oil =	46.896	MKWh		Maximum						-12	MW, at	20:00 hrs
	By Coal = 52.626	By Hydro =	0.613	MKWh		Energy						0	MW	
	By Solar = 2.352													
11.	Total Gas Supplied	:	935.27	MMCFD										
(D) Forecast of 31.03.23 (Today) Friday :														
01.	Maximum Demand	:	11000	MW	(Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	14162	MW	(Generation end)	05.	Total Generation	:	233.21	MW				
03.	Reserve / Shortage	:	3162	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka :	:	30.0° C					

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00
(Md. Helalur Rahman)
Deputy Secretary, Generation