

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2023		Day : Saturday			Date : 01.04.23								
Probable Maximum Demand :			11900 MW			Probable Maximum Generation :			14026 MW				
Water Level of Kaptai Lake at 06:00 AM			Yesterday =	76.02	ft	Today =	75.93	ft	Rule Curve = 88.00 ft.				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated / Present Capacity (MW)	31.03.23 (Yesterday)		01.04.23 (Today)		31.03.23 (Yesterday)	Probable Peak Generation (MW)	31.03.23 (Yesterday)	Gen. shortfall for :	Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0			260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0				Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0			365	Under maint.
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	3x43.35	108	108	35	78	75	81			30	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0			105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	338	342	300	300				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	400	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0			115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	301	394	370	390				
11	Siddhirgonj 2 nd 120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0			210	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	218	212	150	220				
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	270	250	280	280				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	55	55	55				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	8	102	102				
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	10	22	19	22				
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x37-7x8.73	80	80	42	45	51	51				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	15	33	33				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	25	51				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	17	70	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	16	64	150				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	35	35				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	15	280	300				
25	Kodda 140 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	88	17	149				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0				
27	Bramhaniganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0				
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	35	17	55				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	17	0	35	35				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	34	72	72				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	4	108	162	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	34	17	34				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	9	92	92				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	8	75	90				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	34	90	90				
Dhaka Zone Total			6004	5847	1955	2517	3129	3617	345	740			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25			205	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0			180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	3	0	5	0				
41	Raezan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	25	25				
42	Teknaf 20MW PP (Solarsen)	Solar (IPP)	1x20	20	20	15	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	20	20				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	17	17	17				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0			150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	227	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	15	50	300	300				
48	Juldah 100 MW PP Unit-3 (Acorn)	HFO (IPP)	8x13.45	100	100	88	100	70	100				
49	Dohazari-Kalash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	51	0	65				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	0	48				
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	5	8	5	5			14	Gas Shortage
	* Malancha, Ctg, EPZ (United)	Gas	5x8.73+3x9.34			24	40	2	10				
52	Chattogram 108 MW PP (IECPV)	HFO (IPP)	16x7.00	108	108	0	0	5	12				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	54	17	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	52	36	51	54				
55	Juldah unit-2 (Acorn)	HFO (IPP)	8x13.6	100	100	12	60	100	100				
56	Juldah 100 MW Unit-1 (Acorn)	HFO (ORPP)	8x13.45	100	100	33	66	55	66				
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0				on test
Chattogram Zone Total			2442	2382	621	847	1049	1233	399	330			
58	Ashuganj TPP Unit- 5	Gas (APSCl)	1 x 150	150	134	0	0	0	0			134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	15	49	50	50				
60	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+1x75	221	221	184	174	210	210				
61	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	0	0	0	0			360	Gas Shortage
62	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	305	290	310	310				
63	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	401	240	320	320				
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	10	45	30	45				
65	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+11'6	195	195	0	0	8	8			195	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6'8.34	51	51	20	43	43	43				
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	135	25	135				
68	Titras 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	35				
69	Chandpur 150 MW CCPP	Gas (PDB)	1X108+1x57	163	163	0	0	0	0			163	Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	17	180	160	180				
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	18	18	18				
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	5	11	11	11				
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33				
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	8	0	52				
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	12	21	18	21				
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+80x1.015+10x1.008	200	200	0	0	0	0				
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	114	114				
78	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	9	9	9	9				
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	1	17	17	17				
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	75	94	115				
	** Impoort (Tripura)	India	160	160	104	132	135	153	153				
Cumilla Zone Total			3309	3285	1169	1480	1605	1879	689	163			
81	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	46	106	51	106			96	Gas Shortage
82	Tangali 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	14	16	16	16				
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	25	113	95	110				
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	2	75	100	180				
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0				
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	36	0	50	0				
87	Tangali 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	18	12	18				
Mymensingh Zone Total			622	614	124	328	326	430	96	0			

Sl. No.	Name of Power Station	Fuel	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	31.03.23 (Yesterday)		01.04.23 (Today)		31.03.23 (Yesterday)	Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Probable start-up date		
						Actual Peak Generation (MW)		Probable Peak Generation (MW)							Description/ Remarks	
						Day	Evening	Day	Evening							
88	Fenchuganj CCPP Phase-1	Gas (PDB)	2x32+1x33	97	70	41	41	41	41			29	GT-1 & ST-1 Under maint.			
89	Fenchuganj CCPP Phase-2	Gas (PDB)	2x35+1x35	104	90	31	31	31	31			59	GT-4 Under maint.			
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	5	50	20	51							
91	Kushiera 163 MW CCPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	112	112	112				ST Under maint.			
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	8	8	8							
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	61	64	65	65							
94	Shahjibazar 330 MW CCPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330	Under maint.			
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	89	89	86	86							
96	Sylhet 225 MW CCPP	Gas (PDB)	1x142+1x89	231	231	108	151	162	162							
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18							
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10							
99	Shahjahanulla 25 MW PP	Gas (CI, PP, REB)	3x9.34	25	25	0	16	16	16		9		Gas Shortage			
100	Bibiana-II 341 MW CCPP (Summit)	Gas (IPP)	1x222+1x119	341	341	270	265	280	280							
101	Bibiyana-III 400 MW CCPP	Gas (PDB)	1x285+1x115	400	400	366	367	400	400							
102	Bibiyana South 383 MW CCPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400							
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100	Under project work			
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12'3.4-5'2	50	50	20	47	20	47							
Sylhet Zone Total						2472	2427	1419	1669	1669	1727	9	572			
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0							
106	Bheramara 410 MW CCPP	Gas (NWP, GCL)	1 x 278+1 x 132	410	410	240	260	240	260		150		Gas Shortage			
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	40	50							
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	40	65							
109	Khulna 225 MW CCPP	HSD/ Gas (NWP, GCL)	1 x 150+1x75	230	230	0	0	0	0							
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0							
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	53	53							
112	Madhumati 100 MW PP	HFO (NWP, GCL)	6x18.415	105	105	0	0	0	0							
113	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	18	0	100	0								
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	0	0	66	83							
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5'8.5	40	40	0	0	8	40							
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFP, GCL)	1x617	617	617	0	0	0	0							
	Khulna 330 MW CCPP	Gas/HSD (B, PDB)														
**	Bheramara (H/DC) India		1000	1000	905	796	922	922								
Khulna Zone Total						3005	3001	1163	1056	1469	1573	150	0			
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	48	48							
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	8	19	19	19							
119	Bhola 225 MW CCPP	Gas (PDB)	2x63+1x68	194	194	144	171	170	170							
120	Payra 1320 MW TPP	Coal (BCP, CL)	2x622	1244	1244	720	860	900	900							
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0							
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	150	249	250	250							
123	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0			220	Under maint.			
Barishal Zone Total						2265	2265	1022	1299	1387	1387	0	220			
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71	Gas Shortage			
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100	Gas Shortage			
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32							
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0							
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	18	40							
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	100							
129	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	32	40							
130	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	42	42							
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	36	0	26	36							
132	Sirajganj 225MW CCPP Unit-1	Gas (NWP, GCL)	1x150+1x75	210	210	140	176	150	170			34	Gas Shortage			
133	Sirajganj 225MW CCPP Unit-2	Gas (NWP, GCL)	1x150 + 1x75	220	220	0	0	0	0			220	Gas Shortage			
134	Sirajganj 225MW CCPP Unit-3	Gas (NWP, GCL)	1x141+1x79	220	220	0	0	0	0			220	Gas Shortage			
135	Sirajganj 400 MW CCPP Unit-4	Gas (IPP)	1x282+1x132	414	414	308	387	330	330			27	Gas Shortage			
136	Bogra 22 MW PP (GGB)	Gas (RPP)	6x4.0	22	22	22	22	22	22							
137	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	5	8	11	11							
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	34							
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	0	0	95	113							
140	Bagura 113 MW (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	50	70							
141	Sirajganj 6.55 MW Solar	Solar (NWP, GCL)	1x6	6	6	4	0	6	0							
	Adani Power Jharkhanda Ltd	Coal				761	764	760	760							
Rajshahi Zone Total						2129	2129	1276	1392	1592	1800	672	0			
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Coal Shortage			
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			85	Under Overhauling			
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170			104	Coal Shortage			
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	49	0	35	95							
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0							
147	Majpara, Taulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0							
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	35	36	50	115							
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	11	0	30	0							
	Teesta Solar Limited	Solar (IPP)				158	0	130	0							
Rangpur Zone Total						830	750	427	206	423	380	189	85			
Sub-total: Plants in operation						23078	22700	9176.0	10794	12649	14026	2549	2110			
(B) Plants under long term maintenance/ contract expired																
150	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0							
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0							
152	Bosilia 108MW PPI (CCLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0							
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0							
154	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0					Contract Expired on 11/01/2022		
Sub-Total: Plants under long term maintenance/ contract expired						404	0	0	0	0	0	0	0		Contract Expired on 11/01/2022	
Gross Total						23482	22700	9176	10794	12649	14026	2549	2110			
(C) Actual data of 31.03.23 (Yesterday) Friday :																
01.	Max. Demand at eve. peak (Generation end)	:	10794	MW, at =	21:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	:	10391	MW, at =	21:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed		
03.	Highest Generation (Generation end)	:	10798	MW, at =	22:00	hrs		MW	MW	MW		MW	MW	MW		
04.	Minimum Generation (Generation end)	:	6307	MW, at =	2:00	hrs	Dhaka	3685	3685	0	Mymensingh	801	801	0		
05.	Day-peak Generation (Generation end)	:	9176	MW, at =	12:00	hrs	Chattogram	1142	1142	0	Sylhet	410	410	0		
06.	Evening-peak Generation (Generation end)	:	10794	MW, at =	21:00	hrs	Khulna	1294	1294	0	Barishal	331	331	0		
07.	Evening Peak Load-shed (Sub-station end)	:	0	MW, at =	21:00	hrs	Rajshahi	1005	1005	0	Rangpur	675	675	0		
08.	Minimum Generation Forecast up to 8:00 hrs.	:	5602	MW, at =	5:00	hrs	Cumilla	1048	1048	0						
09.	Generation shortfall at evening peak due to :	:								Total	10391	10391	0			
	a) Gas/LF limitation	:	2155	MW						(a) Gas = 129156357	Taka	(c) Coal = 192345763	Taka			
	d) Coal supply Limitation	:	189	MW						(b) Oil = 266737089	Taka	Total = 588239209	Taka			
	b) Low water level in Kaptai lake	:	205	MW												
	c) Plants under shut down/ maintenance	:	2110	MW												
10.	Total Energy (Generation + India Import)	:	211.88	MKWh												
	By Gas =	:	121.587	MKWh												
	By Coal =	:	43.985	MKWh												
	By Solar =	:	1.933	MKWh												
	By Oil =	:		20.924	MKWh											
	By Hydro =	:		0.604	MKWh											
11.	Total Gas Supplied	:	942.50	MMCFD												
(D) Forecast of 01.04.23 (Today) Saturday :																
01.	Maximum Demand	:	11900	MW (Generation end)	04.	Maximum Load-shed	:	0	MW	At evening peak (Sub-station end)						
02.	Maximum Generation	:	14026	MW (Generation end)	05.	Total Generation	:	233.51	MKWh							
03.	Reserve / Shortage	:	2126	MW (Generation end)	06.	Probable Max. Temperature in Dhaka	:	30.5° C								
* Captive Power ** Imported Power																
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00																

(Md. Helalur Rahman)

Deputy Secretary, Generation