

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2023				Day : Thursday				Date : 06.04.23				
Probable Maximum Demand : 13800 MW				Probable Maximum Generation : 14450 MW								
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 76.07 ft		Today = 76.16 ft		Rule Curve = 87.00 ft				
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.04.23 (Yesterday)		06.04.23 (Today)		05.04.23 (Yesterday) Probable Peak Generation (MW)	Gas/Coal/Natural Gas/Other Fuel Limitation	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					
					Day	Evening	Day	Evening				
(A) Plants in operation:												
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		Gas Shortage
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	78	81	78	81	27		Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	332	334	340	340		340	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450		450	
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	402	394	400	400		400	
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	210	218	220	220		220	
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	271	255	260	280		280	
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55		55	
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	80	84	102	102		102	
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	22	22	22	22		22	
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	49	50	50	50		50	
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33		33	
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33		33	
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	42	50	50	50		50	
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	57	105	70	105		105	
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	115	150	150	150		150	
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	122	295	280	300		300	
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	102	149	115	149		149	
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x12.4	300	300	0	0	0	0		0	
27	Bramhaniganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		0	
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		0	
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	17	55		55	
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35		35	
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	72	72	72		72	
32	Manikganj 162MW PR(MPGL)	HFO (IPP)	9x18	162	162	54	162	162	162		162	
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0		30	
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	35	35	35		35	
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	42	42	92	92		92	
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	30	35	102	102		102	
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	90	95	68	95		95	
Dhaka Zone Total				6004	5847	3016	3504	3501	3683	707	375	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	2	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	8	25	25		25	
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	17	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19		19	
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	68	17	68		68	
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	224	220	225	225		225	
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	123	230	120	230		230	
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	62	100	62	100		100	
49	Dohazari-Kalataish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	34	0	85		85	
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	8	0	48		48	
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	10	10	10	12		Gas Shortage
	* Malancha, Ctg,EPZ (United)	Gas	5x8.73+3x9.34			3	36	5	20			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	8	0	0	0		0	
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	0	35		35	
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	54	54	54		54	
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	90	75	62	90		90	
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	44	55	44	66		66	
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		107	
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		0	on test
Chattogram Zone Total				2442	2382	792	1066	787	1207	397	330	
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	44	47	45	45		45	
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	191	184	200	200		200	
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Gas Shortage
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	310	280	280	280		280	
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	402	352	320	350		350	
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	50	30	55	55	25		Gas Shortage
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	0	0	195		Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	43	43	43	43		43	
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	18	133	100	150		150	
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	7	0	0	35		35	
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	160	166	180	200		200	
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18		18	
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11		11	
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		33	
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	52	52		52	
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	18	21	21		21	
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	99x1.4+60x1.015+10x1.068	200	200	0	0	0	0		0	
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	84	51	109	114		114	
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	57	9	55		55	
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	18	17	35		35	
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	77	36	115		115	
**	Impoport (Tripura)	India		160	160	130	154	135	153		153	
Cumilla Zone Total				3309	3285	1589	1724	1664	1965	714	163	
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	44	104	50	104		104	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19		19	
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	96	115	100	115		115	
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	136	163	150	170		170	
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		1.6	
86	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	49	0	50	0	0		50	
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	19	19					

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	05.04.23 (Yesterday)		06.04.23 (Today)		05.04.23 (Yesterday)	Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					Gen. shortfall for : Gas/Coal/Oil/Water Limitation MW
					Day	Evening	Day	Evening				
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	40	40	40	40		GT-1 & GT-1 Under maint.	
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	30	40	51	51			
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	80	112	112	112		ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	0	8	8			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	64	65	65			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330 Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	81	86	86	86			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	207	210	210	210			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	19	18	18			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	7	9	9	9			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	8	16	16	16		Gas Shortage	
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	275	270	280	280			
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	365	367	375	375			
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	400	400	400	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100 Under project work	
104	Fenchuganj 44MW (Energyprime)	Gas (NENP)	12'3.4-5'2	50	50	15	50	50	50			
Sylhet Zone Total					2472	2427	1636	1725	1762	1762	9	562
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
106	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	160	165	205	205		Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	30	40	50			
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	40	85			
109	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0			
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0			
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	55	53	53			
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	32	0	100			
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	88	0	100	0			
114	Khulna 115 MW PP (KPLC-2)	HFO (NENP)	7x17	115	115	0	65	66	99			
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5x8.5	40	40	0	40	8	40			
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	373	450	400	450			
**	Bheramara (H/DC) India	Gas/HSD (B/PDB)		1000	1000	888	793	905	905			
Khulna Zone Total					3005	3001	1534	1630	1817	1987	245	0
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	48	48			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	28	20	25			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	171	165	170	170			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	710	902	500	622			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0			
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	185	305	307	307			
123	Bhola 220MW CAPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220 Under maint.	
Barishal Zone Total					2265	2265	1085	1432	1045	1172	0	220
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	8	0	0	32			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	90			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40			
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	42			
131	Santazar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	28	36			
132	Sirajganj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	168	171	180	180		Gas Shortage	
133	Sirajganj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	220		Gas Shortage	
134	Sirajganj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	220		Gas Shortage	
135	Sirajganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	307	285	350	330		Gas Shortage	
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	15	22	22	22			
137	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11			
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	43			
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6'18.55	113	113	35	35	50	113			
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	70			
141	Sirajganj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0			
Adani Power Jharkhand Ltd							685	749	660	750		
Rajshahi Zone Total					2129	2129	1269	1387	1382	1799	779	0
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	220	170	220		Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7'16x 2'3	113	113	92	70	35	113			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0			
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6'20	115	115	35	75	50	115			
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1'30	30	30	38	0	30	0			
	Teesta Solar Limited	Solar (IPP)				201	0	130	0			
Rangpur Zone Total					830	750	542	365	423	448	139	85
Sub-total: Plants in operation					23078	22700	11828.0	13253	12771	14450	3088	1735
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP (Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PPL (LCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
154	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.9	50	0	5	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired					404	0	5	0	0	0	0	0
Gross Total					23482	22700	11833	13253	12771	14450	3088	1735
(C) Actual data of 05.04.23 (Yesterday) Wednesday :												
01.	Max. Demand at eve. peak (Generation end)	:	13291 MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12818 MW, at =	21:00 hrs	Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
03.	Highest Generation (Generation end)	:	13253 MW, at =	21:00 hrs	Dhaka	4741	4741	0	Mymensingh	1055	1020	35
04.	Minimum Generation (Generation end)	:	9961 MW, at =	6:00 hrs	Chattogram	1216	1216	0	Sylhet	383	383	0
05.	Day-peak Generation (Generation end)	:	11833 MW, at =	12:00 hrs	Khulna	1660	1660	0	Barishal	423	423	0
06.	Evening-peak Generation (Generation end)	:	13253 MW, at =	21:00 hrs	Rajshahi	1438	1438	0	Rangpur	738	738	0
07.	Evening Peak Load-shed (Sub-station end)	:	35 MW, at =	21:00 hrs	Cumilla	1164	1164	0				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9998 MW, at =	5:00 hrs					Total	12818	12783	35
09.	Generation shortfall at evening peak due to :	:			13.	Fuel cost :		(a) Gas = 150726526 Taka	(c) Coal = 214080754 Taka			
a)	Gas/LF limitation	:	2744 MW					(b) Oil = 803704990 Taka	Total = 1168512270 Taka			
d)	Coal supply Limitation	:	139 MW									
b)	Low water level in Kaptai lake	:	205 MW									
c)	Plants under shut down/ maintenance	:	1735 MW		14.	Maximum Temperature in Dhaka was : 34.7° C						
10.	Total Energy (Generation + India Import)	:	286.45 MMkWh		15.	Export through East-West interconnections :						
	By Gas = 141.462 MKWh					At evening peak-hour : 11833 MW, at 21:00 hrs						
	By Coal = 56.746 MKWh					Maximum : 44 MW, at 19:30 hrs						
	By Solar = 3.044 MKWh					Energy : 0 MKWh						
11.	Total Gas Supplied	:	1062.03 MMCFD									
(D) Forecast of 06.04.23 (Today) Thursday :												
01.	Maximum Demand	:	13800 MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	14450 MW	(Generation end)	05.	Total Generation : 298.28 MMkWh						
03.	Reserve / Shortage	:	650 MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 36.1° C						

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation