

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2023				Day : Friday				Date : 07.04.23						
Probable Maximum Demand : 13000 MW				Probable Maximum Generation : 14350 MW										
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 76.16 ft				Today = 76.28 ft						
				Rule Curve = 87.00 ft										
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.04.23 (Yesterday)		07.04.23 (Today)		06.04.23 (Yesterday) Probable Peak Generation (MW)	Gas/Coil/Miner Limitation MW	Yester for : Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)	Evening	Actual Peak Generation (MW)	Evening						
(A) Plants in operation:														
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work		
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Gas Shortage		
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180					
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		Gas Shortage		
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	78	102	78	81	6		Gas Shortage		
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage		
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0					
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	300	352	340	360					
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450					
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling		
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	372	398	400	400					
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	0	0	210		Gas Shortage		
12	Siddhirgonj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	170	220	220	220					
13	Meghnaghat CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	277	291	260	290					
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	55	55	55	55					
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	102	102	102					
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	22	22	22					
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	41	42	50	50					
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33					
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	32	33	33	33					
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	41	50	50	50					
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	70	105					
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	98	150	150	150					
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35					
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	300	300	280	300					
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	132	105	115	149					
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0					
27	Bramhanaganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0					
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	17	55					
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35					
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	72	72	72	72					
32	Manikganj 162MW PR(MPGL)	HFO (IPP)	9x18	162	162	72	122	162	162					
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	0	0					
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	35	35	35	35					
35	Siddhirgonj 100 MW PP (Dutch Bangla)	HFO (NENP)	12x8.9	100	100	80	80	80	80					
36	Meghnaghat 100 MW (IEL)	HFO (NENP)	12x8.9	100	100	102	99	100	100					
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	92	92	68	92					
Dhaka Zone Total				6004	5847	3265	3615	3487	3696	686	375			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level		
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Gas Shortage		
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180		Under maint.		
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0					
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	8	25	25					
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	0	20	0	20					
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	19	6	19					
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	68	17	68					
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.		
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	217	214	225	225					
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	126	230	120	230					
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	88	62	88					
49	Dohazari-Katash 100 MW Peaking	HFO (PDB)	6x17.0	102	102	68	17	0	85					
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	32	0	0	48					
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	10	12	10	12	10		Gas Shortage		
	* Malancha, Ctg, EPZ (United)	Gas	5x8.73+3x9.34			2	38	10	30					
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	26	0	0	0					
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	54	0	54					
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	53	54	54					
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	63	76	62	76					
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	55	44	55					
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107					
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			18	0	0	0			on test		
Chattogram Zone Total				2442	2382	904	1064	792	1201	395	330			
58	Ashuganj TPP Unit- 5	Gas (APSCL)	1 x 150	150	134	0	0	0	0	134		Gas Shortage		
59	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	45	43	46	45	48					
60	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	182	190	180	190					
61	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	0	0	0	0	360		Gas Shortage		
62	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	280	300	280	300					
63	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	380	401	320	400					
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	54	51	50	51	4		Gas Shortage		
65	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	0	8	8	8	187		Gas Shortage		
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x8.34	51	51	43	43	43	43					
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	18	147	100	150					
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	26	0	0	35					
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163		Under overhauling		
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	165	200	180	200					
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18					
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	11	11					
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33					
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	44	52	52	52					
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	15	17	17	17					
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	39x1.4+6x1.015+10x1.068	200	200	0	0	0	0					
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	114	77	109	114					
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	97	9	55					
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17					
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	75	36	115					
**	Impoport (Tripura)	India		160	160	158	110	135	153					
Cumilla Zone Total				3309	3285	1644	1891	1643	2010	685	163			
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	44	101	5						

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	06.04.23 (Yesterday)		07.04.23 (Today)		06.04.23 (Yesterday)	Status of Machines under shut-down/ Maintenance	Probable start-up date	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)					Gen. shortfall for : Gas/Coal/Water Limitation MW
					Day	Evening	Day	Evening				
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	37	39	40	40		GT-1 & GT-1 Under maint.	
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		GT-4 Under maint.	
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	12	12	12			
91	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	112	112		ST Under maint.	
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	5	8	8			
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	64	64	64			
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330 Under maint.	
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	86	86	86			
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	205	206	200	206			
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18			
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	9	9	9			
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9	Gas Shortage	
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	275	265	260	280			
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	366	366	375	375			
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	396	400	400	400			
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100 Under project work	
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4+5*2	50	50	46	50	50	50			
Sylhet Zone Total												
			2472	2427	1683	1690	1692	1718	9	563		
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0			
106	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	180	155	170	180	255	Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	40	50			
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	40	80			
109	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0			
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	40			
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	17	17			
112	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	15	67	0	100			
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	98	0	100	0			
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	28	82	66	82			
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	40	24	8	40			
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	480	364	400	400			
**	Bheramara (H/DC) India	Gas/HSD (B/PDB)		1000	1000	888	797	905	905	255	0	
Khulna Zone Total												
			3005	3001	1746	1506	1746	1894	255	0		
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	80	48	80			
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	18	28	20	28			
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	170	171	170	170			
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	490	620	500	622			
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	15	54	0	0			
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	152	307	307	307			
123	Bhola 220MW CAPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220 Under maint.	
Barishal Zone Total												
			2265	2265	845	1260	1045	1207	0	220		
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	100		Gas Shortage	
125	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	14	0	0	32			
126	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0			
127	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	4	0	0	40			
128	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	90			
129	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	0	40			
130	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	40			
131	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	21	36	28	36			
132	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	183	143	170	170	67	Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	220		Gas Shortage	
134	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	220		Gas Shortage	
135	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	337	297	300	300	117	Gas Shortage	
136	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22	22			
137	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	0	11	11			
138	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	43	0	43			
139	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	113	50	113			
140	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	113	35	113			
141	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0			
Adani Power Jharkhand Ltd												
					591	654	660	750				
Rajshahi Zone Total												
			2129	2129	1253	1421	1322	1800	795	0		
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	85		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	85		Under Overhauling	
143	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170	104	Coal Shortage	
144	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
145	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	113	35	113			
146	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0			
147	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0			
148	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	115	115	50	115			
149	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	32	0	30	0			
	Teesta Solar Limited	Solar (IPP)				202	0	130	0			
Rangpur Zone Total												
			830	750	560	398	423	398	189	85		
Sub-total: Plants in operation												
			23078	22700	12286.0	13265	12540	14350	3115	1736		
(B) Plants under long term maintenance/ contract expired												
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0			
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0			
152	Bosilia 108MW PPI(LCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0			
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0			
154	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	28	0	0	0			
Sub-Total: Plants under long term maintenance/ contract expired												
			404	0	28	0	0	0	0			
Gross Total												
			23482	22700	12314	13265	12540	14350	3115	1736		

(C) Actual data of 06.04.23 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	:	13283	MW, at =	21:00 hrs	12.	Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :						
02.	Max. Demand at eve. peak (Sub-station end)	:	12693	MW, at =	21:00 hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	13265	MW, at =	21:00 hrs	MW	MW	MW	MW	MW	MW	MW	MW
04.	Minimum Generation (Generation end)	:	9998	MW, at =	7:00 hrs	Dhaka	4614	4614	0	Mymensingh	1045	1028	17
05.	Day-peak Generation (Generation end)	:	12314	MW, at =	12:00 hrs	Chattogram	1248	1248	0	Sylhet	459	459	0
06.	Evening-peak Generation (Generation end)	:	13265	MW, at =	21:00 hrs	Khulna	1606	1606	0	Barishal	421	421	0
07.	Evening Peak Load-shed (Sub-station end)	:	17	MW, at =	21:00 hrs	Rajshahi	1387	1387	0	Rangpur	751	751	0
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9482	MW, at =	5:00 hrs	Cumilla	1162	1162	0				
09.	Generation shortfall at evening peak due to :	:				Total			12693	12676	17		
a)	Gas/LF limitation	:	2721	MW		Fuel cost :			(a) Gas = 150058240	(c) Coal = 158069289	Taka		
d)	Coal supply Limitation	:	189	MW		(b) Oil = 928368013			Taka	Total = 1236495542	Taka		
b)	Low water level in Kaptai lake	:	205	MW		14. Maximum Temperature in Dhaka was : 35.8° C							
c)	Plants under shut down/ maintenance	:	1736	MW		15. Export through East-West interconnections :							
10.	Total Energy (Generation + India Import)	:	286.27	MKWh		At evening peak-hour : 12314 MW, at 21:00 hrs							
	By Gas = 138.887	By Oil =	70.089	MKWh		Maximum : 44 MW, at 19:30 hrs							
	By Coal = 49.751	By Hydro =	0.293	MKWh		Energy : 0 MKWh							
	By Solar = 3.279												
11.	Total Gas Supplied	:	1057.19	MMCFD									
(D) Forecast of 07.04.23 (Today) Friday :													
01.	Maximum Demand	:	13000	MW	(Generation end)	04.	Maximum Load-shed : 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	:	14350	MW	(Generation end)	05.	Total Generation : 280.55 MKWh						
03.	Reserve / Shortage	:	1350	MW	(Generation end)	06.	Probable Max. Temperature in Dhaka : 37.6° C						

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation