

EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 6-Apr-23

Page -2

Sl. No.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
1	Ghorasal Repowered CCGP Unit-3 (GT)	PDB	1260	260	0	0	Under maint.
2	Ghorasal Repowered CCGP Unit-4	PDB	1210	180	0	0	Gas shortage
3	Ghorasal 365 MW CCGP Unit-7	PDB	1243+1122	365	0	0	Under maint.
4	Ghorasal 78.5 MW PP (MAX)	QRPP	240	0	0	0	
5	Ghorasal 108MW PP (Regent)	IPP	34.3.35	108	102	1868227	
6	Haripur GTPP	SBU, PDB	232	0	0	0	Under maint.
7	Haripur 412 MW CCGP	EGCB	1273+1139	412	398	9236480	Gas shortage
8	Haripur 360MW CCGP(HPL)	IPP	1235+1125	360	352	7760000	Gas shortage
9	Meghnaghat 450 MW CCGP(MPL)	IPP	2150+1150	450	450	9750500	
10	Meghnaghat 100 MW (IEL)	NENP	12*9	100	99	2341440	
11	Meghnaghat CCGP(Summit)	IPP	2110+1110	335	291	6814022	FGMO
12	Madanagar 102 PP(Summit)	NENP	6*17	102	92	1781641	Engine problem
13	Madanagar-55 MW PP(Summit)	IPP	3*17.08+111.3	55	55	1337130	
14	Keraniganj 100 MW PP (Powerpac)	QRPP	8*13.45	0	0	0	Contract Expired
15	Narsingdi 22 MW PP (Doreen)	SIPP, REB	8*2.90	22	22	405648	
16	210 MW Siddhirgonj TFP	PDB	1210	115	0	0	Under maint.
17	Siddhirgonj 2120 MW GTTP	EGCB	2105	210	0	0	Gas shortage
18	Siddhirgonj 100 PP(Dutch) Bangla	NENP	12*8	100	80	1705920	Engine problem
19	Siddhirgonj 335 MW CCGP	EGCB	1217+118	335	220	4416002	ST U/M.
20	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	102	789696	
21	Katipoti 52 MW PP (Sinha)	IPP	7*7.9	0	0	0	Fuel shortage
22	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	54	35	259920	Engine problem
23	Kodda 150 MW PP	BPDB-RPCL	9*17.08	150	149	2885760	
24	Manikganj 55 MW PP (Northern)	IPP	3*19.3	55	35	667834	Engine problem
25	Nabaganj 55 MW PP (Southern power)	IPP	3*19.3	55	55	668001	
26	Bosila 108MW PP(CLC)	IPP	12*8.775+113.5	0	0	0	
27	Summit Power (Madhabdi+Ashulia)	SIPP, REB	3*3.67+4*8.73	80	42	1056000	Engine problem
28	Madhabdi 33 MW PP(Summit)	SIPP, REB	4*8.73	33	33	757400	
29	Ruaganj 30 MW PP(Summit)	SIPP, REB	4*9.73	30	33	773200	
30	Gazipur 52 MW PP	RPCL	6*8.9	52	50	1121280	0.00
31	Tongi 80 MW GTTP	PDB	1*105	105	0	0	Under maint.
32	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.076	300	300	6297815	
33	Keraniganj 300 MW PP (APR)	IPP	256*1.4	300	0	0	Fuel shortage
34	Bramhartha 100 MW PP (Aggreko)	IPP	11*9.959	100	0	0	Fuel shortage
35	Aurahat 100MW PP (Aggreko)	IPP	0.85*23+0.95*91	100	0	0	Fuel shortage
36	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	105	218992	
37	Gazipur 100 MW PP	RPCL	6*17.5	105	105	2454576	
38	Meghnaghat 104 MW PP (OPCL)	IPP	18.5*6	104	72	1694400	Fuel shortage
39	Manikganj 162MW PP(MPGL)	IPP	9*18	162	122	1281600	
40	Spectro Solar Plant Ltd.	IPP	35	35	0	250500	
41	Kanchan Furibachal Power Generation Ltd.	IPP	18.4*3	55	35	850680	Engine problem
Dhaka area Total				5847	3615	73790823	
41	Chattoagram TPP-1	PDB	1210	180	0	0	Gas shortage
42	Chattoagram TPP-2	PDB	1210	180	0	0	Gas shortage
43	Raozan 25 MW PP	RPCL	3*8.9	25	8	389996	Low demand
44	Tafal 20MW PP (Sadarlech)	IPP	20	20	0	1355945	
45	Palenga 50MW PP (Baraka)	IPP	8*6.98	50	19	178560	Fuel shortage
46	Kapila Hydro Unit-1,2,3,4, 5	PDB	2*40+3*50	230	25	292800	Low Water level
47	Sikalbaha 225MW	PDB	1150+175	225	214	4881159	
48	Sikalbaha Peaking GT	PDB	1*150	150	0	0	Under maint.
49	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	68	688327	Fuel shortage
50	Hathazari 100 MW peaking PP	PDB	11*9.9	100	8	513424	Reserve.
51	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	17	1001363	Engine problem
52	Juddah 100 MW Unit-1 (Accorn)	NENP	8*13.45	100	55	871800	Engine problem
53	Juddah 100 MW PP Unit-3 (Accorn)	IPP	8*13.5	100	88	1603200	
54	Barakkunda 22 MW PP (Regent)	SIPP, PDB	6*2.90	22	12	225408	Gas shortage
55	Manartha. Ch. EPZ (United)	IPP	5*8.73+9.34	0	38	568800	
56	Chattoagram 108 MW PP (ECPV)	IPP	16*7	108	0	174720	Fuel shortage
57	Kapila 7 MW Solar PP	PDB	7.4 MW	7	0	33238	
58	Anwara 300 MW PP (United)	IPP	17*17+24	300	230	3028473	Fuel shortage
59	Jodiach Power	IPP	3*18.55+113.6	54	54	485730	Engine problem
60	Kamapahuli Power Ltd.	IPP	18.415*6+8.5	110	53	1329630	Fuel shortage
61	Juddah unit-3 (Accorn)	IPP	8*13.5	76	76	1455360	
62	Anlima Energy Ltd.	IPP	6*21.2	116	107	2580600	
63	Minshaha 150 MW	BPDB-RPCL	18.5*9	0	0	53527	On test.
Chattoagram area Total				2382	1064	20489050	
61	Ashuganj TPP Unit-3	APSCCL	1150	0	0	0	Contract Expired
62	Ashuganj TPP Unit-4	APSCCL	1150	0	0	0	Contract Expired
63	Ashuganj TPP Unit-5	APSCCL	1150	134	0	0	Contract Expired
64	Ashuganj 225 MW CCGP	APSCCL	1142+175	221	190	4639000	FGMO
65	Ashuganj 450 MW CCGP(North)	APSCCL	1360	360	300	7361300	FGMO
66	Ashuganj 450 MW CCGP(South)	APSCCL	1360	360	0	0	Gas shortage
67	Ashuganj 420 MW CCGP(East)	APSCCL	284*1+116*1	400	401	5991900	FGMO
68	Ashuganj 50 MW PP	APSCCL	14.3.968	45	46	1043136	Engine problem
69	Ashuganj 45 MW PP (Precision)	QRPP	15*4	55	51	1134720	
70	Ashuganj 195MW PP (APSCCL-United)	IPP	20*9.73+116	195	8	652363	Gas shortage
71	Ashuganj 51 MW PP (Midland)	IPP	6*9.34	51	43	1003515	Engine problem
72	Ashuganj 150MW PP (Midland)	IPP	23*7.015	150	147	1169236	
73	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	328720	Reserve.
74	Chandpur 150 MW CCGP	PDB	11*106+157	163	0	0	Under maint.
75	Chandpur 200MW (Desh energy)	IPP	12*12+4	200	200	4244160	
76	Feni 22MW PP (Doreen)	SIPP, PDB	8*2.90	22	18	423144	
77	Feni 11 MW PP (Doreen)	SIPP, REB	4*2.90	11	9	231120	
78	Impoport (Tripura)	Imported power	0	160	110	3139200	
79	Jangalia 33MW PP (Summit)	SIPP, PDB	4*8.73	33	33	816600	
80	Jangalia 33 MW PP (Lakshmi)	IPP	6*9.92	52	52	1180426	
81	Cumilla 25 MW PP (Summit)	SIPP, REB	3*3.67+2*6.97	25	17	371820	Engine problem
82	Daudkandi 200 MW PP (B. Trac)	IPP	15*1.4	200	0	0	Fuel shortage
83	Feni Lanka Power	IPP	7*18.415+19.78	114	77	1773840	Engine problem
84	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	97	529200	
85	Bharob 54.5 MW	IPP	3*18.2	54	17	518400	Engine problem
86	Chandpur 115 (Doreen)	IPP	4*18.5+2*22.5	115	75	1197120	Low demand
Cumilla Area Total				3285	1891	37748920	
87	RPCL 210MW CCGP	IPP	4155+170	202	101	1484160	Gas shortage
88	Tangal 22 MW PP (Doreen)	SIPP, PDB	8*2.90	22	19	325178	Engine problem
89	Jamalpur 95 MW PP (Powerpac)	IPP	12*8.924	0	0	0	Under maint.
90	Sarishabari 3 MW Solar Plant	IPP	1*3	3	0	14850	
91	Mymensingh 200 MW PP (United)	IPP	9*78*21	173	200	2457600	
92	Jamalpur 115 MW PP (United)	IPP	9*78*12	115	108	1801200	Fuel shortage
93	Suliakhali 50 MW Solar PP	IPP	50	50	0	344690	
94	Tangal Pali Power Gen 22 MW	IPP	4*6.7	22	19	457920	Engine problem
Mymensingh Area Total				614	420	6885598	
91	Fenchuganj CCGP Phase-1	PDB	2*32+133	70	39	918000	Machine problem
92	Fenchuganj CCGP Phase-2	PDB	2*35+135	90	42	645600	Machine problem
93	Kushkhara 183 MW CCGP (KP)	IPP	1109+1154	163	112	2133961	ST U/M.
94	Shahjibazar 330 MW CCGP	PDB	3*110	330	0	0	Under maint.
95	Fenchuganj 51 MW PP (Barakatullah)	RPP	19*2.90	51	12	562000	Machine problem
96	Fenchuganj 44MW (Energyprima)	NENP	12*3.3+5.2	50	50	1155312	
97	Haldiganj 11MW PP Confidence-E	SIPP, REB	4*2.90	11	5	163328	Engine problem
98	Shahjibazar GTTP Unit-3 & 9	PDB	2*35	86	84	1416960	
99	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	86	2055360	
100	Shahjibazar 100 MW GTTP	PDB	1*100	100	0	0	Under maint.
101	Sylhet 225 MW CCGP	PDB	1142+189	231	208	4166050	Machine problem
102	Sylhet 20 MW GTTP	PDB	1*20	20	18	418000	
103	Sylhet 50MW PP (EPZ)	NENP	2*7	0	0	0	Contract Expired
104	Shahjahanulla 25 MW PP	SIPP, REB	3*9.34	25	16	385728	Engine problem
105	Bibiana-II 341 MW CCGP (Summit)	IPP	1222+1119	341	265	6580500	FGMO
106	Bibiana-III 400 MW CCGP	PDB	285*1+134*1	400	366	8668000	FGMO
107	Sylhet 10MW PP (Desh)	RPP	6*1.95	10	9	200160	
108	Bibiyana South 400 MW	PDB	400 MW	383	400	9311400	
Sylhet Area Total				2427	1699	39999379	
107	Bheramara GTTP Unit-3	PDB	120	16	0	0	Fuel shortage
108	Bheramara (HVDC)	Imported power	2*500	1000	797	20829090	
109	Khulna 115 PP MW (KPCL-2)	NENP	7*17	115	82	1118400	Engine problem
110	Fardpur 50 MW Peaking PP	PDB	6*8.89	54	0	77280	Reserve.
111	Khulna 225 MW CCGP	NWPGCL	1150+175	230	0	0	Fuel conservation
112	Cazipora 100 MW Peaking PP	PDB	116*9.98	109	0	109312	Reserve.
113	Bheramara 410 MW CCGP	NWPGCL	1278+1132	410	155	4435488	Gas shortage
114	Noapara 40 MW PP (Khanjahan Ali)	NENP	5*8.5	40	24	528375	
115	Noapara 100 MW PP (Bangla Trac)	IPP	70*1.4	100	0	0	Reserve.
116	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	17	531840	Fuel shortage
117	Madhumati 180 MW PP	NWPGCL	6*18	105	67	1217088	Transformer OIL
118	Mongia Orion 100 MW Solar PP	IPP	100	100	0	718560	
119	Khulna 330 MW CCGP (DIL)	BPDB	1220+1110	0	0	0	On test.
120	Rampal 1320 MW (BIFPCL)	NTPC&BPDB	660*2	617	364	8458182	On test.
121	Kulna 225 MW CCGP (GAS)	NWPGCL	0	0	0	0	
Khulna Area Total				3001	1506	38023615	
117	Baishal 110 MW PP (Summit)	IPP	7*17.076	110	80	1043328	Line O/L
118	Bhola 33 MW PP (Venture)	NENP	1*34.50	28	40	545300	Engine problem
119	Bhola 225 MW CCGP	PDB	2*63+158	194	171	4414336	Machine problem
120	Bhola 95						