

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2023				Day : Saturday				Date : 08.04.23			
Probable Maximum Demand : 13500 MW				Probable Maximum Generation : 14027 MW							
Water Level of Kaptai Lake at 06:00 AM				Yesterday = 76.28 ft				Today = 76.38 ft			
				Rule Curve = 86.60 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.04.23 (Yesterday)		08.04.23 (Today)		07.04.23 (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coil/Mater Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180		
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365	Gas Shortage
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	81	81	78	81	27	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCGP(HPL)	Gas (IPP)	1x235+1x125	360	360	344	343	340	340	340	
8	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	400	400		
9	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115	Under Overhauling
10	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	412	403	401	400	400		
11	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	0	95	95	210	Gas Shortage
12	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	206	192	0	0		
13	Meghnaghat CCGP(Summit)	GAS (IPP)	2x110+1x110	335	335	288	298	280	290		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	30	55	55	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	24	102	24	102		
16	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	11	22	22	22		
17	Summit Power (Madhabdi+Ashulia)	Gas (SIPP, REB)	6x3.67+7x8.73	80	80	31	50	50	50		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	33	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	29	33	33	33		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	34	42	25	50		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	42	88	70	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	48	150	48	150		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	95	245	280	300		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	89	135	120	149		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	25x11.4	300	300	0	0	0	0		
27	Bramhaniganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	0		
29	Nabaganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	57	72	72	72		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	72	90	55	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	35	35	35	35		
35	Siddhirganj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	9	45	30	92		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	11	50	33	50		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	34	36	68	85		
Dhaka Zone Total				6004	5847	2731	3353	2926	3456	707	375
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205	Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Gas Shortage
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0	180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0		
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	6	6	19		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	51	17	68		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	204	199	195	220		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	124	230	120	230		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	88	50	100		
49	Dohazari-Kalataish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	17	67	51	68		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	24	32		
51	Barakunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	12	12	10	12	10	Gas Shortage
	* Malancha, Ctg, EPZ (United)	Gas	5x8.73+3x9.34			26	37	10	30		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	7	0	0	0		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	34	54	35		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	17	54	54	54		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	63	76	38	76		
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	32	33	55		
57	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0		on test
Chattogram Zone Total				2442	2382	731	1043	844	1156	395	330
58	Ashuganj TPP Unit- 5	Gas (APSCCL)	1 x 150	150	134	0	0	0	0	134	Gas Shortage
59	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	44	41	36	42		
60	Ashuganj 225 MW CCGP	Gas (APSCCL)	1x142+1*75	221	221	208	212	190	200		
61	Ashuganj 450 MW CCGP(South)	Gas (APSCCL)	1x360	360	360	0	0	0	0	360	Gas Shortage
62	Ashuganj 450 MW CCGP(North)	Gas (APSCCL)	1x361	360	360	315	300	280	300		
63	Ashuganj 420 MW CCGP(East)	Gas (APSCCL)	1x284+1x116	400	400	351	401	320	350		
64	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15*4	55	55	0	0	0	0	55	Gas Shortage
65	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20*9.73+1*116	195	195	8	45	45	8	150	Gas Shortage
66	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	35	43	43	43		
67	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	38	145	26	150		
68	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	37	30	40		
69	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling
70	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	158	156	200	200		
71	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	18	18	18		
72	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	11	11		
73	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	33	33	33	33		
74	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	8	52		
75	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	18	21	17	17		
76	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	96x1.4+60x1.015+10x1.068	200	200	0	0	0	0		
77	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	37	34	114	114		
78	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	9	97	9	100		
79	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	17	17	17		
80	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	36	115	36	115		
**	Import (Tripura)	India		160	160	90	100	135	153		
Cumilla Zone Total				3309	3285	1415	1876	1568	1963	699	163
81	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	44	103	50	100	99	Gas Shortage
82	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	19	19	19		
83	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	98	115	100	115		
84	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	132	164	150	170		
85	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0		
86	Sutahali 50 MW Solar PP	Solar (IPP)	1x50	50	51	0	50	0	0		
87	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	19	19	19	19		
Mymensingh Zone Total				622	614	365	420	390	423	99	0

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	07.04.23 (Yesterday)		08.04.23 (Today)		07.04.23 (Yesterday)	Status of Machines under shut-down/ Maintenance			
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				Gas/Coal/Water Limitation MW	Machines shut down (MW)	
					Day	Evening	Day	Evening					Description/ Remarks
88	Fenchuganj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	37	35	40	40		GT-1 & GT-1 Under maint.		
89	Fenchuganj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	42	42	42	42		GT-4 Under maint.		
90	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51				
91	Kushira 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	112	0	0		ST Under maint.		
92	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
93	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	60	61	64	64				
94	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330 Under maint.		
95	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	86	86	86	86				
96	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	204	203	208	208				
97	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	18	18	18	18				
98	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	9	9				
99	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16		Gas Shortage		
100	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	260	270	270	270				
101	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	372	378	368	368				
102	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	388	400	400	400				
103	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100 Under project work		
104	Fenchuganj 44MW (Energyprima)	Gas (NENP)	12*3.4*5*2	50	50	46	47	50	50				
Sylhet Zone Total					2472	2427	1598	1737	1630	1630	9	567	
105	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
106	Bheramara 410 MW CAPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	170	180	220	220		230	Gas Shortage	
107	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	30	50				
108	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	0	65				
109	Khulna 225 MW CAPP	HSD/ Gas (NWP/CGCL)	1 x 150+1x75	230	230	0	0	0	0				
110	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	40				
111	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	17	17	0	0				
112	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x18.415	105	105	0	32	0	100				
113	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	96	0	100	0				
114	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	16	78	32	99				
115	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	8	40				
116	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIF/PCCL)	1x617	617	617	375	375	370	370				
117	Bheramara (H/DC)	Gas/HSD (B/PDB)		0	0	0	0	0	0				
Khulna Zone Total					3005	3001	1406	1281	1681	1905	230	0	
117	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	48	48	48				
118	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	19	28	20	28				
119	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	172	172	170	170				
120	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	850	972	1000	1000				
121	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	0	0				
122	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	161	0	0	0				
123	Bhola 220MW CAPP (Nutan Bidrut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0			220 Under maint.	
Barishal Zone Total					2265	2265	1202	1220	1238	1246	0	220	
124	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0		71	Gas Shortage	
125	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0		100	Gas Shortage	
126	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	32				
127	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
128	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	40				
129	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	40	90				
130	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	26	0	0	40				
131	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	0	40				
132	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	36	28	36				
133	Sirajganj 225MW CAPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	175	173	170	170		37	Gas Shortage	
134	Sirajganj 225MW CAPP Unit-2	Gas (NWP/CGCL)	1x150+1x75	220	220	0	0	0	220			Gas Shortage	
135	Sirajganj 225MW CAPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	0	0	0	220			Gas Shortage	
136	Sirajganj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	304	337	330	350		77	Gas Shortage	
137	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	17	22	22	22				
138	Lilapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	11	11	11	11				
139	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	24	0	43				
140	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	70	50	113				
141	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	113	70	113	113				
142	Sirajganj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	5	0	6	0				
Adani Power Jharkhand Ltd							666	749	650	750			
Rajshahi Zone Total					2129	2129	1352	1492	1420	1650	725	0	
142	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Coal Shortage	
143	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0		85	Under Overhauling	
144	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	170	170	170	170		104	Coal Shortage	
145	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	107	60	113				
147	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
148	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
149	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	36	114	50	115				
150	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	37	0	30	0				
151	Teesta Solar Limited	Solar (IPP)				198	0	130	0				
Rangpur Zone Total					830	750	482	391	448	398	189	85	
Sub-total: Plants in operation					23078	22700	11282.0	12813	12145	14027	3053	1740	
(B) Plants under long term maintenance/ contract expired													
150	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
151	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0				
152	Bosilia 108MW PP(LCL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
153	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
154	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	0	0				
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	0	0	0	0	
Gross Total					23482	22700	11282	12813	12145	14027	3053	1740	

(C) Actual data of 07.04.23 (Yesterday) Friday :					12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
					Dhaka				Mymensingh					
					Demand MW	Supply MW	Load Shed MW				Demand MW	Supply MW	Load Shed MW	
01.	Max. Demand at eve. peak (Generation end)	:	12860	MW, at = 21:00 hrs		4259	4259	0				1098	1055	43
02.	Max. Demand at eve. peak (Sub-station end)	:	12389	MW, at = 21:00 hrs										
03.	Highest Generation (Generation end)	:	12837	MW, at = 22:00 hrs		1188	1188	0				481	481	0
04.	Minimum Generation (Generation end)	:	9482	MW, at = 7:00 hrs		1591	1591	0				412	412	0
05.	Day-peak Generation (Generation end)	:	11282	MW, at = 12:00 hrs		1419	1419	0				756	756	0
06.	Evening-peak Generation (Generation end)	:	12813	MW, at = 21:00 hrs										
07.	Evening Peak Load-shed (Sub-station end)	:	43	MW, at = 21:00 hrs										
08.	Minimum Generation Forecast up to 8:00 hrs.	:	9298	MW, at = 5:00 hrs										
09. Generation shortfall at evening peak due to :					Total				Total					
a) Gas/LF limitation					147965241 Taka				197551623 Taka					
d) Coal supply Limitation					819385072 Taka				1164901936 Taka					
b) Low water level in Kaptai lake														
c) Plants under shut down/ maintenance														
10. Total Energy (Generation + India Import)					36.5° C									
By Gas = 139.252 MKWH					Export through East-West interconnections :									
By Coal = 51.975 MKWH					At evening peak-hour				11282 MW, at 21:00 hrs					
By Solar = 3.265 MKWH					Maximum				-20 MW, at 20:00 hrs					
By Oil = 62.106 MKWH					Energy				0 MKWH					
By Hydro = 0.340 MKWH														
11. Total Gas Supplied					985.92 MMCFD									
(D) Forecast of 08.04.23 (Today) Saturday :					04. Maximum Load-shed : 0 MW At evening peak (Sub-station end)									
01. Maximum Demand : 13500 MW (Generation end)					05. Total Generation : 291.83 MKWH									
02. Maximum Generation : 14027 MW (Generation end)					06. Probable Max. Temperature in Dhaka : 37.8° C									
03. Reserve / Shortage : 527 MW (Generation end)														

* Captive Power ** Imported Power
#Remarks: Highest Generation 14782 MW on 16-04-2022 at 21:00 (Md. Helalur Rahman)
Deputy Secretary, Generation