

**Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2023		Day : Sunday				Date : 16.04.23					
Probable Maximum Demand :		16000 MW		Probable Maximum Generation :		14999 MW					
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 76.06 ft		Today = 76.02 ft		Rule Curve = 85.20 ft					
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.04.23 (Yesterday)		16.04.23 (Today)		Rule Curve (Yesterday)		Status of Machines under shut-down/ Maintenance
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	
(A) Plants in operation:											
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work
2	a) Ghorasal Repowered CCPP Unit-4 b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	180	0	0	0	0		Gas Shortage
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	120	120	365	Gas Shortage
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	74	70	81	81	38	Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105	Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0		
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	323	324	335	335		
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450		
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115 Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	395	404	412	412		
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	183	95	95	95	115	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	0	0	217	217		335 ST Under maint.
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	292	280	300	300		
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	15	55	15	55		
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	100	100	102	102		
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	19		
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	49	33	47	50		
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	25	25	33	33		
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	14	30	32	32		
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	39	49	52	52		
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	105	105	105	105		
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	93	144	48	149		
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	0	35		
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	252	278	195	295		
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	144	149	149	149		
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	263	227	300	300		
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	80	77	90	90		
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	85	85	85	85		
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	55	35	55		
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	55	72	54	72		
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	54	162	54	162		
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	32	0	30	0		
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	33	50	35	54		
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	75	80	60	85		
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	24	65	90	92		
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	94	93	95	96		
Dhaka Zone Total			6004	5847	3617	3846	3950	4412	623	710	
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	50	205	Low water level
39	a) Chattogram TPP-1 b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	100	0	100	100		Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0	180	Under maint.
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	17	25	25	25		
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	20	0	20	0		
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	14	19	6	19		
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	17	85	51	105		
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	0	0	0	0		
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.04	300	300	122	222	120	230		
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	62	88	50	100		
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	62	82	80	84		
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	43	64	51	66		
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	14	11	14	14		
*	Malancha, Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	20	5	10		
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	37	4	10	56		
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	54	17	54		
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	54	83	54	92		
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	76	90	63	90		
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	33	66	56	76		
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	84	107	107		
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			11	0	0	0		on test
Chattogram Zone Total			2442	2382	820	1022	859	1278	205	330	
58	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	34	38	44	44		
59	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+175	221	221	202	210	211	211		
60	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	335	350	360	360		
61	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	0	0	0	0	360	Under maint.
62	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	0	400	Under maint.
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55	Gas Shortage
64	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'16	195	195	195	195	180	195		
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	43	51	51	51		
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	42	112	20	150		
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	32	42	42	42		
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0	163	Under overhauling
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	180	192	175	200		
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	16	18	18		
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	0	9	9	9		
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	33	33		
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	8	52		
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20		
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.056	200	200	0	10	0	0		
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7*18.415+1*9.78	114	114	0	114	0	114		
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	7	111	9	113		
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35		
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	72	93	72	92		
**	limpopt (Tirpura)	India		160	160	126	114	135	153		
Cumilla Zone Total			3159	3151	1355	1796	1422	1892	55	923	
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	81	94	48	94	108	Gas Shortage
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	19	18	19	19		
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	97	97	98	115		
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	153	177	150	177		
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	1.6	0		
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	40	0	50	0		
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	19	19	19	19		
Mymensingh Zone Total			622	614	410	405	386	424	108	0	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	15.04.23 (Yesterday)		16.04.23 (Today)		15.04.23 (Yesterday)	16.04.23 (Today)	Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)				Gas/Coal/Water Limitation MW	Machines shut down (MW)	Description/ Remarks
					Day	Evening	Day	Evening	Gen. shortfall for :				
87	Fenchuganj CCGP Phase-1	Gas (PDB)	2x32+1x33	97	70	34	34	36	36			GT-1 & GT-1 Under maint.	
88	Fenchuganj CCGP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30			GT-4 Under maint.	
89	Fenchuganj 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	53	53	51	51				
90	Kushiera 163 MW CCGP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0			ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	61	32	62				
93	Shahjibazar 330 MW CCGP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330 Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	84	86	86				
95	Sylhet 225 MW CCGP	Gas (PDB)	1x142+1x89	231	231	198	198	208	208				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	17	18	18				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	8	8	9				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16			Gas Shortage	
99	Bibiana-II 341 MW CCGP (Summit)	Gas (IPP)	1x222+1x119	341	341	265	265	280	280				
100	Bibiyana-III 400 MW CCGP	Gas (PDB)	1x285+1x115	400	400	393	368	368	368				
101	Bibiyana South 383 MW CCGP	Gas (PDB)	1x252+1x131	383	383	365	385	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			100 Under project work	
103	Fenchuganj 44MW (Energyprime)	Gas (NENP)	12*3.4+5*2	50	50	43	48	48	49				
Sylhet Zone Total					2472	2427	1556	1575	1589	1621	9	580	
104	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CCGP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	220	195	235	235			Gas Shortage	
106	Fardpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	5	28	20	40				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	50	58	52	65				
108	Khulna 225 MW CCGP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	55	55	55	55				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	85	105	105	105				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	91	0	100	0				
113	Khulna 115 MW PP (KPCL-2)	HFO (NENP)	7x17	115	115	79	95	99	99				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	16	40	40	40				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	0	0	0	0			617 Under maint.	
**	Bheramara (H/DC) India	Gas/HSD (B/PDB)		1000	1000	759	663	773	773				
Khulna Zone Total					3005	3001	1386	1389	1479	1412	215	617	
116	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	110	16	110				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	22	36	20	36				
118	Bhola 225 MW CCGP	Gas (PDB)	2x63+1x88	194	194	162	154	170	170				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1244	1244	1244	1244				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	150	17	150				
121	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0				
122	Bhola 220MW CCGP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0			220 Under maint.	
Barishal Zone Total					2265	2265	1461	1694	1467	1710	0	220	
123	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0			Gas Shortage	
123	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0			Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	28	22	28	30				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	9	43	0	43				
127	Chapainabaganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	66	87	75	86				
128	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	24	40	40	40				
129	Katakali 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	42	42	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	35	33	35	35				
131	Sirajgonj 225MW CCGP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	195	173	174	174			Gas Shortage	
132	Sirajgonj 225MW CCGP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0			Gas Shortage	
133	Sirajgonj 225MW CCGP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	0	0	0	0			Gas Shortage	
134	Sirajgonj 400 MW CCGP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	414	414	414				
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	13	18	21	21				
136	Uliapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	0	11	11	11				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
138	Bagura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	77				
139	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	70				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4	0	6	0				
Adani Power Jharkhanda Ltd							760	752	755	755			
Rajshahi Zone Total					2129	2129	1652	1788	1671	1806	648	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	0	0	0	0			Coal Shortage	
141	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0			Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	200	250	240	240			Coal Shortage	
143	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	34	70	34	70				
145	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tatalia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6	0	8	0				
147	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	113	0	113				
148	Lalmohith 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	32	0	30	0				
Teesta Solar Limited							165	0	130	0			
Rangpur Zone Total					830	750	437	433	442	423	109	85	
Sub-total: Plants in operation					22928	22566	12694.0	13948	13265	14978	1972	3465	
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Katpott 52 MW PP (Sinha)	HFO (IPP)	7x7.50	51	0	0	0	0	0				
151	Bosilia 108MW PPI(CLL)	HFO (IPP)	12x8.775+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Amfura 30 MW PP (Sinha)	HFO (QRPP)	7x7.79	50	0	21	21	21	21				
Sub-Total: Plants under long term maintenance/ contract expired					404	0	21	21	21	21			
Gross Total					23332	22566	12715	13969	13286	14999	1972	3465	

(C) Actual data of 15.04.23 (Yesterday) Saturday :														
01.	Max. Demand at eve. peak (Generation end)	:	15000	MW, at =	21:00	hrs	12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :							
02.	Max. Demand at eve. peak (Sub-station end)	:	14239	MW, at =	21:00	hrs	Zone	Demand	Supply	Load Shed	Zone	Demand	Supply	Load Shed
03.	Highest Generation (Generation end)	:	14104	MW, at =	22:00	hrs	Dhaka	5220	5160	60	Mymensingh	1250	1055	195
04.	Minimum Generation (Generation end)	:	11475	MW, at =	6:00	hrs	Chattogram	1287	1207	80	Sylhet	549	469	80
05.	Day-peak Generation (Generation end)	:	12715	MW, at =	12:00	hrs	Khulna	1658	1488	170	Barishal	470	435	35
06.	Evening-peak Generation (Generation end)	:	13969	MW, at =	21:00	hrs	Rajshahi	1507	1387	120	Rangpur	900	810	90
07.	Evening Peak Load-shed (Sub-station end)	:	950	MW, at =	21:00	hrs	Cumilla	1398	1278	120				
08.	Minimum Generation Forecast up to 8:00 hrs.	:	12010	MW, at =	5:00	hrs	Total 14239 13289 950							
09.	Generation shortfall at evening peak due to :	:					(a) Gas = 155930223 Taka (c) Coal = 311641960 Taka							
a)	Gas/LF limitation	:	1658	MW			(b) Oil = 1234622848 Taka Total = 1702195030 Taka							
d)	Coal supply Limitation	:	109	MW										
b)	Low water level in Kaptai lake	:	205	MW										
c)	Plants under shut down/ maintenance	:	3465	MW										
10.	Total Energy (Generation + India Import)	:	301.24	MKWh			14. Maximum Temperature in Dhaka was : 40.4° C							
	By Gas = 136.324 MKWh						15. Export through East-West interconnections :							
	By Coal = 54.948 MKWh						At evening peak-hour : 12715 MW, at 21:00 hrs							
	By Solar = 2.626 MKWh						Maximum : 280 MW, at 6:00 hrs							
							Energy : 0 MKWh							
11.	Total Gas Supplied	:	1039.46	MMCFD										
(D) Forecast of 16.04.23 (Today) Sunday :														
01.	Maximum Demand	:	16000	MW	(Generation end)	04.	Maximum Load-shed	:	922	MW	At evening peak (Sub-station end)			
02.	Maximum Generation	:	14999	MW	(Generation end)</									