

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2023		Day : Friday				Date : 21.04.23							
Probable Maximum Demand :		13800 MW		Probable Maximum Generation :		16033 MW							
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.69 ft		Today = 75.59 ft		Rule Curve = 86.00 ft							
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.04.23 (Yesterday)		21.04.23 (Today)		Gen. shortfall for : Gas/Coal/Water Limitation MW	Machines shut down (MW)	Status of Machines under shut-down/ Maintenance	Description/ Remarks	Probable start-up date
					Actual Peak Generation (MW)		Probable Peak Generation (MW)						
					Day	Evening	Day	Evening					
(A) Plants in operation:													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0			Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	100	100	180	180				
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	175	175	200	200	79	126	Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	72	76	76	76	32		Gas Shortage	
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0				
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	323	328	300	330				
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	450	450	450	450				
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	386	400	400	400				
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	0	85	90	100	20	105	Gas Shortage	
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	203	212	216	216		123	ST Under maint.	
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	298	305	300	300				
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	14	15	15	15				
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	50	50	91	58	92			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	19	19	19	22				
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, REB)	6x3.67+7x3.73	80	80	36	40	46	46				
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	33	33	33				
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	28	31	32	32				
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	46	48	48	48				
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	88	105	105	105				
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	112	145	145	145				
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	17	17	17	17				
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	93	143	150	150				
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	123	71	35	70				
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	11	40	300	300				
27	Bramhanganj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	60	0	50	100				
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	50	0	0	80				
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	35	35	35	35				
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	52	70	54	90				
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	108	162	108	162				
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	0	0				
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	36	17	34				
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	65	65	65	65				
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	59	64	70	70				
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	94	90	90	97				
Dhaka Zone Total			6004	5847	3284	3486	3769	4095	236	729			
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level	
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	120	120				
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.	
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0				
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	25	25	25				
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0				
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	6	32	26	40				
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	105	105	105				
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	218	222	225	225				
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	124	278	120	277				
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	55	100	50	100				
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	51	68	66	66				
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	44	58	45	60				
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	11	11				
*	Malancha, Clq EPZ (United)	Gas	5x8.73+3x9.34			2	36	25	35				
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	50	0	51				
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	54	17	54				
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	92	104	100	105				
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	63	90	63	90				
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	44	74	55	68				
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	107	107	107				
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test	
Chattogram Zone Total			2442	2382	1133	1561	1210	1564	205	330			
58	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	36	41	41	41				
59	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+175	221	221	190	205	190	210				
60	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	295	230	300	330				
61	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	95	310	300	330				
62	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	0	0	0	350		400	Under maint.	
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55		Gas Shortage	
64	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'16	195	195	45	0	40	40	195		Gas Shortage	
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	51	51	51	51				
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	77	137	80	150				
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	11	37	37	40				
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling	
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	51	68	17	17				
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	18	17	18	18				
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	7	7	9	9				
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	32	33	33				
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	8	52	0	52				
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20				
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.056	200	200	0	0	0	0				
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	114	0	114				
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	8	111	9	94				
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	35	35	35				
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	79	93	94	94				
**	limpoort (Tripura)	India		160	160	116	130	143	166				
Cumilla Zone Total			3159	3151	1174	1690	1417	2194	250	563			
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	47	100	200	200	102		Gas Shortage	
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	19	18	18				
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	96	106	100	100				
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	148	188	140	200				
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.					

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	20.04.23 (Yesterday)		21.04.23 (Today)		20.04.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)			
87	Fenchugon CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	32	33	33	33		37	GT-1 & ST-1 Under maint.	
88	Fenchugon CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	39	40	40		51	GT-4 Under maint.	
89	Fenchugon 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	50	53	51	51				
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	112	112	0	0		54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	59	60	50	60				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	82	84	82	84				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	200	196	200	200				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	0	18	20	20				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	9	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	16	16	16	9		Gas Shortage	
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	280	280	280	290				
100	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	368	410	400	400				
101	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	381	393	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchugon 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	47	44	44	44				
Sylhet Zone Total					2472	2427	1683	1755	1634	1656	9	572	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CAPP	Gas (NWP/GCL)	1 x 278+1 x 132	410	410	145	155	200	200	255		Gas Shortage	
106	Fariapur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	9	30	22	35				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	20	62	55	75				
108	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	0	0				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17				
111	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	40	15	0	105				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	90	0	100	0				
113	Khulna 115 MW PP (KPL-2)	HFO (NENP)	7x17	115	115	46	97	85	98				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	8	24	16	40				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	372	369	370	370				
**	Khulna 330 MW CAPP	Gas/HSD				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	914	854	933	933				
Khulna Zone Total					3005	3001	1644	1623	1798	1873	255	0	
116	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	16	16	16	16				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	25	38	25	35				
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	162	169	170	170				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	1222	1244	1244	1244				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	17	100	17	150				
121	Bansal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0				
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total					2265	2265	1442	1567	1472	1615	0	220	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	26	26	26	26				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	28	0	34				
127	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	56	87	80	80				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	40	24	42				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	16	42	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	34	32	35	35				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	178	178	220	220	32		Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	154	158	220	220	62		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	274	318	400	400	96		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	14	20	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
138	Baigura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	95	35	95				
139	Baigura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	94	35	70				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	5	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				756	740	755	755				
Raishahi Zone Total					2129	2129	1631	1874	1900	2057	581	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	70	67	75	75	18		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	230	220	220	220	54		Coal Shortage	
143	Rangpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	42	92	42	95				
145	Saidpur 20 MW GTTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tazula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thekugaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	24	72	35	35				
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	31	0	30	0				
	Teesta Solar Limited	Solar (IPP)				111	0	130	0				
Rangpur Zone Total					830	750	515	451	540	425	72	85	
Sub-total: Plants in operation					22928	22566	12884.0	14443	14272	16019	1710	2499	
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Kalpatiti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	51	0	0	0	0	0				
151	Bosila 108MW PP(CCL)	HFO (IPP)	12x8.775+1x3.5	109	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Ambari 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	14	14	14	14				
Sub-Total: Plants under long term maintenance/ contract expired					404	0	14	14	14	14	0	0	
Gross Total					23332	22566	12898	14457	14286	16033	1710	2499	
(C) Actual data of 20.04.23 (Yesterday) Thursday :													
01.	Max. Demand at eve. peak (Generation end)	: 14558 MW, at = 21:00 hrs		12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
02.	Max. Demand at eve. peak (Sub-station end)	: 13960 MW, at = 21:00 hrs		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW		
03.	Highest Generation (Generation end)	: 14457 MW, at = 21:00 hrs		Dhaka	4310	4310	0	Mymensingh	1003	1003	0		
04.	Minimum Generation (Generation end)	: 11566 MW, at = 8:00 hrs		Chattogram	1360	1360	0	Sylhet	556	556	0		
05.	Day-peak Generation (Generation end)	: 12898 MW, at = 12:00 hrs		Khulna	1889	1889	0	Barishal	498	498	0		
06.	Evening-peak Generation (Generation end)	: 14457 MW, at = 21:00 hrs		Rajshahi	1797	1726	71	Rangpur	1000	975	25		
07.	Evening Peak Load-shed (Sub-station end)	: 96 MW, at = 21:00 hrs		Cumilla	1548	1548	0						
08.	Minimum Generation Forecast up to 8:00 hrs.	: 10000 MW, at = 5:00 hrs						Total	13960	13864	96		
09.	Generation shortfall at evening peak due to :												
a)	Gas/LF limitation	: 1433 MW		13.	Fuel cost :	(a) Gas = 167909729 Taka	(c) Coal = 323892737 Taka						
d)	Coal supply Limitation	: 72 MW				(b) Oil = 989046589 Taka	Total = 1480849056 Taka						
b)	Low water level in Kaptai lake	: 205 MW											
c)	Plants under shut down/ maintenance	: 2499 MW		14. Maximum Temperature in Dhaka was : 37.3° C									
10.	Total Energy (Generation + India Import)	: 313.35 MWh		15. Export through East-West interconnections :									
	By Gas = 146.893 MKWH	By Oil = 72.872 MKWH											
	By Coal = 66.329 MKWH	By Hydro = 0.283 MKWH											
	By Solar= 2.513 MKWH												
11.	Total Gas Supplied	: 112.74 MMCFD		At evening peak-hour : 12898 MW, at 21:00 hrs									
				Maximum : -24 MW, at 18:30 hrs									
				Energy : 0 MKWh									
(D) Forecast of 21.04.23 (Today) Friday :													
01.	Maximum Demand	: 13800 MW (Generation end)		04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)							
02.	Maximum Generation	: 16033 MW (Generation end)		05.	Total Generation	: 299.11 MKWh							
03.	Reserve / Shortage	: 2233 MW (Generation end)		06.	Probable Max. Temperature in Dhaka :	38.5° C							

* Active Power ** Imported Power
#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)