

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel: 9564667, 9551095

Month April, 2023		Day: Saturday		Date: 22.04.23								
Probable Maximum Demand :		11200 MW		Probable Maximum Generation : 15229 MW								
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.59 ft	Today = 75.48 ft	Rule Curve = 83.80 ft								
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.04.23 (Yesterday)		22.04.23 (Today)		Rule Curve (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	200	150	150	150	104	126	Gas Shortage
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	12	23	76	76	85		Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	262	255	300	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	360	300	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	354	267	400	400			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	97	37	90	100	68	105	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	170	140	216	216		195	ST Under maint.
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	289	278	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	58	92			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	9	0	19	19			
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, REB)	8x3.67+7x8.73	80	80	23	23	46	46			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	33	18	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	16	0	32	32			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	2	5	48	48			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	14	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	16	16	145	145			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	17	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	1	150	150			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	34	17	35	70			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
28	Aurahi 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	80			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	35	35			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	5	35	35			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	52	17	54	90			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	17	35	108	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	17	34			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	65	65			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	17	17	17	50			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	90	90			
Dhaka Zone Total			6004	5847	2190	1798	3666	4015	362	801		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	25	25	25	25	205		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	120	120	100	100			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	4	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	25	8	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	10	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	28	39	26	40			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	105	17	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	224	207	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	122	30	120	277			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	38	10	50	100			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	65	66	66	66			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	45	43	45	60			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	11	13	11	11			
*	Malancha, Clq EPZ (United)	Gas	5x8.73+3x9.34			42	40	30	40			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	1	0	51			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	17	17	17	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	102	17	100	105			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	63	10	63	90			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	56	10	55	68			
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	107	17	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	72	0	0			on test
Chattogram Zone Total			2442	2382	1209	762	1195	1549	205	330		
58	Ashuganj 50 MW PP	Gas (APSCCL)	14x3.968	53	45	34	0	41	41			
59	Ashuganj 225 MW CCPP	Gas (APSCCL)	1x142+175	221	221	206	134	190	210			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCCL)	1x360	360	360	270	270	300	300			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCCL)	1x361	360	360	290	295	300	300			
62	Ashuganj 420 MW CCPP(East)	Gas (APSCCL)	1x284+1x116	400	400	3	11	311	350			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55		Gas Shortage
64	Ashuganj 195MW PP (APSCCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	40	40	195		Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	10	10	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	80	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	31	0	37	40			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	34	34	51	51			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	0	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	8	0	9	9			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	32	0	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	52	0	8			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	21	0	20	20			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	89x1.4+40x1.515+15x1.056	200	200	0	0	0	0			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	114	0	114			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	55	60	9	94			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	35	0	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	75	94	94	94			
**	limpoort (Tripura)	India		160	160	110	18	143	166			
Cumilla Zone Total			3159	3151	1214	1092	1762	2124	250	163		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	203	209	200	200			
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	16	17	17	17			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	88	115	100	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	145	183	140	180			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45	0	50	0			
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	12	12	22	22			
Mymensingh Zone Total			622	614	511	536	531	534	0	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	21.04.23 (Yesterday)		22.04.23 (Today)		21.04.23 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)			
87	Fenchugon CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	34	35	35	35		35	GT-1 & ST-1 Under maint.	
88	Fenchugon CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	40	40	40	40		50	GT-4 Under maint.	
89	Fenchugon 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	11	14	51	51				
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	8	0	8	8				
92	Shahjibazar GTTP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	40	40	40				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	84	0	10	84				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	205	202	0	0				
96	Sylhet 20 MW GTTP	Gas (PDB)	1 x 20	20	20	18	18	20	20				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	8	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	16	8	8	8	17		Gas Shortage	
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	240	280	290				
100	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	325	317	400	400				
101	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	350	370	400	400				
102	Shahjibazar 100 MW GTTP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchugon 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	25	10	44	44				
Sylhet Zone Total					2472	2427	1454	1304	1346	1430	17	569	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CAPP	Gas (NWP/CGCL)	1 x 278+1 x 132	410	410	270	395	250	250	15		Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	22	35				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	55	75				
108	Khulna 225 MW CAPP	HSD/ Gas (NWP/CGCL)	1 x 150+1x75	230	230	0	0	0	0				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.5+15	100	100	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x8.445	105	105	0	5	17	17				
111	Madhumati 100 MW PP	HFO (NWP/CGCL)	6x8.415	105	105	0	0	0	105				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	91	0	100	0				
113	Khulna 115 MW PP (KPL-2)	HFO (NENP)	7x17	115	115	0	32	85	98				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	0	16	40				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIF/CL)	1x617	617	617	370	318	370	0				
	Khulna 330 MW CAPP	Gas/HSD				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	917	917	937	937				
Khulna Zone Total					3005	3001	1648	1667	1852	1557	15	0	
116	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	16	16				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	25	34	25	35				
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	169	161	170	170				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	500	500	600	1244				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	0	17	150				
121	Bansal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0				
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total					2265	2265	694	695	828	1615	0	220	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	20	26	26	26				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	5	28	0	34				
127	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	52	72	80	80				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	40	0	24	42				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	34	0	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	32	35	35				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/CGCL)	1x150+1x75	210	210	130	140	200	200	70		Gas Shortage	
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/CGCL)	1x150 + 1x75	220	220	0	0	0	220			Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/CGCL)	1x141+1x79	220	220	190	130	160	160	90		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	314	306	414	414	108		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	18	20	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	8	0	8				
138	Baigura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	35	75	35	95				
139	Baigura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	35	70	35	70				
140	Sirajgonj 6.55 MW Solar	Solar (NWP/CGCL)	1x6	6	6	4	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				612	603	750	750				
Raishahi Zone Total					2129	2129	1497	1518	1829	1986	659	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	71	74	75	75	11		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	240	240	200	200	200	34		Coal Shortage	
143	Rangpur 20 MW GTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	36	78	42	95				
145	Saidpur 20 MW GTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Talsia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	4	0	8	0				
147	Thekugaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	37	10	35	35				
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	17	0	30	0				
	Teesta Solar Limited	Solar (IPP)				119	0	130	0				
Rangpur Zone Total					830	750	524	402	520	405	45	85	
Sub-total: Plants in operation					22928	22566	10941.0	9774	13529	15215	1553	2168	

(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Kalpatiti 52 MW PP (Simha)	HFO (IPP)	7x7.90	52	0	0	0	0	0				
151	Bosila 108MW PP(CGL)	HFO (IPP)	12x8.75+1x3.5	119	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Amtur 50 MW PP(Simha)	HFO (QRPP)	7x7.79	50	0	7	7	14	14				
Sub-Total: Plants under long term maintenance/ contract expired					404	0	7	7	14	14			
Gross Total					23332	22566	10948	9781	13543	15229	1553	2168	

(C) Actual data of 21.04.23 (Yesterday) Friday :											
01.	Max. Demand at eve. peak (Generation end)	: 9781 MW, at = 19:00 hrs									
02.	Max. Demand at eve. peak (Sub-station end)	: 9415 MW, at = 19:00 hrs									
03.	Highest Generation (Generation end)	: 12807 MW, at = 1:00 hrs									
04.	Minimum Generation (Generation end)	: 10000 MW, at = 8:00 hrs									
05.	Day-peak Generation (Generation end)	: 10948 MW, at = 12:00 hrs									
06.	Evening-peak Generation (Generation end)	: 9781 MW, at = 19:00 hrs									
07.	Evening Peak Load-shed (Sub-station end)	: 0 MW, at = 19:00 hrs									
08.	Minimum Generation Forecast up to 8:00 hrs.	: 8382 MW, at = 5:00 hrs									
09.	Generation shortfall at evening peak due to :										
	a) Gas/LF limitation	: 1303 MW									
	c) Coal supply Limitation	: 45 MW									
	b) Low water level in Kaptai lake	: 205 MW									
	c) Plants under shut down/ maintenance	: 2168 MW									
10.	Total Energy (Generation + India Import)	: 266.05 MKWh									
	By Gas = 150.437 MKWh	By Oil = 38.323 MKWh									
	By Coal = 51.098 MKWh	By Hydro = 0.299 MKWh									
	By Solar= 2.055 MKWh										
11.	Total Gas Supplied	: 1129.95 MMCFD									
(D) Forecast of 22.04.23 (Today) Saturday :											
01.	Maximum Demand	: 11200 MW (Generation end)	04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)						
02.	Maximum Generation	: 15229 MW (Generation end)	05.	Total Generation	: 232.66 MKWh						
03.	Reserve / Shortage	: 4029 MW (Generation end)	06.	Probable Max. Temperature in Dhaka :	: 38.9° C						

#Remarks: Highest Generation 15648 MW on 19-04-2023 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation