

Bangladesh Power Development Board
DAILY ELECTRICITY GENERATION REPORT

Office of the Member, Generation
Tel : 9564667, 9551095

Month April, 2023		Day : Sunday				Date : 23.04.23						
Probable Maximum Demand :		11000 MW		Probable Maximum Generation :		15386 MW						
Water Level of Kaptai Lake at 06:00 AM		Yesterday = 75.48 ft		Today = 75.40 ft		Rule Curve = 83.80 ft						
Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.04.23 (Yesterday)		23.04.23 (Today)		Rule Curve (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :			
					Day	Evening	Day	Evening	Gas/Coal/Water Limitation MW	Machines shut down (MW)		Description/ Remarks
(A) Plants in operation:												
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	0		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	180	180	180	180			
3	Ghorasal 365 MW CCPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	120	200	200	200	54	126	Gas Shortage
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	58	16	60	50		Gas Shortage
5	Tong 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
6	Haripur GTPP	Gas (PDB)	1 x 32	32	20	0	0	0	0			
7	Haripur 360MW CCPP(HPL)	Gas (IPP)	1x235+1x125	360	360	265	340	300	330			
8	Meghnaghat 450 MW CCPP(MPL)	Gas (IPP)	2x140+1x170	450	450	300	420	450	450			
9	210 MW Siddhirgonj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling
10	Haripur 412 MW CCPP	Gas (EGCB)	1x273+1x139	412	412	298	379	400	400			
11	Siddhirgonj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	210	40	58	90	100	47	105	Gas Shortage
12	Siddhirgonj 335 MW CCPP	Gas (EGCB)	1 x 217+1x118	335	335	140	218	218	218		117	ST Under maint.
13	Meghnaghat CCPP(Summit)	Gas (IPP)	2x110+1x110	335	335	294	267	300	300			
14	Madanganj-55 MW PP(Summit)	HFO (IPP)	5x17.08+1x11.3	55	55	0	0	15	15			
15	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	58	92			
16	Narshingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90	22	22	0	10	19	19			
17	Summit Power, Madhabdi+Ashulia	Gas (SIPP, REB)	8x3.67+7x3.73	80	80	26	26	46	46			
18	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	17	0	33	33			
19	Rugganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73	33	33	12	12	32	32			
20	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	42	48	48			
21	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	105	105	105			
22	Kodda 150MW PP	HFO (BRPgen)	9x17.06	149	149	0	0	145	145			
23	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	17	17	17			
24	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	300	300			
25	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	8x18.415+1x8.97	149	149	0	50	35	70			
26	Keraniganj 300 MW PP (APR)	HSD (IPP)	256x1.4	300	300	0	0	300	300			
27	Bramhangonj 100 MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	50	100			
28	Auraha 100MW PP (Aggreko)	HSD (IPP)	23x0.85+91x.959	100	100	0	0	0	80			
29	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	35	35			
30	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	35	35			
31	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	67	54	90			
32	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	168	162			
33	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	30	0	30	0			
34	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	17	34			
35	Siddhirgonj 100 MW PP(Dutch Bangla)	HFO (NENP)	12x8.9	100	100	0	0	65	65			
36	Meghnaghat 100 MW(IEI)	HFO (NENP)	12x8.9	100	100	0	43	17	50			
37	Madanganj 102 PP(Summit)	HFO (NENP)	6x17	102	102	0	0	90	90			
Dhaka Zone Total			6004	5847	1722	2492	3808	4201	256	723		
38	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	0	0	25	25	230		Low water level
39	a) Chattogram TPP-1	Gas (PDB)	1 x 210	210	180	100	120	120	120			
	b) Chattogram TPP-2	Gas (PDB)	1 x 210	210	180	0	0	0	0		180	Under maint.
40	Kaptai 7 MW Solar PP	Solar (PDB)	7	7	7	5	0	5	0			
41	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	16	25	25			
42	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	18	0	20	0			
43	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	32	26	40			
44	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	17	105	105			
45	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.
46	Sikalbaha 225 MW CCPP	Gas (PDB)	1 x 150+1 x 75	225	225	219	227	225	225			
47	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+3x8.04	300	300	100	296	120	294			
48	Juldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	50	100	50	100			
49	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	102	0	67	66	66			
50	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	40	45	60			
51	Barabkunda 22 MW PP (Regent)	Gas (SIPP, PDB)	8x2.90	22	22	13	13	11	11			
*	Malancha, Clq EPZ (United)	Gas	5x8.73+3x9.34			42	42	20	30			
52	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	12	0	51			
53	Sikalbaha 54 MW PP(Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	17	17	54			
54	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	34	17	17	34			
55	Juldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	12	63	90			
56	Juldah 100 MW Unit-1 (Acom)	HFO (QRPP)	8x13.45	100	100	0	10	55	68			
57	Chattogram 116 MW PP (Anilma Energy Ltd.)	HFO (IPP)	6x21.06	116	116	51	69	107	107			
	Mirsharai 150 MW	HFO (BRPgen)	9x18.5			0	0	0	0			on test
Chattogram Zone Total			2442	2382	632	1107	1122	1505	230	330		
58	Ashuganj 50 MW PP	Gas (APSCl)	14x3.968	53	45	34	36	41	41			
59	Ashuganj 225 MW CCPP	Gas (APSCl)	1x142+17x5	221	221	207	210	210	210			
60	Ashuganj 450 MW CCPP(South)	Gas (APSCl)	1x360	360	360	290	305	300	300			
61	Ashuganj 450 MW CCPP(North)	Gas (APSCl)	1x361	360	360	320	310	300	320			
62	Ashuganj 420 MW CCPP(East)	Gas (APSCl)	1x284+1x116	400	400	250	250	311	350			
63	Ashuganj 55 MW PP (Precision)	Gas (RPP)	15'4	55	55	0	0	0	0	55		Gas Shortage
64	Ashuganj 195MW PP (APSCl-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	0	0	195		Gas Shortage
65	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x9.34	51	51	0	20	51	51			
66	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	80	150			
67	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	36	37	40			
68	Chandpur 150 MW CCPP	Gas (PDB)	1X106+1x57	163	163	0	0	0	0		163	Under overhauling
69	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	39	155	51	51			
70	Feni 22MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	17	17	18	18			
71	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90	11	11	9	9	9	9			
72	Jangalia 33MW PP (Summit)	Gas (SIPP, PDB)	4x8.73	33	33	30	30	33	33			
73	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	0	8			
74	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	20	20	20	20			
75	Daudkandi 200 MW PP (B.Trac)	HSD (IPP)	20x1.4+40x1.515+15x1.056	200	200	0	0	0	0			
76	Feni 114 MW (Lakdanavi)	HFO (IPP)	7'18.415+1'9.78	114	114	0	0	0	114			
77	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	19	98	9	94			
78	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	17	35	35	35			
79	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+2x25.428	115	115	53	93	94	94			
**	limpopt (Tripura)	India		160	160	116	152	143	166			
Cumilla Zone Total			3159	3151	1421	1776	1742	2104	250	163		
80	RPCL 210MW CCPP	Gas (IPP)	4x35+1x70	210	202	201	207	210	210			
81	Tangail 22 MW PP (Doreen)	Gas (SIPP, PDB)	8x2.90	22	22	0	16	17	17			
82	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	77	115	100	115			
83	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	85	166	140	180			
84	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2	0	1.6	0			
85	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	52	0	50	0			
86	Tangail 22 MW PP(RPCL)	HFO (IPP)	4x6.7	22	22	0	23	22	22			
Mymensingh Zone Total			622	614	417	527	541	544	0	0		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	22.04.23 (Yesterday)		23.04.23 (Today)		22.04.23 Gen. shortfall for :		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening					
87	Fenchugon CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	35	32	35	35		38	GT-1 & ST-1 Under maint.	
88	Fenchugon CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	28	40	40		62	GT-4 Under maint.	
89	Fenchugon 51 MW PP (Barakatullah)	Gas (RPP)	19x2.90	51	51	2	50	51	51				
90	Kushiera 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0		54	ST Under maint.	
91	Hobiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90	11	11	0	8	8	8				
92	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	40	61	40	61				
93	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0		330	Under maint.	
94	Shahjibazar 86MW PP (Shahjibazar)	Gas (RPP)	32x2.90	86	86	10	85	85	84				
95	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	35	0	0	0				
96	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	17	18	20	20				
97	Sylhet 10MW PP (Desh)	Gas (RPP)	6x1.95	10	10	10	10	10	10				
98	Shahjahanulla 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	0	8	8	8	17		Gas Shortage	
99	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	290	270	280	290				
100	Bibiana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	322	335	400	400				
101	Bibiana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	300	310	400	400				
102	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		100	Under project work	
103	Fenchugon 44MW (Energyprima)	Gas (NENP)	12*3.3+5*2	50	50	0	46	44	44				
Sylhet Zone Total					2472	2427	1091	1261	1421	1451	17	584	
104	Bheramara GTTP Unit- 3	HSD (PDB)	1 x 20	20	16	0	0	0	0				
105	Bheramara 410 MW CAPP	Gas (NWPGL)	1 x 278+1 x 132	410	410	200	400	250	400	10		Gas Shortage	
106	Faridpur 50 MW Peaking PP	HFO (PDB)	8x6.98	54	54	0	0	22	35				
107	Gopalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	55	75				
108	Khulna 225 MW CAPP	HSD/ Gas (NWPGL)	1 x 150+1x75	230	230	0	0	0	0				
109	Noapara 100 MW PP (Bangla Trac)	HSD (IPP)	70x1.4+7x1.515	100	100	0	0	0	0				
110	Rupsha 105 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	17	17	17				
111	Madhumati 100 MW PP	HFO (NWPGL)	6x18.415	105	105	0	15	0	105				
112	Mongla Orion 100 MW Solar PP	Solar (IPP)		100	100	94	0	100	0				
113	Khulna 115 MW PP (KPL-2)	HFO (NENP)	7x17	115	115	0	16	85	98				
114	Noapara 40 MW PP (Khanjahan Ali)	HFO (NENP)	5*8.5	40	40	0	8	16	40				
115	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	1x617	617	617	324	291	0	0				
	Khulna 330 MW CAPP	Gas/HSD				0	0	0	0				
**	Bheramara (HVDC)	India		1000	1000	920	828	941	941				
Khulna Zone Total					3005	3001	1538	1575	1486	1711	10	0	
116	Bansal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	16	16	16				
117	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	0	34	25	35				
118	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	157	170	170	170				
119	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	550	760	750	1244				
120	Potukhali 150MW PP (UPPL)	HFO (IPP)	8x18.415+1x9.78	150	150	0	17	17	150				
121	Bansal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	0	0				
122	Bhola 220MW CAPP (Nutan Bidyut BD Ltd)	Gas/HSD	2x75+1x70	220	220	0	0	0	0		220	Under maint.	
Barishal Zone Total					2265	2265	707	997	978	1615	0	220	
123	a) Baghabari 71 MW GTTP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTTP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Gas Shortage	
124	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	26	26				
125	Baghabari 200 MW PP (Paramount)	HSD (IPP)	135x1.6	200	200	0	0	0	0				
126	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	34				
127	Chapanawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	80	80				
128	Katakhal 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	24	42				
129	Katakhal 50 MW PP (Northern)	HFO (QRPP)	6x8.9	50	50	0	0	34	42				
130	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	35	35	35				
131	Sirajgonj 225MW CAPP Unit-1	Gas (NWPGL)	1x150+1x75	210	210	140	208	200	200				
132	Sirajgonj 225MW CAPP Unit-2	Gas (NWPGL)	1x150 + 1x75	220	220	0	0	0	0	220		Gas Shortage	
133	Sirajgonj 225MW CAPP Unit-3	Gas (NWPGL)	1x141+1x79	220	220	130	172	160	160	48		Gas Shortage	
134	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	313	370	414	414	44		Gas Shortage	
135	Bogra 22 MW PP (GBB)	Gas (RPP)	6x4.0	22	22	0	22	22	22				
136	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90	11	11	8	8	8	8				
137	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	0	8				
138	Baigura 113 MW (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	95	95				
139	Baigura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	35	70				
140	Sirajgonj 6.55 MW Solar	Solar (NWPGL)	1x6	6	6	4	0	6	0				
	Adani Power Jharkhanda Ltd	Coal				446	524	500	500				
Raishahi Zone Total					2129	2129	1041	1409	1639	1736	483	0	
141	a) Barapukuria TPP Unit-1	Coal (PDB)	1 x 125	125	85	76	71	75	75	14		Coal Shortage	
	b) Barapukuria TPP Unit-2	Coal (PDB)	1 x 125	125	85	0	0	0	0	85		Under Overhauling	
142	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	180	220	200	220	220	54		Coal Shortage	
143	Rangpur 20 MW GTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
144	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*16x 2*3	113	113	0	37	42	95				
145	Saidpur 20 MW GTP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
146	Majpara, Tazula 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	7	0	8	0				
147	Thekugaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	112	35	115				
148	Lalmohini 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	35	0	30	0				
	Teesla Solar Limited	Solar (IPP)				173	0	130	0				
Rangpur Zone Total					830	750	471	440	520	505	68	85	
Sub-total: Plants in operation					22928	22566	9040.0	11584	13257	15372	1314	2105	
(B) Plants under long term maintenance/ contract expired													
149	Jamalpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924	95	0	0	0	0	0				
150	Kalipatti 52 MW PP (Sinha)	HFO (IPP)	7x7.90	52	0	0	0	0	0				
151	Bosila 108MW PP(CCL)	HFO (IPP)	12x8.75+1x3.5	108	0	0	0	0	0				
152	Keraniganj 100 MW PP (Powerpac)	HFO (QRPP)	8x13.45	100	0	0	0	0	0				
153	Ambari 50 MW PP(Sinha)	HFO (QRPP)	7x7.79	50	0	0	0	14	14				
Sub-Total: Plants under long term maintenance/ contract expired					404	0	0	0	14	14			
Gross Total					23332	22566	9040	11584	13271	15386	1314	2105	
(C) Actual data of 22.04.23 (Yesterday) Saturday :													
01.	Max. Demand at eve. peak (Generation end)	: 11606 MW, at = 21:00 hrs											
02.	Max. Demand at eve. peak (Sub-station end)	: 11150 MW, at = 21:00 hrs											
03.	Highest Generation (Generation end)	: 11764 MW, at = 22:00 hrs											
04.	Minimum Generation (Generation end)	: 8056 MW, at = 9:00 hrs											
05.	Day-peak Generation (Generation end)	: 9040 MW, at = 12:00 hrs											
06.	Evening-peak Generation (Generation end)	: 11584 MW, at = 21:00 hrs											
07.	Evening Peak Load-shed (Sub-station end)	: 21 MW, at = 21:00 hrs											
08.	Minimum Generation Forecast up to 8:00 hrs.	: 8501 MW, at = 5:00 hrs											
09.	Generation shortfall at evening peak due to :												
a)	Gas/LF limitation	: 1016 MW											
c)	Coal supply Limitation	: 68 MW											
b)	Low water level in Kaptai lake	: 230 MW											
c)	Plants under shut down/ maintenance	: 2105 MW											
10.	Total Energy (Generation + India Import)	: 239.16 MCKWh											
	By Gas = 147.798 MCKWh	By Oil = 21.402 MCKWh											
	By Coal = 42.603 MCKWh	By Hydro = 0.000 MCKWh											
	By Solar = 2.977 MCKWh												
11.	Total Gas Supplied	: 1150.10 MCMCFD											
(D) Forecast of 23.04.23 (Today) Sunday :													
01.	Maximum Demand	: 11000 MW (Generation end)											
02.	Maximum Generation	: 15386 MW (Generation end)											
03.	Reserve / Shortage	: 4386 MW (Generation end)											
04.	Maximum Load-shed	: 0 MW At evening peak (Sub-station end)											
05.	Total Generation	: 223.63 MCKWh											
06.	Probable Max. Temperature in Dhaka :	33.6° C											
				12. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :									
		Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW				
		Dhaka	3011	3011	0	Mymensingh	1117	1096	21				
		Chattogram	974	974	0	Sylhet	462	462	0				
		Khulna	1582	1582	0	Barishal	440	440	0				
		Rajshahi	1469	1469	0	Rangpur	815	815	0				
		Cumilla	1280	1280	0	Total	11150	11129	21				
		13. Fuel cost :	(a) Gas = 163193635 Taka		(c) Coal = 185125591 Taka								
			(b) Oil = 279097138 Taka		Total = 627416364 Taka								
		14. Maximum Temperature in Dhaka was :	36.2° C										
		15. Export through East-West interconnections :											